# Plumbing Attendance Sheet

## Service Record

Customer: Pine Ridge Pediatric Dentistry LLC. Claim reference: CLM-26-722023.

Visit: 2026-08-18. Address: 1505 Alder Court, Suite B.

## Cause Assessment

The inlet elbow under the handwash basin cracked at its lower socket. A chair-side assistant heard the flow before opening the suite in the morning. The plumber closed the local stop valve, removed the elbow and pressure-tested the replacement. The suction plant supply was not the leak source.

## Work Notes

The service ticket was closed on 2026-08-18 after the connection test. The technician recorded work at the connection and the accessible immediate area. Finish reinstatement was not carried out under this ticket.