MERIDIAN INDUSTRIAL GROUP - PERIODIC SAFETY AUDIT REPORT
Audit Number: AUD-2026-TEST-INGEST-01
Facility Code: FAC-001
Title: Apex Plant A Fall Semi-Annual Compliance Review
Audit Type: Safety & OSHA Compliance
Auditor Name: Marcus Vance, Lead Auditor
Date: 2026-10-25
Compliance Score: 88.5
Summary: Semi-annual inspection of manufacturing floors, stamping presses, and fire safety systems.

==========
FINDINGS AND OBSERVATIONS
==========

[FINDING 1]
Finding Code: FIND-2026-TEST-01
Title: Blocked primary emergency exit door in Bay 7
Severity: CRITICAL
Category: Fire Safety
Regulation Ref: OSHA 1910.37
Description: Emergency egress door 7B was completely obstructed by two wooden skids loaded with heavy casting parts. Exit signage partially obscured. Prior finding noted in previous inspection.
Evidence: Digital photograph DSC_0492.JPG showing pallet obstruction in door radius.

[FINDING 2]
Finding Code: FIND-2026-TEST-02
Title: Missing arc flash warning label on 480V distribution switchboard
Severity: MAJOR
Category: Electrical Safety
Regulation Ref: NFPA 70E / OSHA 1910.303
Description: Main power feed panel in mechanical mezzanine lacked standard bilingual arc flash boundary danger label and PPE requirement placard.
Evidence: Inspection observation log entry page 4.