SYNTHETIC DEMONSTRATION DOCUMENT — NOT AN OFFICIAL CERTIFICATE

STATE DIRECTORATE OF FIRE SERVICES & DISASTER MANAGEMENT (SIMULATED)

FIRE SAFETY CLEARANCE / NO OBJECTION CERTIFICATE (NOC)

This Fire Safety Certificate is issued to **Zenith Satellite Campus** situated at **Sector 14, Plot 8, Navi Mumbai, Maharashtra - 400714** following satisfactory on-site inspection of active firefighting installations and passive life safety features.

1. CERTIFICATE PARTICULARS & VALIDITY SCHEDULE

Certification Clause	Fire Safety Particulars
NOC Reference Number:	**NOC Number:** FS-NOC-5531
Institution Name & Campus:	**Institution Name:** Zenith Satellite Campus
Date of Issuance:	**Issue Date:** 01-02-2024
Valid Until / Expiry Date:	**Valid Until:** 31-12-2028
Hazard Classification:	Group B Educational (Low Hazard Occupancy)
Underground Static Water Tank:	1,50,000 Litres Dedicated Fire Reserve + 25,000L Overhead Tank
Emergency Evacuation Stairways:	2 Separate Enclosed Fire Escape Staircases (Width 2.0m each)

2. INSPECTION FINDINGS & SAFETY CONDITIONS

1. Automatic fire sprinkler system in high-hazard electrical and chemical storage labs is functional.
2. Fire hose reel systems, yard hydrants, and manual call points are tested at 7.0 bar operating pressure.
3. Illuminated emergency exit signages and battery-backed emergency lighting operational on all stairwells.
4. This certificate is valid subject to periodic bi-annual mock drill execution and maintenance log submission.

_____
Divisional Fire Officer
Fire Prevention Wing (Simulated)

_____
Chief Fire Officer
Directorate of Fire Services

Directorate Fire Stamp
NOC Reference Verified
Simulated Authority Record

FOR SOFTWARE TESTING ONLY — NO LEGAL VALIDITY