

# ProviewR

OPEN SOURCE PROCESS CONTROL



## **Guide to I/O System**

2015-07-16

Copyright © 2005-2018 SSAB EMEA AB

Permission is granted to copy, distribute and/or modify this document under the terms of the GNU Free Documentation License, Version 1.2 or any later version published by the Free Software Foundation; with no Invariant Sections, no Front-Cover Texts, and no Back-Cover Texts.

# Table of Contents

About this Guide .....	8
Introduction.....	9
Overview.....	10
Levels.....	10
Configuration.....	10
I/O System.....	11
PSS9000.....	12
Rack objekt.....	12
Rack_SSAB.....	12
Attributes.....	12
Driver.....	12
Ssab_RemoteRack.....	12
Attributes.....	12
Di cards.....	13
Ssab_BaseDiCard.....	13
Ssab_DI32D.....	13
Do cards.....	13
Ssab_BaseDoCard.....	13
Ssab_DO32KTS.....	14
Ssab_DO32KTS_Stall.....	14
Ai cards.....	14
Ssab_BaseACard.....	14
Ssab_AI8uP.....	14
Ssab_AI16uP.....	15
Ssab_AI32uP.....	15
Ssab_AI16uP_Logger.....	15
Ao cards.....	15
Ssab_AO16uP.....	15
Ssab_AO8uP.....	15
Ssab_AO8uPL.....	15
Co cards.....	15
Ssab_CO4uP.....	15
Profibus.....	17
The Profibus configurator.....	17
Address.....	18
SlaveGsdData.....	18
UserPrmData.....	18
Module.....	19
Specify the data area.....	20
Digital inputs.....	20
Analog inputs.....	21
Digital outputs.....	21
Analog outputs.....	21
Complex dataareas.....	21
Driver.....	21
Agent object.....	21

Pb_Profiboard.....	21
Slave objects.....	21
Pb_Dp_Slave.....	21
ABB_ACS_Pb_Slave.....	22
Siemens_ET200S_IM151.....	22
Siemens ET200M_IM153.....	22
Module objects.....	22
Pb_Module.....	22
ABB_ACS_PPO5.....	22
Siemens_ET200S_Ai2.....	22
Siemens_ET200S_Ao2.....	22
Siemens_ET200M_Di4.....	22
Siemens_ET200M_Di2.....	22
Siemens_ET200M_Do4.....	22
Siemens_ET200M_Do2.....	22
Profinet.....	23
The profinet configurator.....	23
Network Settings.....	24
DeviceName.....	24
IP Address.....	24
Subnet mask.....	24
MAC Address.....	25
SendClock.....	25
ReductionRatio.....	25
Phase.....	25
ByteOrdering.....	25
DeviceInfo.....	25
Device.....	25
DAP.....	25
Slot1 - Slotx.....	25
ModuleType.....	26
ModuleClass.....	26
ModuleInfo.....	26
Subslot X.....	26
Profinet viewer.....	27
Agent object.....	28
PnControllerSoftingPNAK.....	28
Device objects.....	28
PnDevice.....	28
Siemens_ET200S_PnDevice.....	28
Siemens_ET200M_PnDevice.....	28
Sinamics_G120_PnDevice.....	28
ABB_ACS_PnDevice.....	28
Module objects.....	28
PnModule.....	28
BaseFcPPO3PnModule.....	28
Sinamics_Tgm1_PnModule.....	28
Siemens_Ai2_PnModule.....	29
Siemens_Ao2_PnModule.....	29
Siemens_Di4_PnModule.....	29

Siemens_Di2_PnModule.....	29
Siemens_Do4_PnModule.....	29
Siemens_Do2_PnModule.....	29
Siemens_Do32_PnModule.....	29
Siemens_D16_PnModule.....	29
Siemens_Do8_PnModule.....	29
Siemens_Di32_PnModule.....	29
Siemens_Di16_PnModule.....	29
Siemens_Di8_PnModule.....	29
Siemens_Dx16_PnModule.....	29
Siemens_Ai8_PnModule.....	30
Siemens_Ao8_PnModule.....	30
Siemens_Ai4_PnModule.....	30
Siemens_Ao4_PnModule.....	30
Ethernet Powerlink.....	31
What Powerlink does.....	31
Main features.....	31
Powerlink facts.....	31
Proview as a MN.....	32
openCONFIGURATOR (CDC-file).....	33
Proview as a CN.....	40
Communication between two Proview nodes.....	42
Modbus TCP Client.....	43
Configuration of a device.....	44
Master.....	44
Slaves.....	44
Modules.....	45
Specify the data area.....	46
Example.....	46
Master object.....	49
Modbus_Master.....	49
Slave objects.....	49
Modbus_TCP_Slave.....	49
Module objects.....	50
Modbus_Module.....	50
Modbus TCP Server.....	51
Data areas.....	51
Unit id.....	51
Port.....	51
Hilscher cifX.....	54
SYCON.net configuration.....	54
cifX driver configuration.....	55
Proview configuration.....	55
MotionControl USB I/O.....	58
Driver.....	58
Rack object.....	58
MotonControl_USB.....	58
Card object.....	59
MotionControl_USBIO.....	59
Channels.....	59

Ai configuration.....	59
Ao configuration.....	60
Link file.....	60
Velleman K8055.....	61
Agent object.....	61
USB_Agent.....	61
Rack object.....	61
Velleman_K8055.....	61
Card object.....	62
Velleman_K8055_Board.....	62
Channels.....	62
Ai configuration.....	62
Ao configuration.....	62
Link file.....	62
Arduino Uno.....	64
Initialization of the Arduino board.....	64
USB port baud rate .....	65
I/O Configuration.....	65
Rack object.....	66
Arduino_USB.....	66
Card object.....	66
Arduino_Uno.....	66
Channels.....	66
GPIO.....	69
OneWire.....	70
OneWire_AiDevice.....	70
Maxim_DS18B20.....	70
Adaption of I/O systems.....	72
Overview.....	72
Levels.....	72
Area objects.....	73
I/O objects.....	73
Processes.....	73
Framework.....	73
Methods.....	74
Framework.....	74
Create I/O objects.....	76
Flags.....	78
Attributes.....	79
Description.....	79
Process.....	79
ThreadObject.....	79
Method objects.....	79
Agents.....	80
Racks.....	80
Cards.....	80
Connect-method for a ThreadObject.....	80
Methods.....	81
Local data structure.....	81
Agent-Methods.....	81

IoAgentInit.....	81
IoAgentClose.....	81
IoAgentRead.....	82
IoAgentWrite.....	82
IoAgentSwap.....	82
Rack-metoder.....	82
IoRackInit.....	82
IoRackClose.....	82
IoRackRead.....	82
IoRackWrite.....	82
IoRackSwap.....	82
Card-metoder.....	83
IoCardInit.....	83
IoCardClose.....	83
IoCardRead.....	83
IoCardWrite.....	83
IoCardSwap.....	83
Method registration.....	83
Class registration.....	83
Module in Proview base system.....	83
Project.....	84
Example of rack methods.....	84
Example of the methods of a digital input card.....	85
Example of the methods of a digital output card.....	88
Step by step description.....	91
Attach to a project.....	91
Create classes.....	91
Create a class volume.....	91
Open the classvolume.....	92
Create a rack class.....	93
Create a card class.....	95
Build the classvolume.....	101
Install the driver.....	101
Write methods.....	102
Class registration.....	106
Makefile.....	106
Link file.....	107
Configure the node hierarchy.....	107

# About this Guide

The *Proview Guide to I/O System* is intended for persons who will connect different kinds of I/O systems to Proview, and for users that will gain a deeper understanding of how the I/O handling or proview works. The first part is an overview of the I/O systems adapted to Proview, and the second part a description of how to adapt new I/O systems to Proview.



# Introduction

The Proview I/O handling consists of a framework that is designed to

- be portable and runnable on different platforms.
- handle I/O devices on the local bus.
- handle distributed I/O systems and communicate with remote rack systems.
- make it possible to add new I/O-systems with ease.
- allow projects to implement local I/O systems.
- synchronize the I/O-system with the execution of the plc-program, or application processes.

# Overview

The I/O devices of a process station is configured by creating objects in the Proview database. The objects are divided in two trees, the Plant hierarchy and the Node hierarchy.

The Plant hierarchy describes how the plant is structured in various process parts, motors, pumps, fans etc. Here you find signal objects that represents the values that are fetched from various sensors and switches, or values that are put out to motors, actuators etc. Signal objects are of the classes Di, Do, Ai, Ao, Ii, Io, Co or Po.

The node hierarchy describes the configuration of the process station, with server processes and I/O system. The I/O system is configured by a tree of agent, rack, card and channel objects. The channel objects represent an I/O signal attached to the computer at a channel of an I/O card (or via a distributed bus system). The channel objects are of the classes ChanDi, ChanDo, ChanAi, ChanAo, ChanIi, ChanIo and ChanCo. Each signal object in the plant hierarchy points to a channel object in the node hierarchy. The connection corresponds to the physical link between the sensor and the channel of a I/O unit.

## Levels

The I/O objects in a process station are configured in a tree structure with four levels: Agent, Rack, Card and Channel. The Channel objects can be configured as individual objects, or reside as internal attributes in a Card object.

## Configuration

When configuring an I/O system on the local bus, often the Rack and Card-levels are sufficient. A configuration can look like this. A Rack object is placed below the \$Node object, and below this a Card object for each I/O card that is installed in the rack. The card objects contains channel objects for the channels on the cards. The channel objects are connected to signal objects in the plant hierarchy. The Channels for analog signals contains attributes for measurement ranges, and the card objects contains attributes for addresses.

The configuration of a distributed I/O system is a bit different. Still the levels Agent, Rack, Card and Channel are used, but the levels has another meaning. If we take Profibus as an example, the agentlevel consist of an object for the master card that is mounted on the computer. The rack level consist of slave objects, that represent the Profibus slaves that are connected to the Profibus circuit. The card level consist of module objects that represent modules handled by the slaves. The Channel objects represent data sent on the bus from the master card to the modules or vice versa.

# I/O System

This chapter contains descriptions of the I/O systems that are implemented in Proview.

# PSS9000

PSS9000 consist of a set of I/O cards for analog input, analog output, digital input and digital output. There are also cards for counters and PID controllers. The cards are placed in a rack with the bus QBUS, a bus originally designed for DEC's PDP-11 processor. The rack is connected via a PCI-QBUS converter to an x86 PC, or connected via Ethernet, so called Remoterack.

The system is configured with objects from the SsabOx volume. There are objects representing the Rack and Carde levels. The agent level i represented by the \$Node object.

## Rack objekt

### ***Rack\_SSAB***

The Rack\_SSAB object represents a 19" PSS9000 rack with QBUS backplane. The number of card slots can vary.

The rack is connected to a x86 PC with a PCI-QBUS converter card, PCI-Q, that is installed into the PC and connected to the rack with a cable. Several racks can be connected via bus extension card.

The rack objects are placed below the \$Node objects and named C1, C2 etc (in older systems the naming convention R1, R2 etc can be found).

### **Attributes**

Rack\_SSAB doesn't contain any attributes used by the system.

### **Driver**

The PCI-QBUS converter, PCI-Q, requires installation of a driver.

### ***Ssab\_RemoteRack***

The Ssab\_RemoteRack object configures a PSS9000 rack connected via Ethernet. A BFBETH card is inserted into the rack and connected Ethernet.

The object is placed below the \$Node object and named E1, E2 etc.

### **Attributes**

<i>Attributes</i>	<i>Description</i>
Address	ip-adress for the BTBETH card.
LocalPort	Port in the process station.
RemotePort	Port for the BTBETH card. Default value 8000.
Process	Process that handles the rack. 1 the plcprogram, 2 io_comm.

<i>Attributes</i>	<i>Description</i>
ThreadObject	Thread object for the plc thread that should handle the rack. Only used if Process is 1.
StallAction	No, ResetInputs or EmergencyBreak. Default EmergencyBreak.

## Di cards

All digital input cards have a common base class, Ssab\_BaseDiCard, that contains attributes common for all di cards. The objects for each card type are extended with channel objects for the channels of the card.

### ***Ssab\_BaseDiCard***

<i>Attributes</i>	<i>Description</i>
RegAddress	QBUS address.
ErrorHardLimit	Error limit that stops the system.
ErrorSoftLimit	Error limit that sends an alarm message.
Process	Process that handles the rack. 1 the plcprogram, 2 io_comm.
ThreadObject	Thread object for the plc thread that should handle the rack. Only used if Process is 1.
ConvMask1	The conversion mask states which channels will be converted to signal values. Handles channel 1 – 16.
ConvMask2	See ConvMask1. Handles channel 17 – 32.
InvMask1	The invert mask states which channels are inverted. Handles channel 1-16.
InvMask2	See InvMask1. Handles channel 17 – 32.

### ***Ssab\_DI32D***

The object configures a digital input card of type DI32D. The card has 32 channels, which channel objects reside as internal attributes in the object. The object is placed as a child to a Rack\_SSAB or Ssab\_RemoteRack object. Attributes, see BaseDiCard.

## Do cards

All digital output cards have a common base class, Ssab\_BaseDoCard, that contains attributes that are common for all do cards. The objects for each card type are extended with channel objects for the channels of the card.

### ***Ssab\_BaseDoCard***

<i>Attributes</i>	<i>Description</i>
RegAddress	QBUS address.
ErrorHardLimit	Error limit that stops the system.
ErrorSoftLimit	Error limit that sends an alarm message.

<i>Attributes</i>	<i>Description</i>
Process	Process that handles the rack. 1 the plcprogram, 2 io_comm.
ThreadObject	Thread object for the plc thread that should handle the rack. Only used if Process is 1.
InvMask1	The invert mask states which channels are inverted. Handles channel 1-16.
InvMask2	See InvMask1. Handles channel 17 – 32.
FixedOutValue1	Bitmask for channel 1 to 16 when the I/O handling is emergency stopped. Should normally be zero.
FixedOutValue2	See FixedOutValue1. FixedOutValue2 is a bitmask for channel 17 – 32.
ConvMask1	The conversion mask states which channels will be converted to signal values. Handles channel 1 – 16.
ConvMask2	See ConvMask1. Handles channel 17 – 32.

### ***Ssab\_DO32KTS***

The object configures a digital output card of type DO32KTS. The card has 32 output channels, whose DoChan objects are internal attributes in the card object. The object is positioned as a child to a Rack\_SSAB or Ssab\_RemoteRack object. Attributes, see BaseDoCard.

### ***Ssab\_DO32KTS\_Stall***

The object configures a digital output card of type DO32KTS Stall. The card is similar to DO32KTS, but also contains a stall function, that resets the bus, i.e. all outputs are zeroed on all cards, if no write or read is done on the card in 1.5 seconds.

## **Ai cards**

All analog cards have a common base class, Ssab\_BaseACard, that contains attributes that are common for all analog cards. The objects for each card type are extended with channel objects for the channels of the card.

### ***Ssab\_BaseACard***

<i>Attribut</i>	<i>Beskrivning</i>
RegAddress	QBUS address.
ErrorHardLimit	Error limit that stops the system.
ErrorSoftLimit	Error limit that sends an alarm message.
Process	Process that handles the rack. 1 the plcprogram, 2 io_comm.
ThreadObject	Thread object for the plc thread that should handle the rack. Only used if Process is 1.

### ***Ssab\_AI8uP***

The object configures an analog input card of type Ai8uP. The card has 8 channels, whose AiChan objects are internal attributes in the card object. The object is positioned as a child to a Rack\_SSAB or Ssab\_RemoteRack object. Attributes, see BaseACard.

### ***Ssab\_AI16uP***

The object configures an analog input card of type Ai16uP. The card has 16 channels, whose AiChan objects are internal attributes in the card object. The object is positioned as a child to a Rack\_SSAB or Ssab\_RemoteRack object. Attributes, see BaseACard.

### ***Ssab\_AI32uP***

The object configures an analog input card of type Ai32uP. The card has 32 channels, whose AiChan objects are internal attributes in the card object. The object is positioned as a child to a Rack\_SSAB or Ssab\_RemoteRack object. Attributes, see BaseACard.

### ***Ssab\_AI16uP\_Logger***

The object configures an analog input card of type Ai16uP\_Logger. The card has 16 channels, whose AiChan objects are internal attributes in the card object. The object is positioned as a child to a Rack\_SSAB or Ssab\_RemoteRack object. Attributes, see BaseACard.

## **Ao cards**

### ***Ssab\_AO16uP***

The object configures an analog input card of type AO16uP. The card has 16 channels, whose AoChan objects are internal attributes in the card object. The object is positioned as a child to a Rack\_SSAB or Ssab\_RemoteRack object. Attributes, see BaseACard.

### ***Ssab\_AO8uP***

The object configures an analog input card of type AO8uP. The card has 8 channels, whose AoChan objects are internal attributes in the card object. The object is positioned as a child to a Rack\_SSAB or Ssab\_RemoteRack object. Attributes, see BaseACard.


### ***Ssab\_AO8uPL***

The object configures an analog input card of type AO8uP. The card has 8 channels, whose AoChan objects are internal attributes in the card object. The object is positioned as a child to a Rack\_SSAB or Ssab\_RemoteRack object. Attributes, see BaseACard.

## **Co cards**

### ***Ssab\_CO4uP***

The object configures a counter card of type CO4uP. The card has 4 channels, whose CoChan objects are internal attributes in the card object. The object is positioned as a child to a Rack\_SSAB or Ssab\_RemoteRack object. Attributes, see BaseACard.



**Fig PSS9000 configuration example**



# Profibus

Profibus is a fieldbus with nodes of type master and slave. The usual configuration is a monomaster system with one master and up to 125 slaves. Each slave can handle one or several modules.

In the Proview I/O handling the master represents the agent level, the slaves the rack level, and the module the card level.

Proview has support for the mastercard *Softing PROFiboard PCI* (see [www.softing.com](http://www.softing.com)) that is installed in the PCI-bus of the process station. The card is configured by an object of class Profibus:Pb\_Profiboard that is placed below the \$Node object.


Each slave connected to the Profibus circuit is configured with an object of class Pb\_DP\_Slave, or a subclass to this class. The slave objects are placed as children to the master object. For the slave objects, a Profibus configurator can be opened, that configures the slave object, and creates module object for the modules that is handled by the slave. The Profibus configurator uses the gsd-file for the slave. The gsd-file is a textfile supplied by the vendor, that describes the various configurations available for the actual slave. Before opening the Profibus configurator you has to specify the name of the gsd-file. Copy the file to \$pwrp\_exe and insert the file name into the attribute GSDfile in the slave object.

If there is a subclass present for the slave your about to configure, e.g. Siemens\_ET200S\_IM151, the gsd-file is already stated in the slave object, and the gsd-file is included in the Proview distribution.

When this operation is preformed, the Profibus configurator is opened by rightclicking on the object and activating 'Configure Slave' from the popup menu.

## The Profibus configurator

The Profibus configurator is opened for a slave object, i.e. an object of class Pb\_DP\_Slave or a subclass of this class. There has to be a readable gsd-file stated in the GSDfile attribute in the slave object.



## Address

The address of the slave is stated in the Address attribute. The address has a value in the interval 0-125 that is usually configured with switches on the slave unit.

## SlaveGsdData

The map *SlaveGsdData* contains informational data.

## UserPrmData


The map *UserPrmData* contains the parameter that can be configured for the current slave.

## Module

A slave can handle one or several modules. There are modular slaves with one single module, where the slave and the module constitutes on unit. and there are slaves of rack type, into which a large number of modules can be inserted. The Profibus configurator displays on map for each module that can be configured for the current slave.

Each slave is given an object name, e.g. M1 M2 etc. Modules on the same slave has to have different object names.

Also the module type is stated. This is chosen from a list of moduletypes supported by the current slave. The list is found below *Type*.



**Fig Module Type and Class selected**

When the type is chosen, the parameter of the selected moduletype is configured under *UserPrmData*.

You also have to state a class for the module object. At the configuration, a module object is created for each configured module. The object is of class Pb\_Module or a subclass of that class. Under


*Class* all the subclasses to Pb\_Module are listed. If you find a class corresponding to the current module type, you select this class, otherwise you select the base class Pb\_Module. The difference between the subclasses and the baseclass is that in the subclasses, the data area is specified with channel objects (see section Specify the data area).

When all the modules are configured you save by clicking on 'Ok' and leave by clicking 'Cancel'. The module objects with specified object names and classes are now created below the slave object.

If you are lucky, you will find a module object that corresponds to the current module. The criteria for the correspondence is whether the specified data area matches the current module or not. If you don't find a suitable module class there are two options: to create a new class with Pb\_Module as baseclass, extended with channel objects to specify the data area, or to configure the channel as separate objects below a Pb\_Module object. The second alternative is more convenient if there are one or a few instances. If there are several modules you should consider creating a class for the module.

## Specify the data area

The next step is to specify the data area for a module. Input modules read data that are sent to the process station over the bus, and output modules receive data from the process station. There are also modules with both input and output data, e.g. frequency converters. The data areas that are sent and received via the bus have to be configured, and this is done with channel objects. The inarea is specified with ChanDi, ChanAi and ChanIi objects, the outarea with ChanDo, ChanAo and ChanIo objects. The channel objects are placed as children to the module object, or, if you choose, do make a specific class for the module, as internal attributes in the module object. In the channel object you should set *Representation*, that specifies the format of a parameter, and in some cases also *Number* (for Bit representation). In the slave object you might have to set the *ByteOrdering* (LittleEndian or BigEndian) and *FloatRepresentation* (Intel or IEEE).



## Digital inputs

Digital input modules send the value of the inputs as bits in a word. Each input is specified with a

ChanDi object. Representation is set to Bit8, Bit16, Bit32 or Bit64 dependent on the size of the word, and in Number the bit number that contains the channel value is stated (first bit has number 0).

### **Analog inputs**

An analog input is usually transferred as a integer value and specified with a ChanAi object. Representation matches the integer format in the transfer. In some cases the value is sent as a float, and the float format has to be stated in *FloatRepresentation* (FloatIntel or FloatIEEE) in the slave object. Ranges for conversion to engineering value are specified in *RawValRange*, *ChannelSigValRange*, *SensorSigValRange* and *ActValRange* (as the signalvalue is not used *ChannelSigValRange* and *SensorSigValRange* can have the same value as *RawValRange*).

### **Digital outputs**

Digital outputs are specified with ChanDo objects. *Representation* should be set to Bit8, Bit16, Bit32 or Bit64 dependent on the transfer format.

### **Analog outputs**

Analog outputs are specified with ChanAo objects. Set *Representation* and specify ranges for conversion from engineering unit to transfer value (set *ChannelSigValRange* and *SensorSigValRange* equal to *RawValRange*).

### **Complex dataareas**

Many modules sends a mixture of integer, float, bitmasks etc. You then have to combine channel objects of different type. The channel objects should be placed in the same order as the data they represent is organized in the data area. For modules with both in and out area, the channels of the inarea i are usually placed first and thereafter the channels of the outarea.

## **Driver**

Softing PROFiBoard requires a driver to be installed. Download the driver from [www.softing.com](http://www.softing.com).

## **Agent object**

### ***Pb\_Profiboard***

Agent object for a Profibus master of type Softing PROFiBoard. The object is placed in the nodehierarchy below the \$Node object.

## **Slave objects**

### ***Pb\_Dp\_Slave***

Baseobject for a profibus slave. Reside below a Profibus agent object. In the attribute *GSDfile* the gsd-file for the current slave is stated. When the gsd-file is supplied the slave can be configured by the Profibus configurator.

### ***ABB\_ACS\_Pb\_Slave***

Slave object for a frequency converter ABB ACS800 with protocol PPO5.

### ***Siemens\_ET200S\_IM151***

Slave object for a Siemens ET200S IM151.

### ***Siemens\_ET200M\_IM153***

Slave object for a Siemens ET200M IM153.

## **Module objects**

### ***Pb\_Module***

Base class for a Profibus module. The object is created by the Profibus configurator. Placed as child to a slave object.

### ***ABB\_ACS\_PPO5***

Module object for a frequency converter ABB ACS800 with protocol PPO5.

### ***Siemens\_ET200S\_Ai2***

Module object for a Siemens ET200S module with 2 analog inputs.

### ***Siemens\_ET200S\_Ao2***

Module object for a Siemens ET200S module with 2 analog outputs.

### ***Siemens\_ET200M\_Di4***

Module object for a Siemens ET200M module with 4 digital inputs.

### ***Siemens\_ET200M\_Di2***

Module object for a Siemens ET200M module with 2 digital inputs.

### ***Siemens\_ET200M\_Do4***

Module object for a Siemens ET200M module with 4 digital outputs.

### ***Siemens\_ET200M\_Do2***

Module object for a Siemens ET200M module with 2 digital outputs.

# Profinet

Profinet is a real time ethernet standard for automation. A Profinet IO system consists of three device-types.

- The IO Controller, which controls the automation task.
- The IO Device, which is a field device, monitored and controlled by an IO Controller.
- The IO Supervisor is a software used for setting parameters and diagnosing individual IO devices. Each device can consist of several modules and submodules.

Typically you have one controller controlling multiple IO devices. It is though possible to have several controllers on the same network.

In the Proview I/O handling the controller represents the agent level, the devices the rack level, and the module the card level.

Proview has support for a Profinet stack from the company *Softing* (see [www.softing.com](http://www.softing.com)). From Proview V5.3.1 the Profinet stack is implemented as a shared library that has to be installed on the runtime station. If the Profinet I/O should be handled by the plc process the Profinet stack also has to be installed on the development station. The stack is configured by an object of class Profibus:PnControllerSoftingPNAK that is placed below the \$Node object.

Each device connected to the Profinet controller is configured with an object of class PnDevice, or a subclass to this class. The device objects are placed as children to the master. For the device objects, a Profinet configurator can be opened, that configures the device object and creates module objects for the modules that is handled by the device. The Profinet configurator uses the gsdml-file for the specific device. The gsdml-file is a text file supplied by the vendor, that describes the various configurations available for the actual device. Before opening the Profinet configurator you have to specify the name of the gsdml-file. Copy the file to \$pwrp\_exe and insert the file name into the attribute GSDMLfile in the device object.


If there is a subclass present for the device you are about to configure, e.g.

Sinamics\_G120\_PnDevice, the gsdml-file is already stated in the slave object and the gsdml-file is included in the Proview distribution.

When this operation is performed, the Profinet configurator is opened by rightclicking on the object and activating 'ConfigureDevice' from the popup menu.

## The profinet configurator

The Profinet configurator is opened for a device object, i.e. an object of class PnDevice or a subclass of this class. There has to be a readable gsdml-file stated in the GSDMLfile attribute in the device object.



## ***Network Settings***

Set the properties for the network settings.

### **DeviceName**

This is the most important setting and defines the device on the network. When IO communication starts the Profinet stack will first look up all the devices on the network by the name.

### **IP Address**

This is the ip-address of the device.

### **Subnet mask**

The subnet mask of the device. Normally it should be set to 255.255.255.0.



## **MAC Address**

The MAC Address should be given on the format XX:XX:XX:XX:XX:XX.

## **SendClock**

The send clock factor is the number to multiply with  $31,25 \mu\text{s}$  that results in the send clock. A send clock factor of 32 will give a send clock of 1 ms.

## **ReductionRatio**

Reduction ratio applied to the send clock to form the send cycle time. A send clock factor of 32 and a reduction ratio of 32 will give send cycle time of 32 ms.

## **Phase**

In case of a reduction ratio greater than one this property can be used to distribute the network traffic more evenly. E.g. For reduction ratio 3 (phase can be between 1 and 3): if phase is one, data will be sent on 1., 4., 7., etc. controller cycle (defined by the send clock). If phase is 2, it is sent on 2., 5., 8., ... cycle. Finally if phase is 3, data will be sent on 3., 6., 9., ... cycle.

## ***ByteOrdering***

Byte ordering of the device.

## ***DeviceInfo***

Information about the device as defined in the gsdml-file.

## ***Device***


Definition of the device.

## ***DAP***

The device access point is always defined on slot 0. Device-specific data is defined in it.

## ***Slot1 - Slotx***

A device can have one or several slots. The configurator will show you how many slots that can be configured. For each slot you need to configure some things.



## ModuleType

Pick the correct module type for this slot.

## ModuleClass

Pick the Proview Profinet module class for this slot. The class PnModule will be valid for all types of modules. If this is picked, IO channels will automatically be created as children to the PnModule-object corresponding to the data area for this module. In many cases there exist prepared subclasses of the PnModule-class for the specific module. This is for example the case for a Siemens ET200M device. For the prepared classes the IO channels will exist as a part of the module-object. The prepared classes should be used if they exist.

## ModuleInfo

Information about the module.

## Subslot X

On some types of modules there are some parameters that can be set that will define the behaviour of the subslot. Very often there is nothing to configure for the subslots.


When all the slots are configured you save by clicking on 'Ok' and leave by clicking 'Cancel'. The module objects with specified object names and classes are now created below the slave object.

## Profinet viewer

There is a tool for searching a network for Profinet devices. In the Proview environment the viewer is started by issuing the command:

```
profinet_viewer [device]
```

Where 'device' is for example *eth0*. By default the `profinet_viewer` will connect to *eth1*.



The tool will start searching the network for available devices by issuing a broadcast message. Active devices will respond. After a certain time (a few seconds) you will get a list of the found devices. For each found device you will get information about:

DeviceName

Ip-address

MAC-address

Vendor Id

Device Id

Family

InfoText

For each of these devices it is possible to set the DeviceName and the IP Address. It is very important that you do this for all of the devices you intend to control.

In the *Functions*-menu you can choose to 'Update' the list or to 'Set Device Properties' for the marked device.

## Agent object

### ***PnControllerSoftingPNAK***

Agent object for a Profinet controller of type Softing Profinet Stack. The object is placed in the node hierarchy below the \$Node object.

## Device objects

### ***PnDevice***

Base object for a Profinet device. Reside below a Profinet agent object. In the attribute *GSDMfile* the gsdml-file for the current device is stated. When the gsdml-file is supplied the device can be configured by the Profinet configurator.

### ***Siemens\_ET200S\_PnDevice***

Device object for a Siemens ET200S.

### ***Siemens\_ET200M\_PnDevice***

Device object for a Siemens ET200M.

### ***Sinamics\_G120\_PnDevice***

Device object for a Sinamics G120 drive.

### ***ABB\_ACS\_PnDevice***

Device object for a ABB ACS800 drive with RETA-02 interface (Profinet).

## Module objects

### ***PnModule***

Base class for a Profinet module. The object is created by the Profinet configurator. Placed as child to a device object.

### ***BaseFcPPO3PnModule***

Module object for a drive using Standard Telegram 1 / PPO3. The Io-attribute of this object can be directly connected to a drive object of type BaseFcPPO3 in the \$PlantHier. This one in turn can be connected to a function object in a plc-program of type BaseFcPPO3Fo.

### ***Sinamics\_Tgm1\_PnModule***

Module object for a drive using Standard Telegram 1. The Io-attribute of this object can be directly connected to a drive object of type Sinamics\_G120\_Tgm1 in the \$PlantHier. This one in turn can be connected to a function object in a plc-program of type Sinamics\_G120\_Tgm1Fo.

***Siemens\_Ai2\_PnModule***

Module object for a Siemens ET200 module with 2 analog inputs.

***Siemens\_Ao2\_PnModule***

Module object for a Siemens ET200 module with 2 analog outputs.

***Siemens\_Di4\_PnModule***

Module object for a Siemens ET200 module with 4 digital inputs.

***Siemens\_Di2\_PnModule***

Module object for a Siemens ET200 module with 2 digital inputs.

***Siemens\_Do4\_PnModule***

Module object for a Siemens ET200M module with 4 digital outputs.

***Siemens\_Do2\_PnModule***

Module object for a Siemens ET200 module with 2 digital outputs.

***Siemens\_Do32\_PnModule***

Module object for a Siemens ET200 module with 32 digital outputs.

***Siemens\_D16\_PnModule***

Module object for a Siemens ET200 module with 16 digital outputs.

***Siemens\_Do8\_PnModule***

Module object for a Siemens ET200 module with 8 digital outputs.

***Siemens\_Di32\_PnModule***

Module object for a Siemens ET200 module with 32 digital inputs.

***Siemens\_Di16\_PnModule***

Module object for a Siemens ET200 module with 16 digital inputs.

***Siemens\_Di8\_PnModule***

Module object for a Siemens ET200 module with 8 digital outputs.

***Siemens\_Dx16\_PnModule***

Module object for a Siemens ET200 module with 16 digital outputs and 16 digital inputs.

***Siemens\_Ai8\_PnModule***

Module object for a Siemens ET200 module with 8 analog inputs.

***Siemens\_Ao8\_PnModule***

Module object for a Siemens ET200 module with 8 analog outputs.

***Siemens\_Ai4\_PnModule***

Module object for a Siemens ET200 module with 4 analog inputs.

***Siemens\_Ao4\_PnModule***

Module object for a Siemens ET200 module with 4 analog outputs.

# Ethernet Powerlink

Powerlink is a real time ethernet protocol. Proview implements the openPOWERLINK-V1.08.2 stack through Linux userspace, the stack is pre-compiled with Proview. This makes the implementation very flexible as you can use any ethernet NIC. There is no need for special hardware to achieve hard-real time performance. A Powerlink network consists of two device-types. A MN (MN = Managing Node) and one or several CN (Controlled Node), max 239 CNs. Proview can act as both a CN and a MN but not at the same time. When creating a Powerlink network you need a configuration file, this file can be generated using openCONFIGURATOR (<http://sourceforge.net/projects/openconf/>), the file is used by the MN Powerlink stack to configure the MN and CNs. When buying a Powerlink CN you will be provided a node specific configuration file with the xdd/xdc extension, this file is imported to your openCONFIGURATOR project.

## What Powerlink does

Powerlink expands the Ethernet standard with a mixed polling and timeslicing mechanism. This enables:

- Guaranteed transfer of time-critical data in very short isochronic cycles with configurable response time.
- Time-synchronization of all nodes in the network with very high precision of sub-microseconds.
- Transmission of less time-critical data in a reserved asynchronous channel.

## Main features

One of Powerlink's key characteristics is that nodes on the network can communicate via cross-traffic, which works similar to the broadcast principle: all nodes on the network can receive data that any one sender among them supplies to the network. This way of communication does not require data to pass through the Master.

Powerlink supports all kinds of network topologies, star, tree, ring, or daisy chain, and any combination of them.

Hot plugging capabilities, easily accessible system diagnostics, and easy integration with CANopen are other features of Powerlink.

## Powerlink facts

**Network Type:** Scalable Ethernet-based advanced communication system.

**Topology:** Very flexible with line, bus, star or tree topology.

**Installation:** Hub based Ethernet transmission with shielded twisted pair cables and RJ45 connectors.

**Data Rate:** 100 Mbit/s (gigabit ready)

**Max number of stations:** 240 including the master.

**Data:** Each node: up to 1490 bytes per telegram frame. Total: theoretically 1490x239 bytes.

**Network features:** Combines the Ethernet standard with CANopen technology, plus special features developed by the ESPG.

## Preview as a MN

In Preview I/O handling the MN represents the agent level, CN the rack level and the module the card level.

When using Preview as a Powerlink MN you create an instance of the Epl\_MN class in the Node hierarchy. For every CN connected to the Powerlink network you add objects of the Epl\_CN class, or objects of subclass to this class. The CN objects are placed as children to the MN object. Some configuration is done by editing the attributes of these objects. Most of the Powerlink configuration in the CNs is done by the MN, the MN achieves this by using a file with .cdc extension. The file is created with openCONFIGURATOR.

### MN object setup example

Epl	Epl_MN
Description	
CDCfile	/home/pwrp/mnobjd.cdc
Device	eth0
NodeId	240
Process	128
ThreadObject	Nodes-Acs880-Plc-100ms
StallAction	No
Priority	0
Timeout	5
NmtState	EplNmtGsOff
Status	
ErrorCount	0
ErrorSoftLimit	25
ErrorHardLimit	50
InputAreaSize	0
OutputAreaSize	0
NumberOfSlaves	0


### CN object setup example

Epl	Epl_MN
CN1	Epl_CN
ObjectName	CN1
Description	
Specification	
DataSheet	
NodeId	1
NmtState	EplNmtGsOff
Status	
Process	128
ThreadObject	Nodes-Acs880-Plc-100ms
StallAction	No
Timeout	20
ErrorCount	0
ErrorSoftLimit	25
ErrorHardLimit	50
ByteOrdering	Little Endian
InputAreaOffset	0
InputAreaSize	0
OutputAreaOffset	0
OutputAreaSize	0




## **openCONFIGURATOR (CDC-file)**


openCONFIGURATOR can be downloaded from <http://sourceforge.net/projects/openconf/>, it is developed by a company named Kalycito. Below is a guide of how to use openCONFIGURATOR and create a small Powerlink network. You start openCONFIGURATOR by right clicking on a MN object in the node-hierarchy and then click “ConfigureEpl”. You can either create a new project or open a existing.




When creating a new project, set the MN configuration option to “default” and set Auto generate to “Yes”, press “Ok” button.




On the left the Powerlink network of the current project is displayed. Click the MN object, on the right you will now be able to insert the cycle time, after you insert the time press “Save” button. The fastest cycle time available in your Powerlink network depend on the capabilities of the present CNs, how many CNs used in the network and the total size of the process image (The MN stack used by with Proview is tested successfully with cycle times 1 – 100ms). To add a CN, right click on the MN object and click “add CN...”, in the popup window press the “Ok” button. Repeat this till all the CNs in your network is added.




Click “View” and select “Advanced view”. Right click on one of the CNs and click “Replace with XDC/XDD...”, locate the xdc/xdd file associated with the current CN (provided by the manufacturer). Repeat this for all CNs. Click all CN objects one by one and change the “PollResponse Timeout” to 270us, press “Save” button.




Now you have to create the mapping for the in and output areas. With most CNs you have to create the mapping by yourself. If you want/have to specify what data to be sent and received by the CN you begin by expanding the slave, click the plus sign left of the slave you want to map. Now you can see all the objects located in the slave, some objects is used to configure the slave and some objects contain process data (usually you only map objects containing process data). If you want to configure the CN to send a object you expand the PDO (Process data object) object, expand all the objects under PDO. It should now look something like the picture below.




The objects containing the mapping is located at the following addresses: 0x1800, 0x1A00, 0x1600, 0x1400, if they don't exist you have to create them manually, this can be done by right clicking on PDO and click “Add PDO...”, enter the address e.g 0x1800 and press “Ok”. For every object you want the CN to send, you have to create a subindex in the 0x1A00 object. Right click on the object with address 0x1A00 and click “Add SubIndex...”, enter 0x01, press “Ok”. Repeat this for every object you want the CN to send (increment the subindex). Repeat this procedure for the objects you want the CN to receive by adding subindex to object with address 0x1600. When done it should look something like the picture below. CN\_1 is configured to send two objects and receive two objects, now you have to specify the objects to send/receive.



Click the TPDO object and a view of the transmit mapping will visible on the right. Every row represents one object the CN will send, to create more rows you add more subindex to the 0x1A00 object as described above. In each row you input the offset, length, index and subindex of the object you want the CN to send (“Node Id” column should be 0x0, you only change it if you use cross-talk ). The first row always have offset 0x0000 (it is the first object in the output area). The picture below show a CN configured to send and receive two objects. The two object the CN will send have a length of 8 bits and is located at address 0x6400 subindex 0x01 and subindex 0x02. The second object must have a offset of 8 bits int the output area since the first objects occupies the first 8 bits. To map the input area of the CN you click the RPDO and add your mapping in the same way as described above.



When the mapping is completed you click the subindex objects one by one in the object at address 0x1A00 and 0x1600 and check the box next to the text “Include subindex in CDC generation”. When you've checked all the boxes, the configuration is done. Press “Build Project” button, all of the mapping and configuration will automatically be inserted to the MN obd, a directory (cdc\_xap) will be created in the working directory of the project. The configuration file mnobd.cdc is generated in this directory. Copy the .cdc file to a suitable location. When configuring the Epl\_MN object in the node-hierarchy you insert the path to the .cdc files location to the CDCfile attribute.



MN	Epl_MN
CN1	Epl_CN
M1	Epl_Module
Di_8bit_bit0	ChanDi
Di_8bit_bit1	ChanDi
Di_8bit_bit2	ChanDi
Di_8bit_bit3	ChanDi
Di_8bit_bit4	ChanDi
Di_8bit_bit5	ChanDi
Di_8bit_bit6	ChanDi
Di_8bit_bit7	ChanDi
Ai_8bit_0	ChanAi
Do_8bit_bit0	ChanDo
Do_8bit_bit1	ChanDo
Do_8bit_bit2	ChanDo
Do_8bit_bit3	ChanDo
Do_8bit_bit4	ChanDo
Do_8bit_bit5	ChanDo
Do_8bit_bit6	ChanDo
Do_8bit_bit7	ChanDo
Ao_8bit_0	ChanAo
CN2	Epl_CN
M1	Epl_Module
Ai_16bit_0	ChanAi
Ai_16bit_1	ChanAi
Ao_16bit_0	ChanAo
Ao_16bit_1	ChanAo
CN3	Epl_CN
M1	Epl_Module
Ai_32bit_0	ChanAi
Ai_32bit_1	ChanAi
Di_8bit_bit0	ChanDi
Di_8bit_bit1	ChanDi
Di_8bit_bit2	ChanDi
Di_8bit_bit3	ChanDi
Di_8bit_bit4	ChanDi
Di_8bit_bit5	ChanDi
Di_8bit_bit6	ChanDi
Di_8bit_bit7	ChanDi
Ai_8bit_2	ChanAi
Ai_16bit_3	ChanAi
Ai_16bit_4	ChanAi
Ao_32bit_0	ChanAo
Ao_32bit_1	ChanAo
Do_8bit_bit0	ChanDo
Do_8bit_bit1	ChanDo
Do_8bit_bit2	ChanDo
Do_8bit_bit3	ChanDo
Do_8bit_bit4	ChanDo
Do_8bit_bit5	ChanDo
Do_8bit_bit6	ChanDo
Do_8bit_bit7	ChanDo
Ao_8bit_2	ChanAo
Ao_16bit_3	ChanAo
Ao_16bit_4	ChanAo

```

/* This file was autogenerated by openCONFIGURATOR-1.2.2 on 15-Jul-2013 16:51:28 */
#ifndef XAP_h
#define XAP_h

# define COMPUTED_PI_OUT_SIZE 24
typedef struct
{
    unsigned CN1_M00_DigitalInput_00h_AU8_DigitalInput:8;
    unsigned CN1_M00_AnalogueInput_00h_AI8_AnalogueInput:8;
    unsigned CN2_M01_AnalogueInput_00h_AI16_AnalogueInput01:16;
    unsigned CN2_M01_AnalogueInput_00h_AI16_AnalogueInput02:16;
    unsigned PADDING_VAR_1:16;
    unsigned CN3_M02_AnalogueInput_00h_AI32_AnalogueInput01:32;
    unsigned CN3_M02_AnalogueInput_00h_AI32_AnalogueInput02:32;
    unsigned CN3_M00_DigitalInput_00h_AU8_DigitalInput:8;
    unsigned PADDING_VAR_2:8;
    unsigned CN3_M01_AnalogueInput_00h_AI16_AnalogueInput01:16;
    unsigned CN3_M01_AnalogueInput_00h_AI16_AnalogueInput02:16;
    unsigned PADDING_VAR_3:16;
} PI_OUT;

# define COMPUTED_PI_IN_SIZE 24
typedef struct
{
    unsigned CN1_M00_DigitalOutput_00h_AU8_DigitalOutput:8;
    unsigned CN1_M10_AnalogueOutput_00h_AI8_AnalogueOutput:8;
    unsigned CN2_M11_AnalogueOutput_00h_AI16_AnalogueOutput01:16;
    unsigned CN2_M11_AnalogueOutput_00h_AI16_AnalogueOutput02:16;
    unsigned PADDING_VAR_1:16;
    unsigned CN3_M12_AnalogueOutput_00h_AI32_AnalogueOutput01:32;
    unsigned CN3_M12_AnalogueOutput_00h_AI32_AnalogueOutput02:32;
    unsigned CN3_M10_AnalogueOutput_00h_AI8_AnalogueOutput:8;
    unsigned PADDING_VAR_2:8;
    unsigned CN3_M11_AnalogueOutput_00h_AI16_AnalogueOutput01:16;
    unsigned CN3_M11_AnalogueOutput_00h_AI16_AnalogueOutput02:16;
    unsigned PADDING_VAR_3:16;
} PI_IN;

```

All that remains is to insert Epl\_Module objects (or subclass objects to this class) as children to the Epl\_CN objects (or objects of subclass to Epl\_CN). When doing this it is a good idea to compare your node-hierarchy with the xap.h file, they should match. openCONFIGURATOR will 16-bit align 16-bit variables and 32-bit align 32-bit variables, it will also 32-bit align the whole in and out areas. In Proview you don't have to compensate for the padding variables added by openCONFIGURATOR (added when align). The logic behind the objects will compensate automatically when padding is needed. The pictures above is a good example of a node-hierarchy that match a xap.h file. Note that no padding variables is inserted in the node-hierarchy.

## Proview as a CN

When Proview should act as a CN you create an EPL\_CNServer object in the node hierarchy, and below this an EPL\_CnServerModule object. In the EPL\_CNServer object the network device, IP address and NodeId is specified. The NodeId is a unique number between 1 and 239 on the



Powerlink circuit, and the NodeId should also be the last number in the IP address. For example NodeId 14 will require the IP address 10.0.0.14.

CNServer	Epl_CNServer
Description	
Device	eth1
IpAddress	10.0.0.14
IpNetmask	255.255.255.0
NodeId	14
Process	128
ThreadObject	_00.0.0.0:0
StallAction	No
Priority	20
StartupTimeout	10000
Timeout	2
NmtState	EplNmtGsOff
Status	
ErrorCount	0
ErrorSoftLimit	25
ErrorHardLimit	50
InputAreaSize	0
OutputAreaSize	0

**Fig Configuration of a Epl\_CNServer object**

Under the module object, channel objects are created for signals that should be exposed for the MN. As for other bus I/O the Representation attribute in the channel objects states the format in the Powerlink message. Input channels can be written to by the MN and output channels can be read by the MN.

CNServer	Epl_CNServer
M1	Epl_CnServerModule
Di00	ChanDi
Di01	ChanDi
Di02	ChanDi
Di03	ChanDi
Di04	ChanDi
Di05	ChanDi
Di06	ChanDi
Di07	ChanDi
Di08	ChanDi
Di09	ChanDi
Ai04	ChanAi
Ai00	ChanAi
Ai05	ChanAi
Ai01	ChanAi
Ai06	ChanAi
Ai02	ChanAi
Ai03	ChanAi
Ii00	ChanIi
Ii01	ChanIi
Ii02	ChanIi
Ii03	ChanIi
Ii04	ChanIi
Ii05	ChanIi
Do00	ChanDo
Do01	ChanDo
Do02	ChanDo
Do03	ChanDo
Do04	ChanDo
Do05	ChanDo
Do06	ChanDo
Do07	ChanDo
Do08	ChanDo
Do09	ChanDo
Ao00	ChanAo
Ao01	ChanAo
Ao02	ChanAo
Ao03	ChanAo
Ao04	ChanAo
Ao05	ChanAo
Io00	ChanIo
Io04	ChanIo

**Fig CN server configuration**


When CN configuration is complete, an xdd-file is created by rightclicking on the Epl\_CnServer object in the configurator, and activating GenerateXddFile. This will create the file \$pwrp\_cnf/cnserver.xdd which can be used when configuring the Powerlink circuit.

The Powerlink server process should also be configured with a EplHandler object in the node hierarchy. When this object exist, the CN server process, rt\_powerlink\_cn, will be started.

## Communication between two Proview nodes

Powerlink can be used to send messages between two Proview nodes with realtime performance. In this case one node is configured as a MN and the other as a CN server. The CN node is configured as described in the *Proview as CN* section above, and an xdd-file is generated and used in the configuration of the MN node.

The MN node is configured with an Epl\_MN object in the node hierarchy, and below this an Epl\_CN, and below this an Epl\_Module. Under the Epl\_Module object the channel objects is created which should correspond with the channels in the CN node, with the difference that outputs here are configured as inputs, and inputs as outputs. The Epl\_MN is configured with IP address 10.0.0.240 and NodeId 240, and the Epl\_CN with the NodeId of the CN node.




**Fig MN configuration**

The Powerlink circuit also has to be configured in the openCONFIGURATOR, and this is opened


by rightclicking on the Epl\_MN object and activating ConfigureEpl. Create a new project with Default MN Configuration and AutoGenerate set to Yes.

Rightclick on the created MN node and activate *Add CN*. Enter the Node ID, select *Import XDC/XDD*, and specify the previously created xtt-file for the CN server, cnserver.xdd on \$pwrp\_cnf.



**Fig Add CN in openCONFIGURATOR**

Select the created CN node and set the PollResponse Timeout to 270 us. Save and build the project.



**Fig Circuit configuration in openCONFIGURATOR**

Copy the created configuration file

\$pwrp\_login/Documents/openCONFIGURATOR\_Projects/'projectname'/cdc\_xap/mnodb.cdc to \$pwrp\_load. This file should be distributed to the MN node with an ApplDistribute object in the directory volume.

Also the Powerlink server process should be configured with a EplHandler object in the node hierarchy in both the CN and MN node.

# Modbus TCP Client

MODBUS is an application layer messaging protocol that provides client/server communication

between devices. Proview implements the MODBUS messaging service over TCP/IP.

MODBUS is a request/reply protocol and offers services specified by function codes. For more information on the MODBUS protocol see the documents:

*MODBUS Application Protocol Specification V1.1b*

*MODBUS Messaging on TCP/IP Implementation Guide V1.0b*

Each device that is to be communicated with is configured with an object of class Modbus\_TCP\_Slave, or a subclass to this class. The interface to the device is defined by instances of the class Modbus\_Module. Each instance of the Modbus\_Module represents a function code for the service that is requested. The corresponding data area is defined with channels.

## **Configuration of a device**


### ***Master***

Insert a Modbus\_Master-object in the node-hierarchy. By default all Modbus communication will be handled by one plc-thread. Connect the master to a plc-thread.

### ***Slaves***

As children to the master-object you configure the devices that you want to communicate with. Each device will be represented by a Modbus\_TCP\_Slave-object.

Insert a Modbus\_TCP\_Slave-object in the node-hierarchy. Specify the ip-address of the MODBUS device. By default the device will be handled by a plc-thread. Connect the slave to a plc-thread. An example is given below.



## Modules

With help of Modbus\_Module's you define what type of actions you want to perform on the slave and at which address. The action is defined by a function code which means either reading or writing data to the Modbus slave. You also specify the address at which to read or write. The number of data to be read or written is defined by how you define the data area (see below).

The supported function codes are:

### *ReadCoils (FC 1)*

This function code is used to read from 1 to 2000 contiguous status of coils in a remote device. Typically the input data area is defined by a number of ChanDi's which represent the number of coils you want to read. The representation on the ChanDi should be set to Bit8.

### *ReadDiscreteInputs (FC 2)*

This function code is used to read from 1 to 2000 contiguous status of discrete inputs in a remote device. Typically the input data area is defined by a number of ChanDi's which represent the number of coils you want to read. The representation on the ChanDi should be set to Bit8.

### *ReadHoldingRegisters (FC 3)*

This function code is used to read the contents of a contiguous block of holding registers in a remote device. A register is 2 bytes long. Typically the input data area is defined by a number of ChanLi's which represent the number of registers you want to read. The representation on the ChanLi should be set to UInt16 or Int16. ChanAi and ChanDi is also applicable. In case of ChanDi the representation should be set to Bit16.

#### *ReadInputRegisters (FC 4)*

This function code is used to read from 1 to 125 contiguous input registers in a remote device. Typically the input data area is defined by a number of ChanLi's which represent the number of registers you want to read. The representation on the ChanLi should be set to UInt16 or Int16. ChanAi and ChanDi is also applicable. In case of ChanDi the representation should be set to Bit16.

#### *WriteMultipleCoils (FC 15)*

This function code is used to force each coil in a sequence of coils to either ON or OFF in a remote Device. Typically the output data area is defined by a number of ChanDo's which represent the number of coils you want to write. The representation on the ChanDo should be set to Bit8.

#### *WriteMultipleRegisters (FC 16)*

This function code is used to write a block of contiguous registers (1 to 123 registers) in a remote device. Typically the output data area is defined by a number of ChanIo's which represent the number of registers you want to write. The representation on the ChanIo should be set to UInt16 or Int16. ChanAo and ChanDo is also applicable. In case of ChanDo the representation should be set to Bit16.

## **Specify the data area**

To specify the data area a number of channel objects are placed as children to the module object. In the channel object you should set *Representation*, that specifies the format of a parameter, and in some cases also *Number* (for Bit representation). The data area is configured in much the same way as the Profibus I/O except for that you never have to think about the byte ordering which is specified by the MODBUS standard to be Big Endian.

To clarify how the data area is specified an example is given below.

### ***Example***

In this example we have a device which is a modular station of type *Schneider*. That means a station to which a number of different I/O-modules could be connected. We will use the function codes for reading and writing holding registers (FC3 and FC16). Our station consist of

1 Di 6 module

1 Do 6 module

1 Ai 2 module

1 Ao 2 module

According to the specification of this modular station the digital input module uses 2 registers, one to report data and one to report status. The digital output module uses one register to echo output data and reports one register as status. The analog input module uses 2 registers, one for each channel. The analog output module uses two registers for output data and reports 2 registers as status for each channel. Thus the data area looks like:

### **Input area**


1 register (2 bytes) digital input data, 6 lowest bits represent the inputs
1 register (2 bytes) digital input status
1 register (2 bytes) echo digital output
1 register, digital output status
1 register, analog input channel 1
1 register, analog input channel 2
1 register, echo analog output channel 1
1 register, echo analog output channel 2

## Output area


1 register digital output data, 6 lowest bits represent the outputs
1 register, analog output channel 1
1 register, analog output channel 2

## Configuration

The configuration is made with 2 Modbus modules. One will read holding registers starting at address 5391 and one will write registers starting at address 0.




The input area is configured with channels as shown below. It consists of 6 ChanDi with representation Bit16 and numbered 0-5 meaning that in the first register (2 bytes, 16 bits) we will read the 6 lowest bits to the channels. The same is done for the statuses of the digital input channels. The rest of the input registers is read with ChanLi's with representation UInt16.



The output area is configured as shown below. The digital outputs are configured with ChanDo's with representation Bit16 and numbered 0 to 5. The analog outputs are specified with 2 ChanLi's, one for the respective channel.





## Master object

### *Modbus\_Master*

Baseobject for a Modbus master. You need to have a master-object to be able to handle Modbus TCP communication at all. This is new since version V4.6.0 and was added to be able to handle the slaves in a little bit more intelligent way. Connect which plc-thread that will run the communication with the slaves.

## Slave objects

### *Modbus\_TCP\_Slave*

Baseobject for a Modbus slave. Reside in the node hierarchy and is placed as a child to a Modbus\_Master-object. The IP-address of the device is configured. See further information in the help for this class.

## Module objects

### ***Modbus\_Module***

Baseclass for a Modbus module. Placed as child to a slave object. Wanted function code is chosen. See further information in the help for this class.

# Modbus TCP Server

With the Modbus TCP Server it is possible for external SCADA and storage systems to fetch data from a Proview system via Modbus TCP. It can also be used to exchange data between Proview systems

The server is configured with a `Modbus_TCP_Server` object in the node hierarchy, and below this with a `Modbus_TCP_ServerModule` object.

## Data areas

The `Modbus_TCP_ServerModule` object handles two data areas. One area for reading, from which the clients can read at specified offsets, and one for writing, where clients can write data. Each area has a logical start address, which is stated in attributes in the `Modbus_TCP_ServerModule` object. `ReadAddress` is the start address for the read area, and `WriteAddress` is the start address for the write area. To perform a read or write operation, the client has to specify an address, and this address is the sum of the start address and the offset to the channel that is to be written or read. The start address makes it possible not to have overlapping address space for the read and write areas, which might cause confusion on the client side.

The data area are configured with channel objects below the server module. The `Representation` attributes in the channel objects states the size of each channel and how the data should be interpreted. The normal representation for Di and Do channels are `Bit8`, where the `Number` attributes specifies the bit number for the channel, and the normal representation for integer and analog channels are `Int16`.


## Unit id

Several modules can be configured in a node, by creating one `Modbus_TCP_ServerModule` object for each module. Every module object has to have a unique unit identity, which is stated in the `UnitId` attribute. This identity is used by the clients to address a specific module.


## Port

By default, the Modbus TCP communication uses the port 502.

If you, for example, want to use Modbus TCP for communication between two Proview systems, another port can be stated in the `Port` attribute of the `Modbus_TCP_Server` object. The same port also has to be specified in the slave object in the client node.



**Fig Modbus Server configuration**



**Fig Modbus Server channel configuration**

# Hilscher cifX

Hilscher cifX is a family of I/O cards handling a number of different I/O buses, CANopen, CC-Link, DeviceNet, EtherCAT, EtherNet/IP, Modbus TCP, Powerlink, Profibus, Profinet and Sercos III. The interface to Proview is the same for all the boards and buses.


The board and the devices/slaves on the bus are configured in the SYCON.net configurator on Windows. The configuration is exported to a configuration file, that is copied to the process station.

A Linux driver for the cifX card has to be installed on the process station.

The library for the interface to the driver, has to be installed on the development station.

## SYCON.net configuration

Download SYCON.net from [www.hilscher.com](http://www.hilscher.com) and install on a Window PC. Start SYCON.net, import device descriptions, eg gsd, gsdml, eds files etc.



A configuration in SYCON.net

When the configuration is finished, export it from the controller menu,

Additional Functions/Export/DBM/nxd...




Fig Export the configuration

This will create a configuration file, in some cases two files, that should be copied to the process station.

## cifX driver configuration

The Linux cifX driver should be installed on the process station. Follow the instructions to build and load the driver.

A directory tree for the driver configuration should be created under opt/cifx.

On /opt/cifx the bootloader, eg NETX100-BSL.bin, should be placed. Under /opt/cifx/deviceconfig one directory for each card is created, with the serial number as directory name, and under this a directory with the device number and serial number, eg /opt/cifx/deviceconfig/1250100/22219. On this directory a file, device.conf is created. This should contain an alias, that is the identification of the card in the Proview configuration. The alias has to correspond to the Alias attribute in the Hilscher\_cifX\_Master object.

An example of device.conf:

```
alias=PROFINET
irq=yes
```

This directory also contains a sub directory, channel0, where the firmware for the board is placed, together with the configuration files generated from SYCON.net. In the example below cifXpnm.nxf is the firmware for the Profinet controller, and config.nxd and nwid.nxd exported from the SYCON.net configuration

```
> ls /opt/cifx/deviceconfig/1250100/22219/channel0
cifXpnm.nxf
config.nxd
nwid.nxd
```


## Proview configuration

The Proview I/O configuration uses the Hilscher\_cifX\_Master, Hilscher\_cifX\_Device and Hilscher\_cifX\_Module objects, which represents the agent, rack and card levels.

Place a Hilscher\_cifX\_Master object in the node hierarchy under the \$Node object. Set the Alias attribute to the same alias as in the device.conf file for the board in the driver configuration. Set also the correct Process and ThreadObject.

Below the master object, a Hilscher\_cifX\_Device object is created for each device/slave on the bus, and below this, a Hilscher\_cifX\_Module object for each module on the device/slave. The input and output areas for the modules are configured with channel objects. Create the correct type of input and output channels, and set representation to match the structure of the areas. Read more about this in *Specify the data area* in the *Profibus* section above.


The data areas are read from, and written to, a double ported memory on the cifX board. It is important that the slave and module order, as well as the channel specification, matches the SYCON.net configuration, so that the areas for each module can be read and written on the correct offset in the double ported memory. The offset and size for each device and module are calculated at runtime, and stored in the device and module objects. These offsets and sizes can be compared with the SYCON configuration.



**Fig Hilscher cifX configuration**

The master object contains a Diagnosis object that displays the state of the board. Note that the Status attribute are displayed in decimal form, and has to be converted to hexadecimal form to be identified in the cifX manuals.





**Fig cifX diagnosis**

# MotionControl USB I/O

Motion Control USB I/O is a device manufactured by Motion Control, [www.motioncontrol.se](http://www.motioncontrol.se). The device is connected to the USB port on the pc. The unit contains 21 channels of different types, divided into 3 ports, A, B and C. The first four channels (A1 – A4) are Digital outputs of relay type for voltage up to 230 V. The next four channels (A5 – A8) are Digital inputs with optocouplers. Next eight channels (B1 – B8) can either be configured as digital outputs, digital inputs or analog inputs. The last 5 channels (C1 – C5) can be digital outputs or inputs, where C4 and C5 also can be configured as analog outputs.

In Proview USB I/O is configured with a rackobject, OtherIO:MotionControl\_USB, that is positioned in the nodehierarchy under the \$Node object, and a card object, OtherIO:MotionControl\_USBIO. Below the card object, channelobjects of the type that corresponds to the configuration of the card, are placed.

The card has a watchdog the resets the outputs of the card, if the card is not written to within a certain time.

For the moment, the driver can only handle one device.

## Driver

Download and unback the tar-file for the driver.

```
> tar -xvzf usbio.tar.tz
```

Build the driver with make

```
> cd usbio/driver/linux-2.6
> make
```

Install the driver `usbio.ko` as root

```
> insmod usbio.ko
```

Allow all to read and write to the driver

```
> chmod a+rw /dev/usbio0
```

There is also an API to the driver with an archive, `usbio/test/libusbio.a`. Copy the archive to `/usr/lib` or `$pwrp_lib` on the development station.

## Rack object

### ***MotonControl\_USB***

The rack object is placed under the \$Node object in the node hierarchy. Process should be 1.

Connect the object to a plc thread by selecting a PlcThread object and activate *Connect PlcThread* in the popup menu for the rack object.

## Card object

### ***MotionControl\_USBIO***

The card object is positioned under the rack object. Process should also here be 1 and the object should be connected to a plc thread. State the card identity, that is found on the circuit card, in the Address attribute. The watchdog is activated if a value is set in WatchdogTime, that states the timeout time in seconds.

## Channels

The channels of the card are configured under the card object with channels objects. The Number attribute of the channel object states which channel the object configures (0 – 20), and the class of the object states if the channel is used as a Di, Do, Ai or Ao. The table below displays how the channels can be configured.

<i>Channel</i>	<i>Type</i>	<i>Number</i>
A1	ChanDo	0
A2	ChanDo	1
A3	ChanDo	2
A4	ChanDo	3
A5	ChanDi	4
A6	ChanDi	5
A7	ChanDi	6
A8	ChanDi	7
B1	ChanDi, ChanDo or ChanAi	8
B2	ChanDi, ChanDo or ChanAi	9
B3	ChanDi, ChanDo or ChanAi	10
B4	ChanDi, ChanDo or ChanAi	11
B5	ChanDi, ChanDo or ChanAi	12
B6	ChanDi, ChanDo or ChanAi	13
B7	ChanDi, ChanDo or ChanAi	14
B8	ChanDi, ChanDo or ChanAi	15
C1	ChanDi or ChanDo	16
C2	ChanDi or ChanDo	17
C3	ChanDi or ChanDo	18
C4	ChanDi, ChanDo or ChanAo	19
C5	ChanDi, ChanDo or ChanAo	20

### ***Ai configuration***

The Ai channels has rawvalue range 0 – 1023 and signalvalue range 0 – 5 V, i.e. RawValRange and ChannelSigValRange should be set to

RawValRangeLow	0
RawValRangeHigh	1023
ChannelSigValRangeLow	0
ChannelSigValRangeHigh	5

For example, to configure ActualValue range to 0 – 100, set SensorSigValRange 0 - 5 and ActValRange 0 – 100.

### ***Ao configuration***

The Ao channels has rawvalue range 0 – 5 and signalvalue range 0 – 5, i.e. RawValRange and ChannelSigValRange should be set to

RawValRangeLow	0
RawValRangeHigh	5
ChannelSigValRangeLow	0
ChannelSigValRangeHigh	5

For example, to configure ActualValue range to 0 – 100, set SensorSigValRange 0 – 5 and ActValRange 0 – 100.

### **Link file**

The archive with the driver API has to be linked to the plcprogram. This is done by creating the file \$pwrp\_exe/plc\_'nodename'\_'busnumber'\_'plcname'.opt, e.g.

\$pwrp\_exe/plc\_mynode\_0517\_plc.opt with the content

```
$pwr_obj/rt_io_user.o -lpwr_rt -lusbio -lpwr_usb_dummy -lpwr_pnak_dummy
-lpwr_cifx_dummy -lpwr_nodave_dummy -lpwr_epl_dummy
```

# Velleman K8055

Velleman K8055 is an USB experiment board with 2 Ai, 5 Di, 8 Do and 2 Ao. It is can be purchased as a kit, K8055, or as an assembled board, VM110. The card can be used to test Proview with some simple application. Note that there are no watchdog or stall function on the board.

The board is quite slow, a read write cycle takes about 25 ms.

On the board are two switches for address setting, SK5 and SK6. Four different addresses can be set:

Adress	SK5	SK6
0	on	on
1	off	on
2	on	off
3	off	off

The card doesn't require any special driver, however the package libusb-1.0 has to be installed. Proview has to have read and write access to the device. The device will appear under /dev/bus/usb, e.g. /dev/bus/usb/002/003. With the command

```
> sudo chmod a+rw /dev/bus/usb/002/003
```

all users are given read and write access (use lsusb to find out the current device-name).

A more permanent solution to set write permissions on Ubuntu is to create the file /etc/rules.d/Velleman.rules with the content

```
SUBSYSTEM !="usb_device", ACTION !="add", GOTO="velleman_rules_end"
SYSFS{idVendor} == "10cf", SYSFS{idProduct} == "5502", SYMLINK+="Velleman"
MODE="0666", OWNER="pwrp", GROUP="root"
LABEL="velleman_rules_end"
```

Velleman K8055 is tested on Ubuntu 10.4. It does not work on Debian Lenny.

The card is configured in Proview with the agent object USB\_Agent, the rack object Velleman\_K8055 and the card object Velleman\_K8055\_Board.

## Agent object

### **USB\_Agent**

A USB\_Agent object is configured under the node object. This is a general object for devices that is accessed by libusb. State the Process (Plc) and plc thread in the PlcThread attribute.

## Rack object

### **Velleman\_K8055**

Under the USB\_Agent object a Velleman\_K8055 object is configured. Also in this object, the

Process and PlcThread has to be stated.

## Card object

### ***Velleman\_K8055\_Board***

Beneath the rack object, a card object of type Velleman\_K8055\_Board is configured. You can have up to 4 cards in one system. State Process and PlcThread, and state the card address in the Address attribute.

## Channels

All channelobjects reside internally in the card object, Velleman\_K8055\_Board. There are one array with two ChanAi objects, one array with 5 ChanDi objects, one array with 2 ChanAo objects, and one array with ChanDo objects. Connect the channel object to suitable signal objects.

### ***Ai configuration***

The Ai channels has rawvalue range 0 – 255 and signalvalue range 0 – 5 V, i.e. RawValRange and ChannelSigValRange should be set to

RawValRangeLow	0
RawValRangeHigh	255
ChannelSigValRangeLow	0
ChannelSigValRangeHigh	5

For example, to configure ActualValue range to 0 – 100, set SensorSigValRange 0 - 5 and ActValRange 0 – 100.

### ***Ao configuration***

The Ao channels has rawvalue range 0 – 255 and signalvalue range 0 – 5, i.e. RawValRange and ChannelSigValRange should be set to

RawValRangeLow	0
RawValRangeHigh	255
ChannelSigValRangeLow	0
ChannelSigValRangeHigh	5

For example, to configure ActualValue range to 0 – 100, set SensorSigValRange 0 – 5 and ActValRange 0 – 100.

## Link file

The archive libusb-1.0 has to be linked to the plcprogram. This is done by creating the file \$pwrp\_exe/ plc\_'nodename'\_'busnumber'\_'plcname'.opt, e.g.

\$pwrp\_exe/plc\_mynode\_0517\_plc.opt with the content

\$pwr\_obj/rt\_io\_user.o -lpwr\_rt -lusb-1.0 -lpwr\_usbio\_dummy -lpwr\_pnak\_dummy

-lpwr\_cifx\_dummy -lpwr\_nodave\_dummy -lpwr\_epl\_dummy




Fig Velleman K8055 configuration

# Arduino Uno

Interface to Arduino USB boards, e.g. Uno and Mega2560.

## Initialization of the Arduino board


Install the Arduino environment on your development station.

Connect the Arduino board to the development station and examine the device, normally /dev/ttyACM0 on linux.

Open the sketch

```
$pwr_inc/pwr_arduino_uno.ino
```

in the Arduino Development Environment. Select board type in Tools/Board in the menu, and serial port in Tools/Serial Port. Press the Upload button.



**Fig The Arduino Development Environment**



See [www.arduino.cc](http://www.arduino.cc) for more information.

## USB port baud rate

For scan times faster than 50 ms you need to increase the baud rate of the USB port. The default baud rate of 9600 gives a read write cycle of about 45 ms. By increasing the baud rate to 38400 this time is reduced to 7 ms, which makes it possible to use scan times down to 10 ms.

To change the baud rate you

- configure the baud rate in the BaudRate attribute in the Arduino\_Uno object.

- change the baud rate value in the Serial.begin() call in the pwr\_arduino\_uno sketch and upload the modified sketch to the board.




Fig Baud rate changed to 38400

## I/O Configuration

Don't use digital channels 0 and 1, which seems to interfere with the USB communication.

The card is configured in Proview with the rack object Arduino\_USB and the card object Arduino\_Uno.

## Rack object

### ***Arduino\_USB***

A *Arduino\_USB* object is configured under the node object. State the Process (Plc) and plc thread in the PlcThread attribute.

## Card object

### ***Arduino\_Uno***

Beneath the rack object, a card object of type *Arduino\_Uno* is configured. You can have several cards in one system. State Process and PlcThread and the device name of the USB port, e.g. /dev/ttyACM0.

## Channels

### **Digital channels**

Create channel objects under the *Arduino\_Uno* object. For digital channels (2-13 on Uno and 2-53 on Mega2560), create ChanDi for the pins you want to use as digital inputs, and ChanDo for the pins you want to use as digital outputs. Set attribute Number to the pin number. Connect to suitable signal objects. Only the channels that are going to be used have to be configured.

### **Ai channels**

Create ChanAi objects for the analog input channels (0-5 on Uno and 0-15 on Mega2560). Set Number to the channel number.

The Ai channels has rawvalue range 0 – 1023 and signalvalue range 0 – 5 V, i.e. RawValRange and ChannelSigValRange should be set to

RawValRangeLow	0
RawValRangeHigh	1023
ChannelSigValRangeLow	0
ChannelSigValRangeHigh	5

For example, to configure ActualValue range to 0 – 100, set SensorSigValRange 0 - 5 and ActValRange 0 – 100.


### **PWM Ao channels**

Some digital pins can be used as PWM. To configure a pin as PWM, create a ChanAo and set Number to channel number.


The PWM channels have rawvalue range 0 – 255 and signalvalue range 0 – 5 V, i.e. RawValRange and ChannelSigValRange should be set to

RawValRangeLow	0
RawValRangeHigh	255

ChannelSigValRangeLow	0
ChannelSigValRangeHigh	5



**Fig Arduino Uno configuration**




**Fig Arduino Uno channel configuration**

# GPIO

GPIO, General Purpose I/O, are available on some micro processors. As they are connected directly to the processor chip, they have very limited current and voltage tolerance, and are not ideal for use for process control. Usually some intermediate electronic circuit is needed for this type of applications.

The GPIO implementation in Proview uses the support for GPIO in the Linux kernel. GPIO has to be specified in the kernel setup.

The rack level is configured with a GPIO object, and the card level with a GPIO\_Module object. Below the card level, the GPIO channels are specified with ChanDi and ChanDo objects. In the Number attribute of the channel object, the identity of the channel is stated.



**Fig GPIO configuration**

# OneWire

1-Wire is a serial bus system with low speed data transfer.

The rack level is configured with a OneWire object, and below this, the card objects for components attached to the 1-Wire circuit.

The 1-Wire implementation in Proview uses the support for 1-Wire in the Linux kernel. 1-Wire has to be specified in the kernel setup.

1-Wire devices has an identity that has to be stated in the Address attribute of the card object. The identity should be stated in decimal form. To retrieve the identity, attach the sensor to the bus, and list the directory `/sys/bus/w1/w1\ bus\ master`.

```
> ls /sys/bus/w1/w1\ bus\ master
28-0000028fa89c
```

The first number is the family (28) and the last number is the identity (28fa89c) in hexadecimal form. This should be converted to decimal and inserted into the Address attribute.

## OneWire\_AiDevice

A generic object for an analog input device connected to the 1-wire bus.


The path of the file containing the sensor value is stated in the DataFile attribute. A `%s` in the filename will be replaced by the family and serial number, eg “28-0000028fa89c”.

A search string is stated in ValueSearchString to indicate where in the file the sensor value is located. When reading the value, the search string is searched for, and the value is expected to be found after the search string. If the search string is empty, the value will be read from the beginning of the file.

The object contains an Ai channel, that should be connected to an Ai signal. The range attributes should be set in the channel object. If the sensor value in the file is given as a integer value, set Representation to Int32, if it is given as a float, set Representation to Float32.

## Maxim\_DS18B20

Card object for a DS18B20 temperature sensor. The identity of the sensor should be stated in the Address attribute. The object contains a ChanAi object that should be connected to an Ai object. The rawvalue range is -55000 – 125000 which corresponds to an actual range of -55 – 125 C. A read operation with 12 bit resolution takes about 750 ms.



**Fig 1-Wire configuration with a DS18B20 temperature sensor**

# Adaption of I/O systems

This section will describe how to add new I/O systems to Proview.

Adding a new I/O system requires knowledge of how to create classes in Proview, and baseknowledge of c programming.

An I/O system can be added for a single project, for a number of projects, or for the Proview base system. In the latter case you have to install and build from the Proview source code.

## Overview

The I/O handling in Proview consist of a framework that identifies the I/O objects on a process node, and calls the methods of the I/O objects to fetch or transmit data.

## Levels

The I/O objects in a process node are configured in four levels: agent, rack, cards and channels. The channelobjects can be configured as individual objects or as internal objects in a card object.

To the agent, rack and card objects methods can be registered. The methods can be of type Init, Close, Read, Write or Swap, and is called by the I/O framework in a specific order. The functionality of an I/O object consists of the attributes of the object, and the registered methods of the object. Everything the framework does is to identify the objects, select the objects that are valid for the current process, and call the methods for these objects in a specific order.

Look at a centralized I/O system with digital inputcards and digital outputcards mounted on the local bus of the process node. In this case the agent level is superfluous and represented by the \$Node object. Below the \$Node object is placed a rack object with an open and a close method. The open method attaches to the driver of the I/O system. Below the rack object, cardobjects for the Di and Do cards are configured. The Di card has an Open and a Close method that initiates and closes down the card, and a Read method the fetches the values of the inputs of the card. The Do card also has Open and Close methods, and a Write method that transfers suitable values to the outputs of the card.

If we study another I/O system, Profibus, the levels are not as easy to identify as in the previous example. Profibus is a distributes system, with a master card mounted on the local PCI-bus, that communicates via a serial connection to slaves positioned in the plant. Each slave can contain modules of different type, e.g. one module with 4 Di channels, and one with 2 Ao channels. In this case the master card represents the agent level, the slaves the rack level and the modules the card level.

The Agent, rack and card levels are very flexible, and mainly defined by the attributes and the methods of the classes of the I/O system. This does not apply to the channel level that consists of the object ChanDi, ChanDo, ChanAi, ChanAo, ChanLi, ChanIo and ChanCo. The task for the channel object is to represent an input or output value on an I/O unit, and transfer this value to the signal object that is connected to the channel object. The signal object reside in the plant hierarchy and represents for example a sensor or an order to an actuator in the plant. As there is a physical



connection between the sensor in the plant and the channel on the I/O card, also the signal objects are connected to the channel object. Plcprograms, HMI and applications refer to the signal object that represents the component in the plant, not the channel object, representing a channel on an I/O unit.

## Area objects

Values that are fetched from input units and values that are put out to output units are stored in special area objects. The area objects are created dynamically in runtime and reside in the system volume under the hierarchy pwrNode-active-io. There are one area object for each signal type. Normally you refer to the value of a signal through the ActualValue attribute of the signal. This attribute actually contains a pointer that points to the area object, and the attribute ValueIndex states in which index in the area object the signal value can be found. The reason to this construction with area objects is that during the execution of a logical net, you don't want any changes of signal values. Each plc-thread therefor takes a copy of the area objects before the start of the execution, and reads signal values from the copy, calculated output signal values though, are written in the area object.

## I/O objects

The configuration of the I/O is done in the node hierarchy below the \$Node object. To each type of component in the I/O hierarchy you create a class that contains attributes and methods. The methods are of type Open, Close, Read, Write and Swap, and is called by the I/O framework. The methods connects to the bus and read data that are transferred to the area objects, or fetches data from the area objects that are put out on the bus.

## Processes

There are two system processes in Proview that calls the I/O framework, the plc process and rt\_io\_comm. In the plc process each thread makes an initialization of the I/O framework, which makes it possible to read and write I/O units synchronized with the execution of the plc code for the threads.

## Framework

The main task for the I/O framework is to identify I/O objects and call the methods that are registered for the objects.

A first initialization is made at start of the runtime environment, when the area objects are created, and each signal is allocated a place in the area object. The connections between signals and channels are also checked. When signals and channels are connected in the development environment, the identity for the channel is stored in the signals *SigChanCon* attribute. Now the identity of the signal object is put into the channels *SigChanCon* attribute, thus making it easy to find the signal from the channel.

The next initialization is made by every process that wants to connect to the I/O handling. The plc process and rt\_io\_comm does this initialization, but also applications that need to read or write directly to I/O units can connect. At the initialization a data structure is allocated with all agents, racks, cards and channels that is to be handled by the current process, and the init methods for them are called. The process then makes a cyclic call of a read and write function, that calls the read and write methods for the I/O objects in the data structure.

## Methods

The task of the methods are to initiate the I/O system, perform reading and writing to the I/O units, and finally disconnect the I/O system. How these tasks are divided, depend on the construction of the I/O system. In a centralized I/O on the local bus, methods for the different card objects can attach the bus and read and write data themselves to their unit, and the methods for the agent and rack object doesn't have much to do. In a distributed I/O the information for the units are often gathered in a package, and it is the methods of the agent or rack object that receives the package and distribute its content on different card objects. The card object methods identifies data for its channels, performs any conversion and writes or reads data in the area object.

## Framework

A process can initiate the I/O framework by calling `io_ini()`. As argument you send a bitmask that indicates which process you are, and the threads of the plc process also states the current thread. `io_init()` performs the following

- creates a context.
- allocates a hierarchic data structure of I/O objects with the levels agent, rack, card and channel. For agents a struct of type `io_sAgent` is allocated, for racks a struct of type `io_sRack`, for cards a struct of type `io_sCard`, and finally for channels a struct of type `io_sChannel`.
- searches for all I/O objects and checks their Process attributes. If the Process attribute matches the process sent as an argument to `io_init()`, the object is inserted into the data structure. If the object has a descendant that matches the process it is also inserted into the data structure. For the plc process, also the thread argument of `io_init()` is checked against the ThreadObject attribute in the I/O object. The result is a linked tree structure with the agents, racks, card and channel objects that is to be handled by the current process.
- for every I/O objects that is inserted, the methods are identified, and pointers to the method functions are fetched. Also pointers to the object and the objects name, is inserted in the data structure.
- the init methods for the I/O objects in the data structure is called. The methods of the first agent is called first, and then the first rack of the agent, the first card of the rack etc.

When the initialization is done, the process can call `io_read()` to read from the I/O units that are present in the data structure, and `io_write()` to put out values. A thread in the plc process calls `io_read()` every scan to fetch new values from the process. Then the plc-code is executed and `io_write()` is called to put out new values. The read methods are called in the same order as the init methods, and the write methods in reverse order.

When the process terminates, `io_close()` is called, which calls the close methods of the objects in the data structure. The close methods are called in reverse order compared to the init methods.

The swap method has an event argument that indicates which type of event has occurred, and in some cases also from where it is called. The swap method is called when emergency break is set and the IO should stop, and when a soft restart is performed.

When a soft restart is performed, a restart of the I/O handling is also performed. First the close methods are called, and then, during the time the restart lasts, the swap methods are called, and then the init methods. The call to the swap methods are done by `rt_io_comm`.

## io\_init, function to initiate the framework

```
pwr_tStatus io_init(
    io_mProcess    process,
    pwr_tObjid     thread,
    io_tCtx        *ctx,
    int            relativ_vector,
    float          scan_time
);
```

## io\_sCtx, the context of the framework

```
struct io_sCtx {
    io_sAgent      *agentlist;    /* List of agent structures */
    io_mProcess     Process;       /* Callers process number */
    pwr_tObjid      Thread;        /* Callers thread objid */
    int            RelativVector; /* Used by plc */
    pwr_sNode       *Node;        /* Pointer to node object */
    pwr_sClass_IOHandler *IOHandler; /* Pointer to IO Handler object */
    float          ScanTime;      /* Scantime supplied by caller */
    io_tSupCtx      SupCtx;       /* Context for supervise object lists */
};
```

## Data structure for an agent

```
typedef struct s_Agent {
    pwr_tClassId    Class;         /* Class of agent object */
    pwr_tObjid      Objid;         /* Objid of agent object */
    pwr_tOName      Name;         /* Full name of agent object */
    io_mAction      Action;       /* Type of method defined (Read/Write)*/
    io_mProcess     Process;       /* Process number */
    pwr_tStatus     (* Init) ();   /* Init method */
    pwr_tStatus     (* Close) ();  /* Close method */
    pwr_tStatus     (* Read) ();   /* Read method */
    pwr_tStatus     (* Write) ();  /* Write method */
    pwr_tStatus     (* Swap) ();   /* Write method */
    void           *op;           /* Pointer to agent object */
    pwr_tDlId       DlId;         /* DlId for agent object pointer */
    int             scan_interval; /* Interval between scans */
    int             scan_interval_cnt; /* Counter to detect next time to scan */
    io_sRack        *racklist;    /* List of rack structures */
    void           *Local;        /* Pointer to method defined data structure*/
    struct s_Agent  *next;        /* Next agent */
} io_sAgent;
```

## Datastructure for a rack

```
typedef struct s_Rack {
    pwr_tClassId    Class;         /* Class of rack object */
    pwr_tObjid      Objid;         /* Objid of rack object */
    pwr_tOName      Name;         /* Full name of rack object */
    io_mAction      Action;       /* Type of method defined (Read/Write)*/
    io_mProcess     Process;       /* Process number */
    pwr_tStatus     (* Init) ();   /* Init method */
    pwr_tStatus     (* Close) ();  /* Close method */
    pwr_tStatus     (* Read) ();   /* Read method */
    pwr_tStatus     (* Write) ();  /* Write method */
    pwr_tStatus     (* Swap) ();   /* Swap method */
    void           *op;           /* Pointer to rack object */
    pwr_tDlId       DlId;         /* DlId for rack object pointer */
};
```

```

pwr_tUInt32    size;           /* Size of rack data area in byte */
pwr_tUInt32    offset;        /* Offset to rack data area in agent */
int            scan_interval; /* Interval between scans */
int            scan_interval_cnt; /* Counter to detect next time to scan */
int            AgentControlled; /* TRUE if controlled by agent */
io_sCard       *cardlist;     /* List of card structures */
void           *Local;        /* Pointer to method defined data structure*/
struct s_Rack  *next;         /* Next rack */
} io_sRack;

```

## Data structure for a card

```

typedef struct s_Card {
    pwr_tClassId    Class;           /* Class of card object */
    pwr_tObjid      Objid;           /* Objid of card object */
    pwr_tOName      Name;            /* Full name of card object */
    io_mAction      Action;          /* Type of method defined (Read/Write)*/
    io_mProcess     Process;         /* Process number */
    pwr_tStatus     (* Init) ();      /* Init method */
    pwr_tStatus     (* Close) ();     /* Close method */
    pwr_tStatus     (* Read) ();      /* Read method */
    pwr_tStatus     (* Write) ();     /* Write method */
    pwr_tStatus     (* Swap) ();      /* Write method */
    pwr_tAddress     *op;             /* Pointer to card object */
    pwr_tDlId       DlId;            /* DlId for card object pointer */
    pwr_tUInt32     size;            /* Size of card data area in byte */
    pwr_tUInt32     offset;          /* Offset to card data area in rack */
    int             scan_interval;    /* Interval between scans */
    int             scan_interval_cnt; /* Counter to detect next time to scan */
    int             AgentControlled; /* TRUE if controlled by agent */
    int             ChanListSize;    /* Size of chanlist */
    io_sChannel     *chanlist;       /* Array of channel structures */
    void            *Local;          /* Pointer to method defined data structure*/
    struct s_Card   *next;           /* Next card */
} io_sCard;

```

## Data structure for a channel

```

typedef struct {
    void          *cop;             /* Pointer to channel object */
    pwr_tDlId     ChanDlId;         /* DlId for pointer to channel */
    pwr_sAttrRef  ChanAref;        /* AttrRef for channel */
    void          *sop;             /* Pointer to signal object */
    pwr_tDlId     SigDlId;          /* DlId for pointer to signal */
    pwr_sAttrRef  SigAref;         /* AttrRef for signal */
    void          *vbp;             /* Pointer to valuebase for signal */
    void          *abs_vbp;         /* Pointer to absvaluebase (Co only) */
    pwr_tClassId  ChanClass;        /* Class of channel object */
    pwr_tClassId  SigClass;         /* Class of signal object */
    pwr_tUInt32   size;             /* Size of channel in byte */
    pwr_tUInt32   offset;           /* Offset to channel in card */
    pwr_tUInt32   mask;            /* Mask for bit oriented channels */
} io_sChannel;

```

## Create I/O objects

For a process node the I/O system is configured in the node hierarchy with objects of type agent, rack and card. The classes for these objects are created in the class editor. The classes are defined with a \$ClassDef object, a \$ObjBodyDef object (RtBody), and below this one \$Attribute object for each attribute of the class. The attributes are determined by the functionality of the methods of the

class, but there are some common attributes (*Process*, *ThreadObject* and *Description*). In the \$ClassDef objects, the *Flag* word should be stated if it is an agent, rack or card object, and the methods are defined with specific Method objects.

It is quite common that several classes in an I/O system share attributes and maybe even methods. An input card that is available with different number of inputs, can often use the same methods. What differs is the number of channel objects. The other attributes can be stored in a baseclass, that also contains the methods-objects. The subclasses inherit both the attributes and the methods. They are extended with channel objects, that can be put as individual attributes, or, if they are of the same type, as a vector of channel objects. If the channels are put as a vector or as individual attributes, depend on the how the reference in the plc documents should look. With an array you get an index starting from zero, with individual objects you can control the naming of the attributes yourself.

In the example below a baseclass is viewed in Fig *Example of a baseclass* and a subclass in Fig *Example of a cardclass with a superclass and 32 channel objects*. The baseclass Ssab\_BaseDiCard contains all the attributes used by the I/O methods and the I/O framework. The subclass Ssab\_DI32D contains the Super attribute with TypeRef Ssab\_BaseDiCard, and 32 channel attributes of type ChanDi. As the index for this card type by tradition starts from 1, the channels are put as individual attributes, but they could also be an array of type ChanDi.




Fig Example of a baseclass for a card




Fig Example of a cardclass with a superclass an 32 channel objects

## Flags

In the *Flag* attribute of the \$ClassDef object, the *IOAgent* bit should be set for agent classes, the *IORack* bit for rack classes and the *IOCard* bit for card classes.

	<b>Rack_SSAB</b>	<b>\$ClassDef</b>	
	<b>Editor</b>	<b>0</b>	
	<b>Method</b>	<b>1</b>	
	<b>Flags</b>	<b>8208</b>	
	<b>DevOnly</b>		<input type="checkbox"/>
	<b>System</b>		<input type="checkbox"/>
	<b>Multinod</b>		<input type="checkbox"/>
	<b>ObjXRef</b>		<input type="checkbox"/>
	<b>RtBody</b>		<input checked="" type="checkbox"/>
	<b>AttrXRef</b>		<input type="checkbox"/>
	<b>ObjRef</b>		<input type="checkbox"/>
	<b>AttrRef</b>		<input type="checkbox"/>
	<b>TopObject</b>		<input type="checkbox"/>
	<b>NoAdopt</b>		<input type="checkbox"/>
	<b>Template</b>		<input type="checkbox"/>
	<b>IO</b>		<input type="checkbox"/>
	<b>IOAgent</b>		<input type="checkbox"/>
	<b>IORack</b>		<input checked="" type="checkbox"/>
	<b>IOCard</b>		<input type="checkbox"/>
	<b>HasCallBack</b>		<input type="checkbox"/>

**Fig IORack bit set for a rack class**

## Attributes

### Description

Attribute of type pwr:Type-\$String80. The content is displayed as description in the navigator.

### Process

Attribute of type pwr:Type-\$UInt32. States which process should handle the unit.

### ThreadObject

Attribute of type pwr:Type-\$Objid. States which thread in the plcprocess should handle the I/O.

	<b>Ssab_BaseDoCard</b>	<b>\$ClassDef</b>
	<b>RtBody</b>	<b>\$ObjBodyDef</b>
	<b>Description</b>	<b>\$Attribute</b>
	<b>Process</b>	<b>\$Attribute</b>
	<b>ThreadObject</b>	<b>\$Attribute</b>

**Fig Standard attributes**

## Method objects

The method objects are used to identify the methods of the class. The methods consist of c-functions that are registered in the c-code with a name, a string that consists of class name and method name, e.g. "Ssab\_AIuP-IOCardInit". The name is also stored in a method object in the class description, and makes it possible for the I/O framework to find the correct c-function for the class.

Below the \$ClassDef object, a \$RtMethod object is placed with the name IoMethods. Below this one \$Method object is placed for each method that is to be defined for the class. In the attribute MethodName the name of the method is stated.

## Agents


For agents, \$Method objects with the name IoAgentInit, IoAgentClose, IoAgentRead and IoAgentWrite are created.

## Racks

For racks, \$Method objects with the names IoRackInit, IoRackClose, IoRackRead och IoRackWrite are created.

## Cards

For cards \$Method objects with the names IoCardInit, IoCardClose, IoCardRead och IoCardWrite are created.



	Ssab_AI32uP	\$ClassDef
	RtBody	\$ObjBodyDef
	Template	Ssab_AI32uP
	IoMethods	\$RtMethod
	IoCardInit	\$Method
	MethodName	Ssab_AiuP-IoCardInit
	MethodArguments	
	IoCardClose	\$Method
	MethodName	Ssab_AiuP-IoCardClose
	MethodArguments	
	IoCardRead	\$Method
	MethodName	Ssab_AiuP-IoCardRead
	MethodArguments	

Fig Method objects

## Connect-method for a ThreadObject

When the thread object in attribute *ThreadObject* should be stated for an I/O object, it can be typed manually, but one can also specify a menu method that inserts the selected thread object into the attribute. The method is activated from the popup menu of the I/O object in the configurator.

The method is defined in the class description with a \$Menu and a \$MenuButton object, se *Fig Connect Metod*. Below the \$ClassDef object a \$Menu object with the name *ConfiguratorPoson* is placed. Below this, another \$Menu object named *Pointed*, and below this a \$MenuButton object named *Connect*. State *ButtonName* (text in the popup menu for the method), *MethodName* and *FilterName*. The method and the filter used is defined in the \$Objid class. *MethodName* should be \$Objid-Connect and *FilterName* \$Objid-IsOkConnected.






Fig Connect method

## Methods

For the agent, rack and card classes you write methods in the programming language c. A method is a c function that is common for a class (or several classes) and that is called by the I/O framework for all instances of the class. To keep the I/O handling as flexible as possible, the methods are doing most of the I/O handling work. The task for the framework is to identify the various I/O objects and to call the methods for these, and to supply the methods with proper data structures.

There are five types of methods: Init, Close, Read, Write and Swap.

- Init-method is called at initialization of the I/O handling, i.e. at start up of the runtime environment and at soft restart.
- Close-method is called when the I/O handling is terminated, i.e. when the runtime environment is stopped or at a soft restart.
- Read-method is called cyclic when its time to read the input cards.
- Write-method is called cyclic when its time to put out values to the output cards.
- Swap-method is called during a soft restart and when emergency break is set.

### Local data structure

In the data structures io\_sAgent, io\_sRack and io\_sCard there is an element, *Local*, where the method can store a pointer to local data for an I/O unit. Local data is allocated by the init method and then available at each method call.

### Agent-Methods

#### IoAgentInit

Initialization method for an agent.

```
static pwr_tStatus IoAgentInit( io_tCtx      ctx,
                               io_sAgent    *ap)
```

#### IoAgentClose

Close method för en agent.

```
static pwr_tStatus IoAgentClose( io_tCtx      ctx,  
                                io_sAgent    *ap)
```

## IoAgentRead

Read method for an agent.

```
static pwr_tStatus IoAgentRead( io_tCtx      ctx,  
                                io_sAgent    *ap)
```

## IoAgentWrite

Write method for an agent.

```
static pwr_tStatus IoAgentWrite( io_tCtx      ctx,  
                                io_sAgent    *ap)
```

## IoAgentSwap

Swap method for an agent.

```
static pwr_tStatus IoAgentSwap( io_tCtx      ctx,  
                                io_sAgent    *ap,  
                                io_eEvent    event)
```

## Rack-metoder

### IoRackInit

```
static pwr_tStatus IoRackInit( io_tCtx      ctx,  
                                io_sAgent    *ap,  
                                io_sRack     *rp)
```

### IoRackClose

```
static pwr_tStatus IoRackClose( io_tCtx      ctx,  
                                io_sAgent    *ap,  
                                io_sRack     *rp)
```

### IoRackRead

```
static pwr_tStatus IoRackRead( io_tCtx      ctx,  
                                io_sAgent    *ap,  
                                io_sRack     *rp)
```

### IoRackWrite

```
static pwr_tStatus IoRackWrite( io_tCtx      ctx,  
                                io_sAgent    *ap,  
                                io_sRack     *rp)
```

### IoRackSwap

```
static pwr_tStatus IoRackSwap( io_tCtx      ctx,  
                                io_sAgent    *ap,  
                                io_sRack     *rp,  
                                io_eEvent    event)
```

## Card-metoder

### IoCardInit

```
static pwr_tStatus IoCardInit( io_tCtx      ctx,
                              io_sAgent    *ap,
                              io_sRack     *rp,
                              io_sCard     *cp)
```

### IoCardClose

```
static pwr_tStatus IoCardClose( io_tCtx      ctx,
                                io_sAgent    *ap,
                                io_sRack     *rp,
                                io_sCard     *cp)
```

### IoCardRead

```
static pwr_tStatus IoCardRead( io_tCtx      ctx,
                               io_sAgent    *ap,
                               io_sRack     *rp,
                               io_sCard     *cp)
```

### IoCardWrite

```
static pwr_tStatus IoCardWrite( io_tCtx      ctx,
                                io_sAgent    *ap,
                                io_sRack     *rp,
                                io_sCard     *cp)
```

### IoCardSwap

```
static pwr_tStatus IoCardSwap( io_tCtx      ctx,
                               io_sAgent    *ap,
                               io_sRack     *rp,
                               io_sCard     *cp,
                               io_eEvent    event)
```

## ***Method registration***

The methods for a class have to be registered, so that you from the the method object in the class description can find the correct functions for a class. Below is an example of how the methods IoCardInit, IoCardClose and IoCardRead are registered for the class Ssab\_AiuP.

```
pwr_dExport pwr_BindIoMethods(Ssab_AiuP) = {
    pwr_BindIoMethod(IoCardInit),
    pwr_BindIoMethod(IoCardClose),
    pwr_BindIoMethod(IoCardRead),
    pwr_NullMethod
};
```

## ***Class registration***

Also the class has to be registered. This is done in different ways dependent on whether the I/O system is implemented as a module in the Proview base system, or as a part of a project.

## **Module in Proview base system**

If the I/O system are implemented as a module in the Proview base system, you create a file lib/rt/src/rt\_io\_'modulename'.meth, and list all the classes that have registered methods in this file.

## Project

If the I/O system is a part of a project, the registration is made in a c module that is linked with the plc program. In the example below, the classes Ssab\_Rack and Ssab\_Aiup are registered in the file ra\_plc\_user.c

```
#include "pwr.h"
#include "rt_io_base.h"

pwr_dImport pwr_BindIoUserMethods(Ssab_Rack);
pwr_dImport pwr_BindIoUserMethods(Ssab_Aiup);

pwr_BindIoUserClasses(User) = {
    pwr_BindIoUserClass(Ssab_Rack),
    pwr_BindIoUserClass(Ssab_Aiup),
    pwr_NullClass
};
```

The file is compiled and linked with the plc-program by creating a link file on \$pwrp\_exe. The file should be named plc\_'nodename'\_'busnumber'\_'plcname'.opt, e.g.

plc\_mynode\_0517\_plc.opt. The content of the file is sent as input data to the linker, ld, and you must also add the module with the methods of the class. In the example below these modules are supposed to be found in the archive \$pwrp\_lib/libpwrp.a.

```
$pwrp_obj/rt_io_user.o -lpwrp -lpwr_rt -lpwr_usbio_dummy -lpwr_usb_dummy -lpwr_pnak_dummy
-lpwr_cifx_dummy -lpwr_nodave_dummy -lpwr_epl_dummy
```

## Example of rack methods

```
#include <stdio.h>
#include <errno.h>
#include <unistd.h>
#include <fcntl.h>

#include "pwr.h"
#include "pwr_baseclasses.h"
#include "pwr_ssaboxclasses.h"
#include "rt_io_base.h"
#include "rt_errh.h"
#include "rt_io_rack_init.h"
#include "rt_io_m_ssab_locals.h"
#include "rt_io_msg.h"

/* Init method */
static pwr_tStatus IoRackInit( io_tCtx ctx,
                              io_sAgent *ap,
                              io_sRack *rp)
{
    io_sRackLocal *local;

    /* Open Qbus driver */
    local = calloc( 1, sizeof(*local));
    rp->Local = local;

    local->Qbus_fp = open("/dev/qbus", O_RDWR);
    if ( local->Qbus_fp == -1) {
        errh_Error( "Qbus initialization error, IO rack %s", rp->Name);
        ctx->Node->EmergBreakTrue = 1;
        return IO__ERRDEVICE;
    }
}
```

```

    errh_Info( "Init of IO rack %s", rp->Name);
    return 1;
}

/* Close method */
static pwr_tStatus IoRackClose( io_tCtx ctx,
                                io_sAgent *ap,
                                io_sRack *rp)
{
    io_sRackLocal *local;

    /* Close Qbus driver */
    local = rp->Local;

    close( local->Qbus_fp);
    free( (char *)local);

    return 1;
}

/* Every method to be exported to the workbench should be registered here. */

pwr_dExport pwr_BindIoMethods(Rack_SSAB) = {
    pwr_BindIoMethod(IoRackInit),
    pwr_BindIoMethod(IoRackClose),
    pwr_NullMethod
};

```

### ***Example of the methods of a digital input card***

```

#include <stdio.h>
#include <errno.h>
#include <unistd.h>
#include <fcntl.h>
#include <string.h>
#include <stdlib.h>

#include "pwr.h"
#include "rt_errh.h"
#include "pwr_baseclasses.h"
#include "pwr_ssaboxclasses.h"
#include "rt_io_base.h"
#include "rt_io_msg.h"
#include "rt_io_filter_di.h"
#include "rt_io_ssab.h"
#include "rt_io_card_init.h"
#include "rt_io_card_close.h"
#include "rt_io_card_read.h"
#include "qbus_io.h"
#include "rt_io_m_ssab_locals.h"

/* Local data */
typedef struct {
    unsigned int      Address[2];
    int               Qbus_fp;
    struct {
        pwr_sClass_Di *sop[16];
        void           *Data[16];
        pwr_tBoolean Found;
    } Filter[2];
    pwr_tTime         ErrTime;

```

```

} io_sLocal;

/* Init method */
static pwr_tStatus IoCardInit( io_tCtx   ctx,
                              io_sAgent *ap,
                              io_sRack  *rp,
                              io_sCard  *cp)
{
    pwr_sClass_Ssab_BaseDiCard *op;
    io_sLocal                   *local;
    int                         i, j;

    op = (pwr_sClass_Ssab_BaseDiCard *) cp->op;
    local = calloc( 1, sizeof(*local));
    cp->Local = local;

    errh_Info( "Init of di card '%s'", cp->Name);

    local->Address[0] = op->RegAddress;
    local->Address[1] = op->RegAddress + 2;
    local->Qbus_fp = ((io_sRackLocal *) (rp->Local))->Qbus_fp;

    /* Init filter */
    for ( i = 0; i < 2; i++) {
        /* The filter handles one 16-bit word */
        for ( j = 0; j < 16; j++)
            local->Filter[i].sop[j] = cp->chanlist[i*16+j].sop;
        io_InitDiFilter( local->Filter[i].sop, &local->Filter[i].Found,
                        local->Filter[i].Data, ctx->ScanTime);
    }

    return 1;
}

/* Close method */
static pwr_tStatus IoCardClose( io_tCtx   ctx,
                               io_sAgent *ap,
                               io_sRack  *rp,
                               io_sCard  *cp)
{
    io_sLocal                   *local;
    int                         i;

    local = (io_sLocal *) cp->Local;

    errh_Info( "IO closing di card '%s'", cp->Name);

    /* Free filter data */
    for ( i = 0; i < 2; i++) {
        if ( local->Filter[i].Found)
            io_CloseDiFilter( local->Filter[i].Data);
    }
    free( (char *) local);

    return 1;
}

/* Read method */
static pwr_tStatus IoCardRead( io_tCtx   ctx,
                              io_sAgent *ap,
                              io_sRack  *rp,
                              io_sCard  *cp)

```

```

{
    io_sLocal          *local;
    io_sRackLocal      *r_local = (io_sRackLocal *) (rp->Local);
    pwr_tUInt16        data = 0;
    pwr_sClass_Ssab_BaseDiCard *op;
    pwr_tUInt16        invmask;
    pwr_tUInt16        convmask;
    int                i;
    int                sts;
    qbus_io_read       rb;
    pwr_tTime          now;

    local = (io_sLocal *) cp->Local;
    op = (pwr_sClass_Ssab_BaseDiCard *) cp->op;

    for ( i = 0; i < 2; i++) {
        if ( i == 0) {
            convmask = op->ConvMask1;
            invmask = op->InvMask1;
        }
        else {
            convmask = op->ConvMask2;
            invmask = op->InvMask2;
            if ( !convmask)
                break;
            if ( op->MaxNoOfChannels == 16)
                break;
        }

        /* Read from local Q-bus */
        rb.Address = local->Address[i];
        sts = read( local->Qbus_fp, &rb, sizeof(rb));
        data = (unsigned short) rb.Data;

        if ( sts == -1) {
            /* Increase error count and check error limits */
            clock_gettime(CLOCK_REALTIME, &now);

            if (op->ErrorCount > op->ErrorSoftLimit) {
                /* Ignore if some time has expired */
                if (now.tv_sec - local->ErrTime.tv_sec < 600)
                    op->ErrorCount++;
            }
            else
                op->ErrorCount++;
            local->ErrTime = now;

            if ( op->ErrorCount == op->ErrorSoftLimit)
                errh_Error( "IO Error soft limit reached on card '%s'", cp->Name);
            if ( op->ErrorCount >= op->ErrorHardLimit)
            {
                errh_Error( "IO Error hard limit reached on card '%s', IO stopped", cp-
>Name);
                ctx->Node->EmergBreakTrue = 1;
                return IO__ERRDEVICE;
            }
            continue;
        }

        /* Invert */
        data = data ^ invmask;
    }

```

```

    /* Filter */
    if ( local->Filter[i].Found)
        io_DiFilter( local->Filter[i].sop, &data, local->Filter[i].Data);

    /* Move data to valuebase */
    io_DiUnpackWord( cp, data, convmask, i);
}
return 1;
}

/* Every method to be exported to the workbench should be registered here. */

pwr_dExport pwr_BindIoMethods(Ssab_Di) = {
    pwr_BindIoMethod(IoCardInit),
    pwr_BindIoMethod(IoCardClose),
    pwr_BindIoMethod(IoCardRead),
    pwr_NullMethod
};

```

### ***Example of the methods of a digital output card***

```

#include <stdio.h>
#include <errno.h>
#include <unistd.h>
#include <fcntl.h>
#include <string.h>
#include <stdlib.h>

#include "pwr.h"
#include "rt_errh.h"
#include "pwr_baseclasses.h"
#include "pwr_ssaboxclasses.h"
#include "rt_io_base.h"
#include "rt_io_msg.h"
#include "rt_io_filter_po.h"
#include "rt_io_ssab.h"
#include "rt_io_card_init.h"
#include "rt_io_card_close.h"
#include "rt_io_card_write.h"
#include "qbus_io.h"
#include "rt_io_m_ssab_locals.h"

/* Local data */
typedef struct {
    unsigned int    Address[2];
    int             Qbus_fp;
    struct {
        pwr_sClass_Po *sop[16];
        void          *Data[16];
        pwr_tBoolean Found;
    } Filter[2];
    pwr_tTime       ErrTime;
} io_sLocal;

/* Init method */
static pwr_tStatus IoCardInit( io_tCtx    ctx,
                               io_sAgent *ap,
                               io_sRack   *rp,
                               io_sCard   *cp)
{
    pwr_sClass_Ssab_BaseDoCard *op;
    io_sLocal                   *local;

```



```

int                i, j;

op = (pwr_sClass_Ssab_BaseDoCard *) cp->op;
local = calloc( 1, sizeof(*local));
cp->Local = local;

errh_Info( "Init of do card '%s'", cp->Name);

local->Address[0] = op->RegAddress;
local->Address[1] = op->RegAddress + 2;
local->Qbus_fp = ((io_sRackLocal *) (rp->Local))->Qbus_fp;

/* Init filter for Po signals */
for ( i = 0; i < 2; i++) {
    /* The filter handles one 16-bit word */
    for ( j = 0; j < 16; j++) {
        if ( cp->chanlist[i*16+j].SigClass == pwr_cClass_Po)
            local->Filter[i].sop[j] = cp->chanlist[i*16+j].sop;
    }
    io_InitPoFilter( local->Filter[i].sop, &local->Filter[i].Found,
                    local->Filter[i].Data, ctx->ScanTime);
}

return 1;
}

/* Close method */
static pwr_tStatus IoCardClose( io_tCtx ctx,
                                io_sAgent *ap,
                                io_sRack *rp,
                                io_sCard *cp)
{
    io_sLocal                *local;
    int                        i;

    local = (io_sLocal *) cp->Local;

    errh_Info( "IO closing do card '%s'", cp->Name);

    /* Free filter data */
    for ( i = 0; i < 2; i++) {
        if ( local->Filter[i].Found)
            io_ClosePoFilter( local->Filter[i].Data);
    }
    free( (char *) local);

    return 1;
}

/* Write method */
static pwr_tStatus IoCardWrite( io_tCtx ctx,
                                io_sAgent *ap,
                                io_sRack *rp,
                                io_sCard *cp)
{
    io_sLocal                *local;
    io_sRackLocal            *r_local = (io_sRackLocal *) (rp->Local);
    pwr_tUInt16              data = 0;
    pwr_sClass_Ssab_BaseDoCard *op;
    pwr_tUInt16              invmask;
    pwr_tUInt16              testmask;
    pwr_tUInt16              testvalue;

```

```

int          i;
qbus_io_write      wb;
int          sts;
pwr_tTime        now;

local = (io_sLocal *) cp->Local;
op = (pwr_sClass_Ssab_BaseDoCard *) cp->op;

for ( i = 0; i < 2; i++) {
    if ( ctx->Node->EmergBreakTrue && ctx->Node->EmergBreakSelect == FIXOUT) {
        if ( i == 0)
            data = op->FixedOutValue1;
        else
            data = op->FixedOutValue2;
    }
    else
        io_DoPackWord( cp, &data, i);

    if ( i == 0) {
        testmask = op->TestMask1;
        invmask = op->InvMask1;
    }
    else {
        testmask = op->TestMask2;
        invmask = op->InvMask2;
        if ( op->MaxNoOfChannels == 16)
            break;
    }

    /* Invert */
    data = data ^ invmask;

    /* Filter Po signals */
    if ( local->Filter[i].Found)
        io_PoFilter( local->Filter[i].sop, &data, local->Filter[i].Data);

    /* Testvalues */
    if ( testmask) {
        if ( i == 0)
            testvalue = op->TestValue1;
        else
            testvalue = op->TestValue2;
        data = (data & ~ testmask) | (testmask & testvalue);
    }

    /* Write to local Q-bus */
    wb.Data = data;
    wb.Address = local->Address[i];
    sts = write( local->Qbus_fp, &wb, sizeof(wb));

    if ( sts == -1) {
        /* Increase error count and check error limits */
        clock_gettime(CLOCK_REALTIME, &now);

        if (op->ErrorCount > op->ErrorSoftLimit) {
            /* Ignore if some time has expired */
            if (now.tv_sec - local->ErrTime.tv_sec < 600)
                op->ErrorCount++;
        }
        else
            op->ErrorCount++;
        local->ErrTime = now;
    }
}

```

```

        if ( op->ErrorCount == op->ErrorSoftLimit)
            errh_Error( "IO Error soft limit reached on card '%s'", cp->Name);
        if ( op->ErrorCount >= op->ErrorHardLimit)
        {
            errh_Error( "IO Error hard limit reached on card '%s', IO stopped", cp-
>Name);
            ctx->Node->EmergBreakTrue = 1;
            return IO__ERRDEVICE;
        }
        continue;
    }
}
return 1;
}

/* Every method to be exported to the workbench should be registered here. */
pwr_dExport pwr_BindIoMethods(Ssab_Do) = {
    pwr_BindIoMethod(IoCardInit),
    pwr_BindIoMethod(IoCardClose),
    pwr_BindIoMethod(IoCardWrite),
    pwr_NullMethod
};

```

## Step by step description

This sections contains an example of how to attach an I/O system to Proview.

The I/O system in the example is USB I/O manufactured by Motion Control. It consists of a card with 21 channels of different type. The first four channels (A1 – A4) are Digital outputs of relay type for voltage up to 230 V. The next four channels (A5 – A8) are Digital inputs with optocouplers. Next eight channels (B1 – B8) can either be configured as digital outputs, digital inputs or analog inputs. The last 5 channels (C1 – C5) can be digital outputs or inputs, where C4 and C5 also can be configured as analog outputs. In our example, not wanting the code to be too complex, we lock the configuration to: channel 0-3 Do, 4-7 Di, 8-15 Ai, 16-18 Di and 19-20 Ao.

## Attach to a project

In the first example we attach the I/O system to a project. We will create a class volume, and insert rack and card classes into it. We will write I/O methods for the classes and link them to the plc program. We create I/O objects i the node hierarchy in the root volume, and install the driver for USB I/O, and start the I/O handling on the process station.

### Create classes


#### Create a class volume

The first step is to create classes for the I/O objects. The classes are defined in class volumes, and first we have to create a class volume in the project. The class volume first has to registered in the GlobalVolumeList. We start the administrator with

```
> pwra
```

and opens the GlobalVolumeList by activating *File/Open/GlobalVolumeList* in the menu. We enter

edit mode and create a VolumeReg object with the name *CVolMerk1*. The volume identity for user class volumes should be chosen in the interval 0.0.2-249.1-254 and we choose 0.0.99.20 as the identity for our class volume. In the attribute Project the name of our project is stated, *mars2*.



**Fig Classvolume registration**


### **Open the classvolume**

Next step is to configure and create the class volume in the project. This is done in the directory volume.

We enter the directory volume

```
> pwr
```

in edit mode and create an object of type ClassVolumeConfig in the volume hierarchy. The object is named with the volume name *CVolMerk1*. After saving and leaving edit mode we can open the class volume by activating *OpenClassEditor...* in the popup menu of the object.




**Fig Configuration of the classvolume in the directory volume and start of classeditor**

In the classeditor classes are defined with specific class definition objects. We are going to create two classes, a rack class, *MotionControl\_USB* and a card class *MotionControl\_USBIO*.

Note! The class names has to be unique, which actually is not true for these names any more as they exist in the volume OtherIO.

### **Create a rack class**

In our case the card class will do all the work and contain all the methods. The rack class is there only to inhabit the rack level, and doesn't have any methods or attributes. We will only put a description attribute in the class. We create a \$ClassHier object, and under this a \$ClassDef object for the class rack. The object is named *MotionControl\_USB* and we set the IORack and IO bits in the Flag attribute.



**Fig The IO and IORack bits in Flags**

Below the \$ClassDef object the attributes of the class are defined. We create a \$ObjBodyDef object and below this a \$Attribute object with the name Description and with type (TypeRef) pwr:Type-\$String80.





Fig Attribute object

### Create a card class


There is a baseclass for card objects, *Basecomponent:BaseIOCard*, that we can use, and that contains the most common attributes in a card object. We create another *\$ClassDef* object with the name *MotionControl\_USBIO*, and set the *IOCard* and *IO* bits in the *Flags* attribute.



**Fig The IO and IOCard bits in Flags**


We create an \$ObjBodyDef object and an \$Attribute object to state BaseIOCard as a superclass. The attribute is named Super and in TypeRef Basecomponent:Class-BaseIOCard is set. We will now inherit all attributes and methods defined in the class BaseIOCard.






**Fig Configuration of the superclass BaseIOCard**

We add another attribute for the card status, and for the status we create an enumeration type, MotionControl\_StatusEnum, that contains the various status codes that the status attribute can contain.



**Fig Definition of an enumeration type**

The type of the status attribute is set to the created status type, and in Flags, the bits *State* and *NoEdit* is set, as this attribute is not to be set in the configurator, but will be given a value in the runtime environment.




**Fig Status attribute of enumeration type**

Normally you also add attributes for the channel objects in the card class, but as the USB I/O device is so flexible, the same channel can be configured as a Di, Do or Ai channel, we choose not to place the channel objects as attributes. They will be configured as individual objects and placed as children to the card object in the root volume.

USB I/O contains a watchdog that will reset the unit if it is not written to within a certain time. We also add the attribute WatchdogTime to configure the timeout time.


When a class is saved for the first time, a Template object is created under the \$ClassDef object. This object is an instance of the actual class where you can set default values of the attributes. We state Specification, insert an URL to the data sheet, and set Process to 1. We also set MaxNoOfChannels to 21, as this card has 21 channels.



**Fig Template object**

Next step is to add the methods to the class description. While the card contains both inputs and outputs, we need to create Init, Close, Read and Write methods. These will be configured with method objects of type \$Method. First we put a \$RtMethod object, named IoMethods, under the \$ClassDef object. Below this, we create one \$RtMethod object for each method. The objects are named IoCardInit, IoCardClose, IoCardRead and IoCardWrite. In the attribute MethodName we state the string with which the methods will be registered in the c-code, i.e.

“MotionControl\_USBIO-IoCardInit”, etc.



**Fig I/O method configuration**

From the superclass BaseIOCard we inherit a method to connect the object to a plc thread in the configurator.

### **Build the classvolume**

Now the classes are created, and we save, leave edit mode, and create loadfiles for the class volume by activating *Functions/Build Volume* in the menu. An include-file containing c structs for the classes, \$pwrp\_inc/pwr\_cvolmerk1classes.h, is also created when building the volume.

### **Install the driver**

Download the driver and unpack the tar-file for the driver

```
> tar -xvzf usbio.tar.tz
```

Build the driver with make

```
> cd usbio/driver/linux-2.6
```

```
> make
```

Install the driver usbio.ko as root

```
> insmod usbio.ko
```

Allow all users to read and write to the driver

```
> chmod a+rw /dev/usbio0
```

## Write methods

The next step is to write the c-code for the methods.

The c-file `ra_io_m_motioncontrol_usb.c` are created on `$pwrp_src`.

As Proview has a GPL license, also the code for the methods has to be GPL licensed if the program is distributed to other parties. We therefor put a GPL header in the beginning of the file.

To simplify the code we limit our use of USB I/O to a configuration where channel 0-3 are digital outputs, 4-7 digital inputs, 8-15 analog inputs, 16-18 digital inputs and 19-20 analog outputs.

### `ra_io_m_motioncontrol_usb.c`

```
/*
 * Proview    $Id$
 * Copyright (C) 2005 SSAB Oxelösund.
 *
 * This program is free software; you can redistribute it and/or
 * modify it under the terms of the GNU General Public License as
 * published by the Free Software Foundation, either version 2 of
 * the License, or (at your option) any later version.
 *
 * This program is distributed in the hope that it will be useful
 * but WITHOUT ANY WARRANTY; without even the implied warranty of
 * MERCHANTABILITY or FITNESS FOR A PARTICULAR PURPOSE. See the
 * GNU General Public License for more details.
 *
 * You should have received a copy of the GNU General Public License
 * along with the program, if not, write to the Free Software
 * Foundation, Inc., 675 Mass Ave, Cambridge, MA 02139, USA.
 */

#include "pwr.h"
#include "pwr_basecomponentclasses.h"
#include "pwr_cvolmerklclasses.h"
#include "rt_io_base.h"
#include "rt_io_card_init.h"
#include "rt_io_card_close.h"
#include "rt_io_card_read.h"
#include "rt_io_card_write.h"
#include "rt_io_msg.h"
#include "libusbio.h"

typedef struct {
    int USB_Handle;
} io_sLocal;

// Init method
static pwr_tStatus IoCardInit( io_tCtx ctx,
                               io_sAgent *ap,
                               io_sRack *rp,
                               io_sCard *cp)
{
    int i;
    int timeout;
    io_sLocal *local;
    pwr_sClass_MotionControl_USBIO *op = (pwr_sClass_MotionControl_USBIO *)cp->op;

    local = (io_sLocal *) calloc( 1, sizeof(io_sLocal));
    cp->Local = local;
}
```

```

// Configure 4 Do and 4 Di on Port A
op->Status = USBIO_ConfigDIO( &local->USB_Handle, 1, 240);
if ( op->Status)
    errh_Error( "IO Init Card '%s', Status %d", cp->Name, op->Status);

// Configure 8 Ai on Port B
op->Status = USBIO_ConfigAI( &local->USB_Handle, 8);
if ( op->Status)
    errh_Error( "IO Init Card '%s', Status %d", cp->Name, op->Status);

// Configure 3 Di and 2 Ao on Port C
op->Status = USBIO_ConfigDIO( &local->USB_Handle, 3, 7);
if ( op->Status)
    errh_Error( "IO Init Card '%s', Status %d", cp->Name, op->Status);
op->Status = USBIO_ConfigAO( &local->USB_Handle, 3);
if ( op->Status)
    errh_Error( "IO Init Card '%s', Status %d", cp->Name, op->Status);

// Calculate conversion coefficients for Ai
for ( i = 8; i < 16; i++) {
    if ( cp->chanlist[i].cop &&
        cp->chanlist[i].sop &&
        cp->chanlist[i].ChanClass == pwr_cClass_ChAi)
        io_AiRangeToCoef( &cp->chanlist[i]);
}

// Calculate conversion coefficients for Ao
for ( i = 19; i < 21; i++) {
    if ( cp->chanlist[i].cop &&
        cp->chanlist[i].sop &&
        cp->chanlist[i].ChanClass == pwr_cClass_ChAo)
        io_AoRangeToCoef( &cp->chanlist[i]);
}

// Configure Watchdog
timeout = 1000 * op->WatchdogTime;
op->Status = USBIO_ConfigWatchdog( &local->USB_Handle, 1, timeout, 1,
                                   port_mask, port, 3);

errh_Info( "Init of USBIO card '%s'", cp->Name);

return IO__SUCCESS;
}

// Close method
static pwr_tStatus IoCardClose( io_tCtx ctx,
                                io_sAgent *ap,
                                io_sRack *rp,
                                io_sCard *cp)
{
    free( cp->Local);
    return IO__SUCCESS;
}

// Read Method
static pwr_tStatus IoCardRead( io_tCtx ctx,
                                io_sAgent *ap,
                                io_sRack *rp,

```

```

        io_sCard  *cp)
{
    io_sLocal *local = cp->Local;
    pwr_sClass_MotionControl_USBIO *op = (pwr_sClass_MotionControl_USBIO *)cp->op;
    int value = 0;
    int i;
    unsigned int m;
    pwr_tUInt32 error_count = op->Super.ErrorCount;

    // Read Di on channel 4 - 8
    op->Status = USBIO_ReadDI( &local->USB_Handle, 1, &value);
    if ( op->Status)
        op->Super.ErrorCount++;
    else {
        // Set Di value in area object
        m = 1 << 4;
        for ( i = 4; i < 8; i++) {
            *(pwr_tBoolean *)cp->chanlist[i].vbp = ((value & m) != 0);
            m = m << 1;
        }
    }

    // Read Ai on channel 8 - 16
    for ( i = 0; i < 8; i++) {
        io_sChannel *chanp = &cp->chanlist[i + 8];
        pwr_sClass_ChanaAi *cop = (pwr_sClass_ChanaAi *)chanp->cop;
        pwr_sClass_Ai *sop = (pwr_sClass_Ai *)chanp->sop;

        if ( cop->CalculateNewCoef)
            // Request to calculate new coefficients
            io_AiRangeToCoef( chanp);

        op->Status = USBIO_ReadADVal( &local->USB_Handle, i + 1, &ivalue);
        if ( op->Status)
            op->Super.ErrorCount++;
        else {
            io_ConvertAi( cop, ivalue, &actvalue);

            // Filter the Ai value
            if ( sop->FilterType == 1 &&
                sop->FilterAttribute[0] > 0 &&
                sop->FilterAttribute[0] > ctx->ScanTime) {
                actvalue = *(pwr_tFloat32 *)chanp->vbp +
                    ctx->ScanTime / sop->FilterAttribute[0] *
                    (actvalue - *(pwr_tFloat32 *)chanp->vbp);
            }

            // Set value in area object
            *(pwr_tFloat32 *)chanp->vbp = actvalue;
            sop->SigValue = cop->SigValPolyCoef1 * ivalue + cop->SigValPolyCoef0;
            sop->RawValue = ivalue;
        }
    }

    // Check Error Soft and Hard Limit

    // Write warning message if soft limit is reached
    if ( op->Super.ErrorCount >= op->Super.ErrorSoftLimit &&
        error_count < op->Super.ErrorSoftLimit)
        errh_Warning( "IO Card ErrorSoftLimit reached, '%s'", cp->Name);

    // Stop I/O if hard limit is reached

```



```

if ( op->Super.ErrorCount >= op->Super.ErrorHardLimit) {
    errh_Error( "IO Card ErrorHardLimit reached '%s', IO stopped", cp->Name);
    ctx->Node->EmergBreakTrue = 1;
    return IO__ERRDEVICE;
}

return IO__SUCCESS;
}

// Write method
static pwr_tStatus IoCardWrite( io_tCtx ctx,
                                io_sAgent *ap,
                                io_sRack *rp,
                                io_sCard *cp)
{
    io_sLocal *local = cp->Local;
    pwr_sClass_MotionControl_USBIO *op = (pwr_sClass_MotionControl_USBIO *)cp->op;
    int value = 0;
    float fvalue;
    int i;
    unsigned int m;
    pwr_tUInt32 error_count = op->Super.ErrorCount;
    pwr_sClass_Chao *cop;

    // Write Do on channel 1 - 4
    m = 1;
    value = 0;
    for ( i = 0; i < 4; i++) {
        if ( *(pwr_tBoolean *)cp->chanlist[i].vbp)
            value |= m;
    }
    m = m << 1;
}
op->Status = USBIO_WriteDO( &local->USB_Handle, 1, value);
if ( op->Status) op->Super.ErrorCount++;

// Write Ao on channel 19 and 20
if ( cp->chanlist[19].cop &&
    cp->chanlist[19].sop &&
    cp->chanlist[19].ChanClass == pwr_cClass_Chao) {
    cop = (pwr_sClass_Chao *)cp->chanlist[19].cop;

    if ( cop->CalculateNewCoef)
        // Request to calculate new coefficients
        io_AoRangeToCoef( &cp->chanlist[19]);

    fvalue = *(pwr_tFloat32 *)cp->chanlist[19].vbp * cop->OutPolyCoef1 +
        cop->OutPolyCoef0;
    op->Status = USBIO_WriteAO( &local->USB_Handle, 1, fvalue);
    if ( op->Status) op->Super.ErrorCount++;
}

if ( cp->chanlist[20].cop &&
    cp->chanlist[20].sop &&
    cp->chanlist[20].ChanClass == pwr_cClass_Chao) {
    cop = (pwr_sClass_Chao *)cp->chanlist[20].cop;

    if ( cop->CalculateNewCoef)
        // Request to calculate new coefficients
        io_AoRangeToCoef( &cp->chanlist[20]);

    fvalue = *(pwr_tFloat32 *)cp->chanlist[20].vbp * cop->OutPolyCoef1 +

```

```

        cop->OutPolyCoef0;
    op->Status = USBIO_WriteAO( &local->USB_Handle, 2, fvalue);
    if ( op->Status) op->Super.ErrorCount++;
}

// Check Error Soft and Hard Limit

// Write warning message if soft limit is reached
if ( op->Super.ErrorCount >= op->Super.ErrorSoftLimit &&
    error_count < op->Super.ErrorSoftLimit)
    errh_Warning( "IO Card ErrorSoftLimit reached, '%s'", cp->Name);

// Stop I/O if hard limit is reached
if ( op->Super.ErrorCount >= op->Super.ErrorHardLimit) {
    errh_Error( "IO Card ErrorHardLimit reached '%s', IO stopped", cp->Name);
    ctx->Node->EmergBreakTrue = 1;
    return IO__ERRDEVICE;
}

return IO__SUCCESS;
}

// Every method should be registred here

pwr_dExport pwr_BindIoUserMethods(MotionControl_USBIO) = {
    pwr_BindIoUserMethod(IoCardInit),
    pwr_BindIoUserMethod(IoCardClose),
    pwr_BindIoUserMethod(IoCardRead),
    pwr_BindIoUserMethod(IoCardWrite),
    pwr_NullMethod
};

```

## Class registration

To make it possible for the I/O framework to find the methods of the class, the class has to be registered. This is done by creating the file `$pwrp_src/rt_io_user.c`. You use the macros `pwr_BindIoUserMethods` and `pwr_BindIoUserClass` for each class that contains methods.

### rt\_io\_user.c

```

#include "pwr.h"
#include "rt_io_base.h"

pwr_dImport pwr_BindIoUserMethods(MotionControl_USBIO);

pwr_BindIoUserClasses(User) = {
    pwr_BindIoUserClass(MotionControl_USBIO),
    pwr_NullClass
};

```

## Makefile

To compile the c-files we create a make-file on `$pwrp_src`, `$pwrp_src/makefile`. This will compile `ra_io_m_motioncontro_usbio.c` and `rt_io_user.c`, and place the object modules on the directory `$pwrp_obj`.

### makefile

```

mars2_top : mars2

include $(pwr_exe)/pwrp_rules.mk

```

```

mars2_modules = $(pwrp_obj)/ra_io_m_motioncontrol_usbio.o \
                $(pwrp_obj)/rt_io_user.o

# Main rule
mars2 : $(mars2_modules)
        @ echo "***** Mars2 modules built *****"

# Modules

$(pwrp_obj)/ra_io_m_motioncontrol_usbio.o : \
)/ra_io_m_motioncontrol_usbio.c \
        $(pwrp_inc)/pwr_cvolmerk1classes.h

$(pwrp_obj)/rt_io_user.o : $(pwrp_src)/rt_io_user.c

```

## Link file

We choose to call the methods from the plc process, and have to link the plc program with the object modules of the methods. To do this, we create a link file on \$pwrp\_exe. We also have to add the archive with the USB I/O driver API, `libusbio.a`. The name of the link file contains node name and bus number.

### plc\_mars2\_0507\_plc.opt

```

$pwrp_obj/rt_io_user.o $pwrp_obj/ra_io_m_motioncontrol_usbio.o -lpwr_rt \
-lusbio -lpwr_usb_dummy -lpwr_pnak_dummy -lpwr_cifx_dummy -lpwr_nodave_dummy \
-lpwr_epl_dummy

```


## Configure the node hierarchy

Now its time to configure the I/O objects in the node hierarchy with objects of the classes that we have created.

The root volume in our project is VolMerk1 and we open the configurator with

```
> pwrns volmerk1
```


In the palette to the left, under the map AllClasses we find the class volume of the project, and under this the two classes for the USB I/O that we have created. Below the \$Node object we place a rack-object of class MotionControl\_USB, and below this a card object of class MotionControl\_USBIO. As the channel objects are not internal objects in the card object, we have to create channel objects for the channels that we are going to use, below the card object. See the result in *Fig The Node hierarchy*.



**Fig The Node hierarchy**


We set the attribute Number, which states the index in the channel list, to 0 for the first channel object, 1 for the second etc. We set Process to 1 in the rack and card objects, and connects these objects to a plc thread by selecting a PlcThread object, and activating Connect PlcThread in the popup menu for the rack and card object.

For the analog channels, ranges for conversion to/from ActualValue unit, has to be stated. The RawValue range for Ai channels are 0-1023, and the signal range 0-5 V. We configure the channels with an ActualValue range 0-100 in *Fig Ai channel*.



**Fig Ai channel**

When reading the Ao channels, you receive the signal value 0-5 V, and a configuration for ActualValue range 0-100 can be seen in *Fig Ao channel*.



**Fig Ao channel**

We also have to create signal objects in the plant hierarchy of types Di, Do, Ai and Ao, and connect these to each channel respectively. There also has to be a PlcPgm on the selected thread, to really create a thread in runtime. The remaining activities now are to build the node, distribute, check the linkage of the USB I/O device, connect it to the USB port and start Preview.