

Guide to I/O System

Copyright SSAB Oxelösund AB 2007

Permission is granted to copy, distribute and/or modify this document under the terms of the GNU Free Documentation License, Version 1.2 or any later version published by the Free Software Foundation; with no Invariant Sections, no Front-Cover Texts, and no Back-Cover Texts.

Table of Contents

About this Guide	6
Introduction	7
Overview	8
Levels	8
Configuration	8
I/O System	9
PSS9000	10
Rack objekt	10
Rack_SSAB	10
Attributes	10
Driver	10
Ssab_RemoteRack	10
Attributes	10
Di card	11
Ssab_BaseDiCard	11
Ssab_DI32D	11
Do cards	11
Ssab_BaseDoCard	11
Ssab_DO32KTS	12
Ssab_DO32KTS_Stall	12
Ai cards	12
Ssab_BaseACard	12
Ssab_AI8uP	12
Ssab_AI16uP	13
Ssab_AI32uP	13
Ssab_AI16uP_Logger	13
Ao cards	13
Ssab_AO16uP	13
Ssab_AO8uP	13
Ssab_AO8uPL	13
Co kort	13
Ssab_CO4uP	
Profibus	
The profibus configuator	
Address	
SlaveGsdData	17
UserPrmData	17
Module	17
Specify the data area	19
Digital inputs	
Analog inputs	
Digital outputs	
Analog outputs	
Complex dataareas.	
Driver	
Agent object	20

Pb_Profiboard	20
Slave objects	20
Pb_Dp_Slave	20
ABB_ACS_Pb_Slave	20
Siemens_ET200S_IM151	20
Siemens ET200M_IM153	20
Module objects	21
Pb_Module	21
ABB_ACS_PPO5	21
Siemens_ET200S_Ai2	21
Siemens_ET200S_Ao2	21
Siemens_ET200M_Di4	21
Siemens_ET200M_Di2	21
Siemens_ET200M_Do4	21
Siemens_ET200M_Do2	21
MODBUS TCP	22
Configuration of a device	
Modules	23
Specify the data area	23
Example	24
Slave objects	27
Modbus_TCP_Slave	27
Module objects	27
Modbus_Module	27
MotionControl USB I/O	28
Driver	28
Rack object	28
MotonControl_USB	28
Kortobjekt	29
MotionControl_USBIO	29
Channels	29
Ai configuration	29
Ao configuration	30
Link file	30
Adaption of I/O systems	31
Overview	31
Levels	31
Area objekt	32
I/O objects	32
Processes	32
Framework	32
Methods	33
Framework	33
Create I/O objects	
Flags	37
Attributes	38
Description	38
Process	38
ThreadObject	
Method objects	38

Agents	39
Racks	39
Cards	39
Connect-method for a ThreadObject	39
Methods	
Local data structure	40
Agent-Methods	40
IoAgentInit	40
IoAgentClose	40
IoAgentRead	41
IoAgentWrite	41
IoAgentSwap	41
Rack-metoder	41
IoRackInit	41
IoRackClose	41
IoRackRead	41
IoRackWrite	41
IoRackSwap	41
Card-metoder	41
IoCardInit	41
IoCardClose	42
IoCardRead	42
IoCardWrite	42
IoCardSwap	42
Method registration	42
Class registration	42
Module in Proview base system	42
Project	42
Example of rack methods	43
Example of the methods of a digital input card	44
Example of the methods of a digital output card	
Step by step description	
Attach to a project	50
Create classes	50
Create a class volume	50
Open the classvolume	51
Create a rack class	52
Create a card class	53
Build the classvolume	59
Install the driver	59
Write methods	60
Class registration	64
Makefile	64
Link file	65
Configure the node hierarchy	65

About this Guide

The *Proview Guide to I/O System* is intended for persons who will connect different kinds of I/O systems to Proview, and for users that will gain a deeper understanding of how the I/O handling or proview works. The first part is an overview of the I/O systems adapted to Proview, and the second part a description of how to adapt new I/O systems to Proview.

Introduction

The Proview I/O handling consists of a framework that is designed to

- be portable and runnable on different platforms.
- handle I/O devices on the local bus.
- handle distributed I/O systems and communicate with remote rack systems.
- make it possible to add new I/O-systems with ease.
- allow projects to implement local I/O systems.
- synchronize the I/O-system with the execution of the plc-program, or application processes.

Overview

The I/O devices of a process station is configured by creating objects in the Proview database. The objects are divided in two trees, the Plant hierarchy and the Node hierarchy.

The Plant hierarchy describes how the plant is structured in various process parts, motors, pumps, fans etc. Here you find signal objects that represents the values that are fetched from various sensors and switches, or values that are put out to motors, actuators etc. Signal objects are of the classes Di, Do, Ai, Ao, Ii, Io, Co or Po.

The node hierarchy describes the configuration of the process station, with server processes and I/O system. The I/O system is configured by a tree of agent, rack, card and channel objects. The channel objects represent an I/O signal attached to the computer at a channel of an I/O card (or via a distributed bus system). The channel objects are of the classes ChanDi, ChanDo, ChanAi, ChanAo, ChanIi, ChanIo and ChanCo. Each signal object in the plant hierarchy points to a channel object in the node hierarchy. The connection corresponds to the physical link between the sensor and the channel of a I/O unit.

Levels

The I/O objects in a process station are configured in a tree structure with four levels: Agent, Rack, Card and Channel. The Channel objects can be configured as individual objects, or reside as internal attributes in a Card object.

Configuration

When configuring an I/O system on the local bus, often the Rack and Card-levels are sufficient. A configuration can look like this. A Rack object is placed below the \$Node object, and below this a Card object for each I/O card that i installed in the rack. The cardobjects contains channelobjects for the channels on the cards. The channelobjects are connected to signalobjects in the plant hierarchy. The Channels for analog signals contains attributes for measurement ranges, and the card objects contains attributes for addresses.

The configuration of a distributed I/O system is a bit different. Still the levels Agent, Rack, Card and Channel are used, but the levels has another meaning. If we take Profibus as an example, the agentlevel consist of an object for the master card that is mounted on the computer. The racklevel consist of slave objects, that represent the profibus slaves that are connected to the Profibus circuit. The cardlevel consist of module objects that represent modules handled by the slaves. The Channel objects represent data sent on the bus from the mastercard to the modules or vice versa.

I/O System

This chapter contains descriptions of the I/O systems that are implemented in Proview.

PSS9000

PSS9000 consist of a set of I/O cards for analog input, analog output, digital input and digital output. There are also cards for counters and PID controllers. The cards are placed in a rack with the bus QBUS, a bus originally designed for DEC's PDP-11 processor. The rack is connected via a PCI-QBUS converter to an x86 PC, or connected via Ethernet, so called Remoterack.

The system is configured with objects from the SsabOx volume. There are objects representing the Rack and Carde levels. The agent level i represented by the \$Node object.

Rack objekt

Rack_SSAB

The Rack_SSAB object represents a 19" PSS9000 rack with QBUS backplane. The number of card slots can vary.

The rack is connected to a x86 PC with a PCI-QBUS converter card, PCI-Q, that is installed into the PC and connected to the rack with a cable. Several racks can be connected via bus extension card.

The rackobjects are placed below the \$Node objects and named C1, C2 etc (in older systems the naming convention R1, R2 etc can be found).

Attributes

Rack_SSAB doesn't contain any attributes used by the system.

Driver

The PCI-QBUS converter, PCI-Q, requires installation of a driver.

Ssab_RemoteRack

The Ssab_RemoteRack object configures a PSS9000 rack connected via Ethernet. A BFBETH card is inserted into the rack and connected Ethernet.

The object is placed below the \$Node object and named E1, E2 etc.

Attributes

Attributes	Description	
Address	p-adress for the BTBETH card.	
LocalPort	Port in the process station.	
RemotePort	Port for the BTBETH card. Default value 8000.	
Process	Process that handles the rack. 1 the plcprogram, 2 io_comm.	

Attributes	Description	
ThreadObject	Thread object for the plc thread that should handle the rack. Only used if Process is 1.	
StallAction	No, ResetInputs or EmergencyBreak. Default EmergencyBreak.	

Di card

All digital inputcards have a common baseclass, Ssab_BaseDiCard, that contains attributes common for all di cards. The objects for each card type are extended with channel objects for the channels of the card.

Ssab_BaseDiCard

Attributes	Description	
RegAddress	QBUS address.	
ErrorHardLimit	Error limit that stops the system.	
ErrorSoftLimit	Error limit that sends an alarm message.	
Process	Process that handles the rack. 1 the plcprogram, 2 io_comm.	
ThreadObject	Thread object for the plc thread that should handle the rack. Only used if Process is 1.	
ConvMask1	The conversion mask states which channels will be converted to signal values. Handles channel $1-16$.	
ConvMask2	See ConvMask1. Handles channel 17 – 32.	
InvMask1	The invert mask states which channels are inverted. Handles channel 1-16.	
InvMask2	See InvMask1. Handles channel 17 – 32.	

Ssab_DI32D

The object configures a digital input and of type DI32D. The card has 32 channels, which channel objects reside as internal attributes in the object. The object is placed as a child to a Rack_SSAB or Ssab_RemoteRack object. Attributes, see BaseDiCard.

Do cards

All digital outputcards have a common baseclass, Ssab_BaseDoCard, that contains attributes that are common for all do cards. The objects for each card type are extended with channel objects for the channels of the card.

Ssab_BaseDoCard

Attributes	Description
RegAddress	QBUS address.
ErrorHardLimit	Error limit that stops the system.
ErrorSoftLimit	Error limit that sends an alarm message.

Attributes	Description	
Process	Process that handles the rack. 1 the plcprogram, 2 io_comm.	
ThreadObject	Thread object for the plc thread that should handle the rack. Only used if Process is 1.	
InvMask1	The invert mask states which channels are inverted. Handles channel 1-16.	
InvMask2	See InvMask1. Handles channel 17 – 32.	
FixedOutValue1	Bitmask for channel 1 to 16 when the I/O handling is emergency stopped. Should normally be zero.	
FixedOutValue2	See FixedOutValue1. FixedOutValue2 is a bitmask for channel 17 – 32.	
ConvMask1	The conversion mask states which channels will be converted to signal values. Handles channel $1-16$.	
ConvMask2	See ConvMask1. Handles channel 17 – 32.	

Ssab_DO32KTS

The object configures a digital outputcard of type DO32KTS. The card has 32 output channels, whose DoChan objects are internal attributes in the card object. The object is positioned as a child to a Rack_SSAB or Ssab_RemoteRack object. Attributes, see BaseDoCard.

Ssab_DO32KTS_Stall

The object configures a digital outputcard of type DO32KTS Stall. The card is similar to DO32KTS, but also contains a stall function, that resets the bus, i.e. all outputs are zeroed on all cards, if no write or read i done on the card in 1.5 seconds.

Ai cards

All analog cards have a common baseclass, Ssab_BaseACard, that contains attributes that are common for all analog cards. The objects for each card type are extended with channel objects for the channels of the card.

Ssab_BaseACard

Attribut	Beskrivning	
RegAddress	QBUS address.	
ErrorHardLimit	Error limit that stops the system.	
ErrorSoftLimit	Error limit that sends an alarm message.	
Process	Process that handles the rack. 1 the plcprogram, 2 io_comm.	
ThreadObject	Thread object for the plc thread that should handle the rack. Only used if Process is 1.	

Ssab_Al8uP

The object configures an analog inputcard of type Ai8uP. The card has 8 channels, whose AiChan objects are internal attributes in the card object. The object is positioned as a child to a Rack_SSAB or Ssab_RemoteRack object. Attributes, see BaseACard.

Ssab Al16uP

The object configures an analog inputcard of type Ai16uP. The card has 16 channels, whose AiChan objects is internal attributes in the card object. The object is positioned as a child to a Rack_SSAB or Ssab_RemoteRack object. Attributes, see BaseACard.

Ssab_Al32uP

The object configures an analog inputcard of type Ai32uP. The card has 32 channels, whose AiChan objects are internal attributes in the card object. The object is positioned as a child to a Rack_SSAB or Ssab_RemoteRack object. Attributes, see BaseACard.

Ssab_Al16uP_Logger

The object configures an analog inputcard of type Ai16uP_Logger. The card has 16 channels, whose AiChan objects are internal attributes in the card object. The object is positioned as a child to a Rack_SSAB or Ssab_RemoteRack object. Attributes, see BaseACard.

Ao cards

Ssab AO16uP

The object configures an analog input and of type AO16uP. The card has 16 channels, whose AoChan objects are internal attributes in the card object. The object is positioned as a child to a Rack_SSAB or Ssab_RemoteRack object. Attributes, see BaseACard.

Ssab_AO8uP

The object configures an analog input ard of type AO8uP. The card has 8 channels, whose AoChan objects are internal attributes in the card object. The object is positioned as a child to a Rack_SSAB or Ssab_RemoteRack object. Attributes, see BaseACard.

Ssab_AO8uPL

The object configures an analog inputcard of type AO8uP. The card has 8 channels, whose AoChan objects are internal attributes in the card object. The object is positioned as a child to a Rack_SSAB or Ssab_RemoteRack object. Attributes, see BaseACard.

Co kort

Ssab_CO4uP

The object configures a counter card of type CO4uP. The card has 4 channels, whose CoChan objects are internal attributes in the card object. The object is positioned as a child to a Rack_SSAB or Ssab_RemoteRack object. Attributes, see BaseACard.




Fig PSS9000 configuration example

Profibus

Profibus is a fieldbus with nodes of type master and slave. The usual configuration is a monomastersystem with one master and up to 125 slaves. Each slave can handle one or several modules.

In the Proview I/O handling the master represents the agent level, the slaves the rack level, and the module the card level.

Proview has support for the mastercard *Softing PROFIboard PCI* (see www.softing.com) that is installed in the PCI-bus of the process station. The card is configured by an object of class Profibus:Pb_Profiboard that is placed below the \$Node object.

Each slave connected to the profibus circuit is configured with an object of class Pb_DP_Slave, or a subclass to this class. The slave objects are placed as children to the master object. For the slave objects, a profibus configurator can be opened, that configures the slave object, and creates module object for the modules that is handled by the slave. The profibus configurator uses the gsd-file for the slave. The gsd-file is a textfile supplied by the vendor, that describes the various configurations available for the actual slave. Before opening the profibus configurator you has to specify the name of the gsd-file. Copy the file to \$pwrp_exe and insert the filename into the attribute GSDfile in the slave object.

If there is a subclass present for the slave your about to configure, e.g. Siemens_ET200S_IM151, the gsd-file is already stated in the slave object, and the gsd-file is included in the Proview distribution.

When this operation is preformed, the profibus configurator is opened by rightclicking on the object and activating 'Configure Slave' from the popup menu.

The profibus configuator

The profibus configurator is opened for a slave object, i.e. an object of class Pb_DP_Slave or a subclass of this class. There has to be a readable gsd-file stated in the GSDfile attribute in the slave object.



Address

The address of the slave is stated in the Address attribute. The address has a value in the intervall 0-125 that is usually configured with switches on the slave unit.

SlaveGsdData

The map *SlaveGsdData* contains informational data.

UserPrmData

The map *UserPrmData* contains the parameter that can be configured for the current slave.

Module

A slave can handle one or several modules. There are modulare slaves with one single module, where the slave and the module constitutes on unit. and there are slaves of rack type, into which a large number of modules can be inserted. The Profibus configurator displayes on map for each module that can be configured for the current slave.

Each slave is given an object name, e.g. M1 M2 etc. Modules on the same slave has to have different object names.

Also the module type is stated. This i chosen from a list of moduletypes supported by the current slave. The list is found below *Type*.




Fig Module Type and Class selected

When the type is chosen, the parameter of the selected moduletype is configured under *UserPrmData*.

You also have to state a class for the module object. At the configuration, a module object is created for each configured module. The object is of class Pb_Module or a subclass of that class. Under


Class all the subclasses to Pb_Module are listed. If you find a class corresponding to the current module type, you select this class, otherwise you select the baseclass Pb_Module. The difference between the subclasses and the baseclass is that in the subclasses, the dataarea is specified with channel objects (se section Specify the data area).

When all the modules are configured you save by clicking on 'Ok' and leave by clicking 'Cancel'. The module objects with specified objectnames and classes are now created below the slave object.

If you are lucky, you will find a module object the corresponds to the current module. The criteria for the correspondence is whether the specified data area matches the current module or not. If you don't find a suitable module class there are two options: to create at new class with Pb_Module as baselcass, extended with channel objects to specify the data area, or to configure the channel as separate objects below a Pb_Module object. The second alternative is more convenient if there are one or a few instances. If there are several modules you should consider creating a class for the module.

Specify the data area

The next step is to specify the dataarea for a module. Input modules read data that are sent to the process station over the bus, and output modules receives data from the process station. There are also modules with both input and output data, e.g. frequency converters. The data areas that are sent and received via the bus has to configured, and this is done with channel objects. The inarea is specified with ChanDi, ChanAi and ChanIi objects, the outarea with ChanDo, ChanAo and ChanIo objects. The channelobjects are placed as children to the module object, or, if you choose do make a specific class for the module, as internal attributes in the module object. In the channel object you should set *Representation*, that specifies the format of a parameter, and in som cases also *Number* (for Bit representation). In the slave object you might have to set the *ByteOrdering* (LittleEndian or BigEndian) and *FloatRepresentation* (Intel or IEEE).



Digital inputs

Digital input modules send the value of the inputs as bits in a word. Each input is specified with a

ChanDi object. Representation is set to Bit8, Bit16, Bit32 or Bit64 dependent on the size of the word, and in Number the bit number that contains the channel value is stated (first bit has number 0).

Analog inputs

An analog input is usually transferred as a integer value and specified with a ChanAi object. Representation matches the integer format in the transfer. In some cases the value is sent as a float, and the float format has to be stated in *FloatRepresentation* (FloatIntel or FloatIEEE) in the slave object. Ranges for conversion to engineering value are specified in *RawValRange*, *ChannelSigValRange*, *SensorSigValRange* and *ActValRange* (as the signalvalue is not used *ChannelSigValRange* and *SensorSigValRange* can have the same value as *RawValRange*).

Digital outputs

Digital outputs are specified with ChanDo objects. *Representation* should be set to Bit8, Bit16, Bit32 or Bit64 dependent on the transfer format.

Analog outputs

Analog outputs are specified with ChanAo objects. Set *Representation* and specify ranges for conversion from engineering unit to transfer value (set *ChannelSigValRange* and *SensorSigValRange* equal to *RawValRange*).

Complex dataareas

Many modules sends a mixture of integer, float, bitmasks etc. You then have to combine channel objects of different type. The channelobjects should be placed in the same order as the data they represent is organized in the data area. For modules with both in and out area, the channels of the inarea i are usually placed first and thereafter the channels of the outarea.

Driver

Softing PROFIboard requires a driver to be installed. Download the driver from www.softing.com.

Agent object

Pb_Profiboard

Agent object for a profibus master of type Softing PROFIboard. The object is placed in the nodehierarchy below the \$Node object.

Slave objects

Pb Dp Slave

Baseobject for a profibus slave. Reside below a profibus agent object. In the attribute *GSDfile* the gsd-file for the current slave is stated. When the gsd-file is supplied the slave can be configured by the Profibus configurator.

ABB_ACS_Pb_Slave

Slave object for a frequencyconverter ABB ACS800 with protocol PPO5.

Siemens_ET200S_IM151

Slaveobject for a Siemens ET200S IM151.

Siemens ET200M_IM153

Slave object for a Siemens ET200M IM153.

Module objects

Pb Module

Baseclass for a profibus module. The object is created by the Profibus configurator. Placed as child to a slave object.

ABB_ACS_PPO5

Moduleobject for a frequencyconverter ABB ACS800 with protocol PPO5.

Siemens_ET200S_Ai2

Moduleobject for a Siemens ET200S module with 2 analog inputs.

Siemens ET200S Ao2

Moduleobject for a Siemens ET200S module with 2 analog outputs.

Siemens_ET200M_Di4

Moduleobject for a Siemens ET200M module with 4 digital inputs.

Siemens ET200M Di2

Moduleobject for a Siemens ET200M module with 2 digital inputs.

Siemens_ET200M_Do4

Moduleobject for a Siemens ET200M module with 4 digital outputs.

Siemens_ET200M_Do2

Moduleobject for a Siemens ET200M module with 2 digital outputs.

MODBUS TCP

MODBUS is an application layer messaging protocol that provides client/server communication between devices. Proview implements the MODBUS messaging service over TCP/IP.

MODBUS is a request/reply protocol and offers services specified by function codes. For more information on the MODBUS protocol see the documents:


MODBUS Application Protocol Specification V1.1b

MODBUS Messaging on TCP/IP Implementation Guide V1.0b

Each device that is to be communicated with is configured with an object of class Modbus_TCP_Slave, or a subclass to this class. The interface to the device is defined by instances of the class Modbus_Module. Each instance of the Modbus_Module represents a function code for the service that is requested. The corresponding data area is defined with channels.

Configuration of a device

Insert a Modbus_TCP_Slave-object in the node-hierarchy. Specify the ip-address of the MODBUS device. By default the device will be handled by a plc-thread. Connect the slave to a plc-thread. An example is given below. ReconnectLimit specifies how many times the slave will try to reconnect to the device if connection is lost.



Modules

With help of Modbus_Module's you define what type of actions you want to perform on the slave and at which address. The action is defined by a function code which means either reading or writing data to the Modbus slave. You also specify the address at which to read or write. The number of data to be read or written is defined by how you define the data area (see below).

The supported function codes are:

ReadCoils (FC 1)

This function code is used to read from 1 to 2000 contiguous status of coils in a remote device. Typically the input data area is defined by a number of ChanDi's which represent the number of coils you want to read. The representation on the ChanDi should be set to Bit8.

ReadDiscreteInputs (FC 2)

This function code is used to read from 1 to 2000 contiguous status of discrete inputs in a remote device. Typically the input data area is defined by a number of ChanDi's which represent the number of coils you want to read. The representation on the ChanDi should be set to Bit8.

ReadHoldingRegisters (FC 3)

This function code is used to read the contents of a contiguous block of holding registers in a remote device. A register is 2 bytes long. Typically the input data area is defined by a number of ChanIi's which represent the number of registers you want to read. The representation on the ChanIi should be set to UInt16 or Int16. ChanAi and ChanDi is also applicable. In case of ChanDi the representation should be set to Bit16.

ReadInputRegisters (FC 4)

This function code is used to read from 1 to 125 contiguous input registers in a remote device. Typically the input data area is defined by a number of ChanIi's which represent the number of registers you want to read. The representation on the ChanIi should be set to UInt16 or Int16. ChanAi and ChanDi is also applicable. In case of ChanDi the representation should be set to Bit16.

WriteMultipleCoils (FC 15)

This function code is used to force each coil in a sequence of coils to either ON or OFF in a remote Device. Typically the output data area is defined by a number of ChanDo's which represent the number of coils you want to write. The representation on the ChanDo should be set to Bit8.

WriteMultipleRegisters (FC 16)

This function code is used to write a block of contiguous registers (1 to 123 registers) in a remote device. Typically the output data area is defined by a number of ChanIo's which represent the number of registers you want to write. The representation on the ChanIo should be set to UInt16 or Int16. ChanAo and ChanDo is also applicable. In case of ChanDo the representation should be set to Bit16.

Specify the data area

To specify the data area a number of channel objects are placed as children to the module object. In the channel object you should set *Representation*, that specifies the format of a parameter, and in some cases also *Number* (for Bit representation). The data area is configured in much the same way as the Profibus I/O except for that you never have to think about the byte ordering which is specified by the MODBUS standard to be Big Endian.

To clarify how the data area is specified an example is given below.

Example

In this example we have a device which is a modular station of type *Schneider*. That means a station to which a number of different I/O-modules could be connected. We will use the function codes for reading and writing holding registers (FC3 and FC16). Our station consist of

1 Di 6 module

1 Do 6 module

1 Ai 2 module

1 Ao 2 module

According to the specification of this modular station the digital input module uses 2 registers, one to report data and one to report status. The digital output module uses one register to echo output data and reports one register as status. The analog input module uses 2 registers, one for each channel. The analog output module uses two registers for output data and reports 2 registers as status for each channel. Thus the data area looks like:


Input area

1 register (2 bytes) digital input data, 6 lowest bits represent the inputs
1 register (2 bytes) digital input status
1 register (2 bytes) echo digital output
1 register, digital output status
1 register, analog input channel 1
1 register, analog input channel 2
1 register, echo analog output channel 1
1 register, echo analog output channel 2


Output area

1 register digital output data, 6 lowest bits represent the outputs	
1 register, analog output channel 1	
1 register, analog output channel 2	


The configuration is made with 2 Modbus modules. One will read holding registers starting at address 5391 and one will write registers starting at address 0.



The input area is configured with channels as shown below. It consists of 6 ChanDi with representation Bit16 and numbered 0-5 meaning that in the first register (2 bytes, 16 bits) we will read the 6 lowest bits to the channels. The same is done for the statuses of the digital input channels. The rest of the input registers is read with ChanIi's with representation UInt16.



The output area is configured as shown below. The digital outputs are configured with ChanDo's with representation Bit16 and numbered 0 to 5. The analog outputs are specified with 2 ChanIi's, one for the respective channel.



Slave objects

Modbus_TCP_Slave

Baseobject for a Modbus slave. Reside in the node hierarchy. TCP/IP-address of the device is configured.

Module objects

Modbus_Module

Baseclass for a Modbus module. Placed as child to a slave object. Wanted function code is chosen.

MotionControl USB I/O

Motion Control USB I/O is a device manufactured by Motion Control, www.motioncontrol.se. The device is connected to the USB port on the pc. The unit contains 21 channels of different types, divided into 3 ports, A, B and C. The first four channels (A1 - A4) are Digital outputs of relay type for voltage up to 230 V. The next four channels (A5 - A8) are Digital inputs with optocouplers. Next eight channels (B1 - B8) can either be configured as digital outputs, digital inputs or analog inputs. The last 5 channels (C1 - C5) can be digital outputs or inputs, where C4 and C5 also can be configured as analog outputs.

In Proview USB I/O is configured with a rackobject, OtherIO:MotionControl_USB, that is positioned in the nodehierarchy under the \$Node object, and a card object, OtherIO:MotionControl_USBIO. Below the card object, channelobjects of the type that corresponds to the configuration of the card, are placed.

The card has a watchdog the resets the outputs of the card, if the card is not written to within a certain time.

For the moment, the driver can only handle one device.

Driver

Download and unback the tar-file for the driver.

> tar -xvzf usbio.tar.tz

Build the driver with make

- > cd usbio/driver/linux-2.6
- > make

Install the driver usbio.ko as root

> insmod usbio.ko

Allow all to read and write to the driver

> chmod a+rw /dev/usbio0

There is also an API to the driver with an archive, usbio/test/libusbio.a. Copy the archive to /usr/lib or \$pwrp_lib on the development station.

Rack object

MotonControl_USB

The rack object is placed under the \$Node object in the node hierarchy. Process should be 1. Connect the object to a plc thread by selecting a PlcThread object and activate *Connect PlcThread* in the popup menu for the rack object.

Kortobjekt

MotionControl USBIO

The card object is positioned under the rack object. Process should also here be 1 and the object should be connected to a plc thread. State the card identity, that is found on the circuit card, in the Address attribute. The watchdog is activated if a value is set in WatchdogTime, that states the timeout time in seconds.

Channels

The channels of the card are configured under the card object with channels objects. The Number attribute of the channel object states which channel the object configures (0-20), and the class of the object states if the channel is used as a Di, Do, Ai or Ao. The table below displays how the channels can be configured.

Channel	Type	Number
A1	ChanDo	0
A2	ChanDo	1
A3	ChanDo	2
A4	ChanDo	3
A5	ChanDi	4
A6	ChanDi	5
A7	ChanDi	6
A8	ChanDi	7
B1	ChanDi, ChanDo or ChanAi	8
B2	ChanDi, ChanDo or ChanAi	9
В3	ChanDi, ChanDo or ChanAi	10
B4	ChanDi, ChanDo or ChanAi	11
B5	ChanDi, ChanDo or ChanAi	12
B6	ChanDi, ChanDo or ChanAi	13
В7	ChanDi, ChanDo or ChanAi	14
B8	ChanDi, ChanDo or ChanAi	15
C1	ChanDi or ChanDo	16
C2	ChanDi or ChanDo	17
C3	ChanDi or ChanDo	18
C4	ChanDi, ChanDo or ChanAo	19
C5	ChanDi, ChanDo or ChanAo	20

Ai configuration

The Ai channels has rawvalue range 0-1023 and signalvalue range 0-5 V, i.e. RawValRange and ChannelSigValRange should be set to

RawValRangeLow	0
RawValRangeHigh	1023
ChannelSigValRangeLow	0
ChannelSigValRangeHigh	5

For example, to configure ActualValue range to 0-100, set SensorSigValRange 0-5 and ActValRange 0-100.

Ao configuration

The Ao channels has rawvalue range 0-5 and signalvalue range 0-5, i.e. RawValRange and ChannelSigValRange should be set to

RawValRangeLow	0
RawValRangeHigh	5
ChannelSigValRangeLow	0
ChannelSigValRangeHigh	5

For example, to configure ActualValue range to 0-100, set SensorSigValRange 0-5 and ActValRange 0-100.

Link file

The archive with the driver API has to be linked to the plcprogram. This is done by creating the file \$pwrp_exe/plc_'nodename'_'busnumber'.opt, e.g. \$pwrp_exe/plc_mynode_0517.opt with the content

```
$pwr_obj/rt_io_user.o -lusbio
```

Adaption of I/O systems

This section will describe how to add new I/O systems to Proview.

Adding a new I/O system requires knowledge of how to create classes in Proview, and baseknowledge of c programming.

An I/O system can be added for a single project, for a number of projects, or for the Proview base system. In the latter case you have to install and build from the Proview source code.

Overview

The I/O handling in Proview consist of a framework that identifies the I/O objects on a process node, and calls the methods of the I/O objects to fetch or transmit data.

Levels

The I/O objects in a process node are configured in four levels: agent, rack, cards and channels. The channelobjects can be configured as individual objects or as internal objects in a card object.

To the agent, rack and card objects methods can be registered. The methods can be of type Init, Close, Read, Write or Swap, and is called by the I/O framework in a specific order. The functionality of an I/O object consists of the attributes of the object, and the registered methods of the object. Everything the framework does is to identify the objects, select the objects that are valid for the current process, and call the methods for these objects in a specific order.

Look at a centralized I/O system with digital inputcards and digital outputcards mounted on the local bus of the process node. In this case the agent level is superfluous and represented by the \$Node object. Below the \$Node object is placed a rack object with an open and a close method. The open method attaches to the driver of the I/O system. Below the rack object, cardobjects for the Di and Do cards are configured. The Di card has an Open and a Close method that initiates and closes down the card, and a Read method the fetches the values of the inputs of the card. The Do card also has Open and Close methods, and a Write method that transfers suitable values to the outputs of the card.

If we study another I/O system, Profibus, the levels are not as easy to identify as in the previous example. Profibus is a distributes system, with a mastercard mounted on the local PCI-bus, that communicates via a serial connection to slaves positioned in the plant. Each slave can contain modules of different type, e.g. one module with 4 Di channels, and one with 2 Ao channels. In this case the mastercard represents the agentlevel, the slaves the racklevel and the modules the cardlevel.

The Agent, rack and card levels are very flexible, and mainly defined by the attributes and the methods of the classes of the I/O system. This does not apply to the channel level that consists of the object ChanDi, ChanDo, ChanAi, ChanAo, ChanIi, ChanIo and ChanCo. The task for the channel object is to represent an input or output value on an I/O unit, and transfer this value to the signal object that is connected to the channel object. The signalobject reside in the plant hierarchy and represents for example a sensor or an order to an actuator in the plant. As there is a physical

connection between the sensor in the plant and the channel on the I/O card, also the signalobjects are connected to the channel object. Plcprograms, HMI and applications refer to the signalobject that represents the component in the plant, not the channelobject, representing a channel on an I/O unit

Area objekt

Values that are fetched from input units and values that are put out to output units are stored in special area objects. The area objects are created dynamically in runtime and reside in the systemvolume under the heirarchy pwrNode-active-io. There are one area object for each signal type. Normally you refer to the value of a signal through the ActualValue attribute of the signal. This attribute actually contains a pointer that points to the area object, and the attribute ValueIndex states in which index in the areaobject the signal value can be found. The reason to this construction with area objects is that during the execution of a logical net, you don't want any changes of signal values. Each plc-tread therefor takes a copy of the area objects before the start of the execution, and reads signalvalues from the copy, calculated output signalvalues though, are written in the area object.

I/O objects

The configuration of the I/O is done in the node hierarchy below the \$Node object. To each type of component in the I/O hierchy you create a class that contains attributes and methods. The methods are of type Open, Close, Read, Write and Swap, and is called by the I/O framework. The methods connects to the bus and read data that are transferred to the area objects, or fetches data from the area objects that are put out on the bus.

Processes

There are two system processes in Proview that calls the I/O framework, the plc process and rt_io_comm. In the plc process each thread makes an initialization of the I/O framework, which makes it possible to read and write I/O units synchronized with the execution of the plc code for the threads.

Framework

The main task for the I/O framework is to identify I/O objects and call the methods that are registred for the objects.

A first initialization is made at start of the runtime environment, when the areaobjects are created, and each signal is allocated a place in the area object. The connections between signals and channels are also checked. When signals and channels are connected in the development environment, the identity for the channel is stored in the signals SigChanCon attribute. Now the identity of the signal object is put into the channels SigChanCon attribute, thus making it easy to find the signal from the channel.

The next initialization is made by every process that wants to connect to the I/O handling. The plc process and rt_io_comm does this initialization, but also applications that need to read or write directly to I/O units can connect. At the initialization a datastructure i allocated with all agents, racks, cards and channels that is to be handled by the current process, and the init methods for them are called. The process then makes a cyclic call of a read and write function, that calls the read and write methods for the I/O objects in the data structure.

Methods

The task of the methods are to initiate the I/O system, perform reading and writing to the I/O units, and finally disconnect the I/O system. How these tasks are divided, depend on the construction of the I/O system. In a centralized I/O on the local bus, methods for the different card objects can attach the bus and read and write data themselves to their unit, and the methods for the agent and rack object doesn't have much to do. In a distributed I/O the information for the units are often gathered in a package, and it is the methods of the agent or rack object that receives the package and distribute its content on different card objects. The card object methods identifies data for its channels, performs any conversion and writes or reads data in the area object.

Framework

A process can initiate the I/O framework by calling io_ini(). As argument you send a bitmask that indicates which process you are, and the threads of the plc process also states the current thread. io_init() preforms the following

- creates a context.
- allocates a hierarchic data structure of I/O objects with the levels agent, rack, card and channel. For agents a struct of type io_sAgent is allocated, for racks a struct of type io_sRack, for cards a struct of type io_sCard, and finally for channels a struct of type io sChannel.
- searches for all I/O objects and checks their Process attributes. If the Process attribute matches the process sent as an argument to io_init(), the object is inserted into the data structure. If the object has a descendant that matches the process it is also inserted into the data structure. For the plc process, also the thread argument of io_init() is checked against the ThreadObject attribute in the I/O object. The result is a linked tree structure with the agents, racks, card and channel objects that is to be handled by the current process.
- for every I/O objects that is inserted, the methods are identified, and pointers to the methodsfunctions are fetched. Also pointers to the object and the objects name, is inserted in the data structure.
- the init methods for the I/O objects in the data structure is called. The methods of the first agent is called first, and then the first rack of the agent, the first card of the rack etc.

When the initialization is done, the process can call io_read() to read from the I/O units that are present i the data structure, and io_write() to put out values. A thread in the plc process calls io_read() every scan to fetch new values from the process. Then the plc-code is executed and io_write() is called to put out new values. The read methods are called in the same order as the init methods, and the write methods in reverse order.

When the process terminates, io_close() is called, which calls the close methods of the objects in the data structure. The close methods are called in reverse order compared to the init methods.

When a soft restart is performed, a restart of the I/O handling is also performed. First the close methods are called, and then, during the time the restart lasts, the swap methods are called, and then the init-methods. The call to the swap methods are done by rt_io_comm.

io_init, function to initiate the framework

```
pwr_tStatus io_init(
  io mProcess process,
```

```
pwr_tObjid thread,
  io_tCtx *ctx,
  int relativ_vector,
  float scan_time
);
```

io_sCtx, the context of the framework

```
struct io sCtx {
   io sAgent
                   *agentlist;
                                   /* List of agent structures */
   io mProcess
                   Process;
                                   /* Callers process number */
                   Thread;
                                  /* Callers thread objid */
  pwr tObjid
                   RelativVector; /* Used by plc */
  int
                                   /* Pointer to node object */
                   *Node;
  pwr sNode
                          *IOHandler; /* Pointer to IO Handler object */
  pwr sClass IOHandler
                   ScanTime; /* Scantime supplied by caller */
                                   /* Context for supervise object lists */
   io tSupCtx
                   SupCtx;
};
```

Data structure for an agent

```
typedef struct s Agent {
                                   /* Class of agent object */
  pwr tClassId
                   Class;
  pwr tObjid
                                   /* Objid of agent object */
                   Objid;
                                   /* Full name of agent object */
  pwr tOName
                   Name;
  io mAction
                   Action;
                                   /* Type of method defined (Read/Write)*/
                                   /* Process number */
   io mProcess
                   Process;
                   (* Init) ();
                                  /* Init method */
  pwr tStatus
                   (* Close) ();
                                  /* Close method */
  pwr tStatus
                                  /* Read method */
                   (* Read) ();
  pwr tStatus
  pwr_tStatus
                   (* Write) ();
                                   /* Write method */
                                   /* Write method */
  pwr tStatus
                   (* Swap) ();
                                   /* Pointer to agent object */
  void
                   *op;
  pwr tDlid
                                   /* Dlid for agent object pointer */
                   Dlid;
   int
                   scan interval; /* Interval between scans */
                   scan interval cnt;/* Counter to detect next time to scan */
   int
  io sRack
                   *racklist;
                                 /* List of rack structures */
  void
                                   /* Pointer to method defined data structure*/
                   *Local;
                   *next;
                                   /* Next agent */
   struct s Agent
} io sAgent;
```

Datastructure for a rack

```
typedef struct s Rack {
  pwr_tClassId
                                   /* Class of rack object */
                   Class;
                                   /* Objid of rack object */
  pwr_t0bjid
                   Objid;
  pwr_toName
                   Name;
                                   /* Full name of rack object */
                   Action;
                                   /* Type of method defined (Read/Write)*/
  io mAction
                                   /* Process number */
   io mProcess
                   Process;
                                   /* Init method */
  pwr_tStatus
                   (* Init) ();
  pwr tStatus
                   (* Close) ();
                                   /* Close method */
  pwr tStatus
                   (* Read) ();
                                   /* Read method */
  pwr tStatus
                   (* Write) ();
                                   /* Write method */
  pwr tStatus
                   (* Swap) ();
                                   /* Swap method */
  void
                   *op;
                                   /* Pointer to rack object */
  pwr tDlid
                                   /* Dlid för rack object pointer */
                   Dlid;
  pwr tUInt32
                                   /* Size of rack data area in byte */
                   size;
  pwr tUInt32
                                   /* Offset to rack data area in agent */
                   offset;
                                  /* Interval between scans */
  int
                   scan interval;
   int
                   scan interval cnt;/* Counter to detect next time to scan */
```

Data structure for a card

```
typedef struct s_Card {
  pwr_tClassId
                                 /* Class of card object */
                  Class;
  pwr_tObjid
                  Objid;
                                 /* Objid of card object */
  pwr_tOName
                  Name;
                                 /* Full name of card object */
                                /* Type of method defined (Read/Write)*/
  io mAction
                  Action;
                                /* Process number */
  io mProcess
                 Process;
                (* Init) (); /* Init method */
  pwr tStatus
                (* Close) (); /* Close method */
  pwr tStatus
                 (* Read) ();
  pwr tStatus
                                /* Read method */
  pwr tStatus
                 (* Write) (); /* Write method */
                               /* Write method */
  pwr tStatus
                  (* Swap) ();
                               /* Pointer to card object */
  pwr tAddress
                  *op;
  pwr tDlid
                                 /* Dlid for card object pointer */
                  Dlid;
  pwr tUInt32
                                 /* Size of card data area in byte */
                  size;
  pwr_tUInt32
                                 /* Offset to card data area in rack */
                  offset;
                  scan interval; /* Interval between scans */
   int
  int
                  scan interval cnt;/* Counter to detect next time to scan */
  int
                  AgentControlled; /* TRUE if kontrolled by agent */
                  ChanListSize; /* Size of chanlist */
  int
  io_sChannel
                  *chanlist; /* Array of channel structures */
                                /* Pointer to method defined data structure*/
                  *Local;
  void
                                 /* Next card */
  struct s Card
                  *next;
} io sCard;
```

Data structure for a channel

```
typedef struct {
  void
                *cop;
                             /* Pointer to channel object */
               ChanDlid;
                           /* Dlid for pointer to channel */
  pwr_tDlid
  pwr_sAttrRef
               ChanAref;
                           /* AttrRef for channel */
                            /* Pointer to signal object */
  void
               *sop;
               SigDlid;
                           /* Dlid for pointer to signal */
  pwr_tDlid
  pwr_sAttrRef SigAref;
                           /* AttrRef for signal */
  void
               *vbp;
                            /* Pointer to valuebase for signal */
  pwr tClassId SigClass;
                            /* Class of signal object */
                            /* Size of channel in byte */
  pwr tUInt32
              size;
  pwr tUInt32
                            /* Offset to channel in card */
               offset;
  pwr tUInt32
                            /* Mask for bit oriented channels */
               mask;
} io sChannel;
```

Create I/O objects

For a process node the I/O system is configured in the node hierarchy with objects of type agent, rack and card. The classes for these objects are created in the class editor. The classes are defined with a \$ClassDef object, a \$ObjBodyDef object (RtBody), and below this one \$Attribute object for each attribute of the class. The attributes are determined by the functionality of the methods of the class, but there are som common attributes (*Process, ThreadObject* and *Description*). In the \$ClassDef objects, the *Flag* word should be stated if it is an agent, rack or card object, and the methods are defined with specific Method objects.

It is quite common that several classes in an I/O system share attributes and maybe even methods. An input card that is available with different number of inputs, can often use the same methods. What differs is the number of channel objects. The other attributes can be stored in a baseclass, that also contains the methods-objects. The subclasses inherits both the attributes and the methods. The y are extended with channel objects, that can be put as individual attributes, or, if they are of the same type, as a vector of channelobjecs. If the channels are put as a vector or as individual attributes, depend on the how the reference in the plc documents should look. With an array you get an index starting from zero, with individual objecs you can control the naming of the attributes yourself.

In the example below a baseclass is viewed in Fig *Example of a baseclass* and a subclass in Fig *Example of a cardclass with a superclass and 32 channel objects*. The baseclass Ssab_BaseDiCard contains all the attributes used by the I/O methods and the I/O framework. The subclass Ssab_DI32D contains the Super attribute with TypeRef Sasb_BaseDiCard, and 32 channelattributes of type ChanDi. As the index for this cardtype by tradition starts from 1, the channels are put as individual attributes, but they could also be an array of type ChanDi.




Fig Example of a baseclass for a card




Fig Example of a cardclass with a superclass an 32 channel objecs

Flags

In the *Flag* attribute of the \$ClassDef object, the *IOAgent* bit should be se for agent classes, the *IORack* bit for rack classes and the *IOCard* bit for card classes.

= Editor 0	
- Method 1	
□ DevOnly	
= System	
─ Multinod	
─ ObjXRef	
— RtBody ■	
─ AttrXRef	
□ ObjRef	
─ AttrRef	
─ TopObject	
─ NoAdopt	
─ Template	
= 10	
─ IOAgent	
─ IORack	
= IOCard	
─ Has Call Back	

Fig IORack bit set for a rack class

Attributes

Description

Attribute of type pwrs:Type-\$String80. The content is displayed as description in the navigator.

Process

Attribute of type pwrs:Type-\$Uint32. States which process should handle the unit.

ThreadObject

Attribute of type pwrs:Type-\$Objid. States which thread in the plcprocess should handle the uing.

☐ Ssab_BaseDoCar	d \$ClassDef
	\$ObjBodyDef
Description	\$Attribute
Process	\$Attribute
ThreadObject	\$Attribute

Fig Standard attributes

Method objects

The method objects are used to identify the methods of the class. The methods consist of c-functions that are registered in the c-code with a name, a string that consists of classname and methodname, e.g. "Ssab_AIuP-IoCardInit". The name is also stored in a method object in the class description, and makes is possible for the I/O framework to find the correct c-function for the class.

Below the \$ClassDef object, a \$RtMethod object is placed with the name IoMethods. Below this one \$Method object is placed for each method that is to be defined for the class. In the attribute MethodName the name of the method is stated.

Agents

For agents, \$Method objects with the name IoAgentInit, IoAgentClose, IoAgentRead and IoAgentWrite are created.

Racks

For racks, \$Method objects with the names IoRackInit, IoRackClose, IoRackRead och IoRackWrite are created.

Cards

For cards \$Method objects with the names IoCardInit, IoCardClose, IoCardRead och IoCardWrite are created.




Fig Method objects

Connect-method for a ThreadObject

When the thread object in attribute *ThreadObject* should be stated for an I/O object, it can be typed manually, but one can also specify a menu method that inserts the selected threadobject into the attribute. The method is activated from the popup menu of the I/O object in the configurator.

The method is defined in the class description with a \$Menu and a \$MenuButton object, se Fig Connect Metod. Below the \$ClassDef object a \$Menu object with the name ConfiguratorPoson is placed. Below this, another \$Menu object named Pointed, and below this a \$MenuButton object named Connect. State ButtonName (text in the popup menu for the method), MethodName and FilterName. The method and the filter used is defined in the \$Objid class. MethodName should be \$Objid-Connect and FilterName \$Objid-IsOkConnected.




Fig Connect metod

Methods

For the agent, rack and card classes you write methods in the programming language c. A method is a c function that is common for a class (or several classes) and that is called by the I/O framework for all instances of the class. To keep the I/O handling as flexible as possible, the methods are doing most of the I/O handling work. The task for the framework is to identify the various I/O objects and to call the methods for these, and to supply the methods with proper data structures.

There are five types of methods: Init, Close, Read, Write and Swap.

- Init-method is called at initialization of the I/O handling, i.e. at startup of the runtime environment and at soft restart.
- Close-method is called when the I/O handling is terminated, i.e. when the runtime environment is stopped or at a soft restart.
- Read-method is called cyclic when its time to read the input cards.
- Write-method is called cyclic when its time to put out values to the output cards.
- Swap-method is called during a soft restart.

Local data structure

In the datastructures io_sAgent, io_sRack and io_sCard there is an element, *Local*, where the method can store a pointer to local data for an I/O unit. Local data is allocated by the init-method and then available at each method call.

Agent-Methods

loAgentInit

Initialization method for an agent.

IoAgentClose

Close method för en agent.

static pwr_tStatus IoAgentClose(io_tCtx io_sAgent	ctx, *ap)		
IoAgentRead			
Read method for an agent.			
static pwr_tStatus IoAgentRead(io_tCtx io_sAgent	ctx, *ap)		
IoAgentWrite			
Write method for an agent.			
<pre>static pwr_tStatus IoAgentWrite(io_tCtx</pre>	ctx, *ap)		
IoAgentSwap			
Swap method for an agent.			
static pwr_tStatus IoAgentSwap(io_tCtx io_sAgent	ctx, *ap)		
Rack-metoder			
IoRackInit			
static pwr_tStatus IoRackInit(io_tCtx io_sAgent io_sRack	ctx, *ap, *rp)		
IoRackClose			
static pwr_tStatus IoRackClose(io_tCtx io_sAgent io_sRack	ctx, *ap, *rp)		
IoRackRead			
static pwr_tStatus IoRackRead(io_tCtx io_sAgent io_sRack	ctx, *ap, *rp)		
IoRackWrite			
static pwr_tStatus IoRackWrite(io_tCtx io_sAgent io_sRack	ctx, *ap, *rp)		
IoRackSwap			
<pre>static pwr_tStatus IoRackSwap(io_tCtx</pre>	ctx, *ap, *rp)		
Card-metoder			
loCardInit			
static pwr_tStatus IoCardInit(io_tCtx io_sAgent	ctx, *ap,		

```
io sRack
                                              *rp,
                                io sCard
                                              *cp)
IoCardClose
static pwr tStatus IoCardClose( io tCtx
                                               ctx,
                                 io sAgent
                                               *ap,
                                 io sRack
                                               *rp,
                                 io sCard
                                               *cp)
IoCardRead
static pwr tStatus IoCardRead( io tCtx
                                              ctx,
                                io sAgent
                                              *ap,
                                io sRack
                                              *rp,
                               io_sCard
                                              *cp)
loCardWrite
static pwr tStatus IoCardWrite( io tCtx
                                               ctx.
                                 io sAgent
                                               *ap,
                                 io sRack
                                               *rp,
                                 io sCard
                                               *cp)
IoCardSwap
static pwr tStatus IoCardSwap( io tCtx
                                              ctx,
                               io sAgent
                                              *ap,
                               io sRack
                                              *rp,
                                io_sCard
                                              *cp)
```

Method registration

The methods for a class have to be registered, so that you from the method object in the class description can find the correct functions for a class. Below is an example of how the methods IoCardInit, IoCardClose and IoCardRead are registered for the class Ssab_AiuP.

```
pwr_dExport pwr_BindIoMethods(Ssab_AiuP) = {
   pwr_BindIoMethod(IoCardInit),
   pwr_BindIoMethod(IoCardClose),
   pwr_BindIoMethod(IoCardRead),
   pwr_NullMethod
};
```

Class registration

Also the class has to be registered. This is done in different ways dependent on whether the I/O system is implemented as a module in the Proview base system, or as a part of a project.

Module in Proview base system

If the I/O system are implemented as a module in the Proview base system, you create a file <code>lib/rt/src/rt_io_'modulename'.meth</code>, and list all the classes that have registered methods in this file.

Project

If the I/O system is a part of a project, the registration is made in a c module that is linked with the plc program. In the example below, the classes Ssab_Rack and Ssab_AiuP are registered in the file ra_plc_user.c

```
#include "pwr.h"
#include "rt_io_base.h"

pwr_dImport pwr_BindIoUserMethods(Ssab_Rack);
pwr_dImport pwr_BindIoUserMethods(Ssab_Aiup);

pwr_BindIoUserClasses(User) = {
   pwr_BindIoUserClass(Ssab_Rack),
   pwr_BindIoUserClass(Ssab_Aiup),
   pwr_NullClass
};
```

The file is compiled and linked with the plc-program by creating a link file on \$pwrp_exe. The file should be named plc_'nodename'_'busnumber'.opt, e.g. plc_mynode_0517.opt. The content of the file is sent as input data to the linker, ld, and you must also add the module with the methods of the class. In the example below these modules are supposed to be found in the archive \$pwrp lib/libpwrp.a.

```
$pwr_obj/rt_io_user.o -lpwrp
```

Example of rack methods

```
#include <stdio.h>
#include <errno.h>
#include <unistd.h>
#include <fcntl.h>
#include "pwr.h"
#include "pwr baseclasses.h"
#include "pwr_ssaboxclasses.h"
#include "rt_io_base.h"
#include "rt_errh.h"
#include "rt_io_rack_init.h"
#include "rt_io_m_ssab_locals.h"
#include "rt_io_msg.h"
/* Init method */
static pwr tStatus IoRackInit( io_tCtx ctx,
                               io sAgent *ap,
                               io sRack *rp)
                *local;
 io sRackLocal
  /* Open Qbus driver */
  local = calloc( 1, sizeof(*local));
 rp->Local = local;
 local->Qbus_fp = open("/dev/qbus", O_RDWR);
 if ( local \rightarrow Qbus fp == -1) {
   errh_Error( "Qbus initialization error, IO rack %s", rp->Name);
   ctx->Node->EmergBreakTrue = 1;
   return IO ERRDEVICE;
 errh Info( "Init of IO rack %s", rp->Name);
 return 1;
}
/* Close method */
static pwr tStatus IoRackClose( io tCtx ctx,
                                io sAgent *ap,
```

```
io_sRack *rp)
{
  io_sRackLocal *local;

  /* Close Qbus driver */
  local = rp->Local;

  close( local->Qbus_fp);
  free( (char *)local);

  return 1;
}

/* Every method to be exported to the workbench should be registred here. */

pwr_dExport pwr_BindIoMethods(Rack_SSAB) = {
   pwr_BindIoMethod(IoRackInit),
   pwr_BindIoMethod(IoRackClose),
   pwr_NullMethod
};
```

Example of the methods of a digital input card

```
#include <stdio.h>
#include <errno.h>
#include <unistd.h>
#include <fcntl.h>
#include <string.h>
#include <stdlib.h>
#include "pwr.h"
#include "rt errh.h"
#include "pwr_baseclasses.h"
#include "pwr_ssaboxclasses.h"
#include "rt_io_base.h"
#include "rt io msg.h"
#include "rt io filter di.h"
#include "rt_io_ssab.h"
#include "rt_io_card_init.h"
#include "rt_io_card_close.h"
#include "rt_io_card_read.h"
#include "qbus io.h"
#include "rt_io_m_ssab_locals.h"
/* Local data */
typedef struct {
     unsigned int
                       Address[2];
     int
                 Qbus_fp;
     struct {
       pwr_sClass_Di *sop[16];
       void *Data[16];
       pwr_tBoolean Found;
      } Filter[2];
     pwr tTime
                    ErrTime;
} io_sLocal;
/* Init method */
static pwr_tStatus IoCardInit( io_tCtx
                                          ctx,
                               io sAgent *ap,
                               io sRack *rp,
                               io sCard
                                          *cp)
```

```
{
 pwr sClass Ssab BaseDiCard *op;
  io sLocal
                              *local;
  int
                        i, j;
 op = (pwr sClass Ssab BaseDiCard *) cp->op;
  local = calloc(1, sizeof(*local));
 cp->Local = local;
 errh_Info( "Init of di card '%s'", cp->Name);
  local->Address[0] = op->RegAddress;
  local->Address[1] = op->RegAddress + 2;
  local->Qbus_fp = ((io_sRackLocal *)(rp->Local))->Qbus_fp;
  /* Init filter */
  for ( i = 0; i < 2; i++) {
    /* The filter handles one 16-bit word */
    for (j = 0; j < 16; j++)
      local->Filter[i].sop[j] = cp->chanlist[i*16+j].sop;
    io InitDiFilter( local->Filter[i].sop, &local->Filter[i].Found,
           local->Filter[i].Data, ctx->ScanTime);
  }
 return 1;
/* Close method */
static pwr tStatus IoCardClose( io_tCtx ctx,
                                io_sAgent *ap,
                                io_sRack *rp,
                                io sCard *cp)
  io sLocal
                        *local;
  int
                 i;
  local = (io_sLocal *) cp->Local;
 errh Info( "IO closing di card '%s'", cp->Name);
  /* Free filter data */
  for (i = 0; i < 2; i++) {
   if ( local->Filter[i].Found)
      io CloseDiFilter( local->Filter[i].Data);
  free( (char *) local);
 return 1;
}
/* Read method */
static pwr_tStatus IoCardRead( io_tCtx
                               io sAgent *ap,
                               io_sRack *rp,
                               io sCard
                                        *cp)
  io sLocal
                        *local;
 io sRackLocal
                        *r_local = (io_sRackLocal *)(rp->Local);
 pwr_tUInt16
                       data = 0;
 pwr_sClass_Ssab_BaseDiCard *op;
 pwr_tUInt16
                    invmask;
 pwr_tUInt16
                       convmask;
```

```
int
                  i;
  int
                  sts;
  qbus io read
                        rb;
  pwr tTime
                        now;
  local = (io sLocal *) cp->Local;
  op = (pwr_sClass_Ssab_BaseDiCard *) cp->op;
  for ( i = 0; i < 2; i++) {
    if ( i == 0) {
      convmask = op->ConvMask1;
      invmask = op->InvMask1;
    else {
      convmask = op->ConvMask2;
      invmask = op->InvMask2;
      if ( !convmask)
       break;
      if ( op->MaxNoOfChannels == 16)
        break;
    }
    /* Read from local Q-bus */
    rb.Address = local->Address[i];
    sts = read( local->Qbus_fp, &rb, sizeof(rb));
    data = (unsigned short) rb.Data;
    if ( sts == -1) {
      /* Increase error count and check error limits */
      clock_gettime(CLOCK_REALTIME, &now);
      if (op->ErrorCount > op->ErrorSoftLimit) {
        /* Ignore if some time has expired */
        if (now.tv_sec - local->ErrTime.tv_sec < 600)</pre>
          op->ErrorCount++;
      }
      else
        op->ErrorCount++;
      local->ErrTime = now;
      if ( op->ErrorCount == op->ErrorSoftLimit)
       errh Error( "IO Error soft limit reached on card '%s'", cp->Name);
      if ( op->ErrorCount >= op->ErrorHardLimit)
        errh_Error( "IO Error hard limit reached on card '%s', IO stopped", cp-
>Name);
        ctx->Node->EmergBreakTrue = 1;
        return IO ERRDEVICE;
      continue;
    /* Invert */
    data = data ^ invmask;
    /* Filter */
    if ( local->Filter[i].Found)
      io DiFilter( local->Filter[i].sop, &data, local->Filter[i].Data);
    /* Move data to valuebase */
    io_DiUnpackWord( cp, data, convmask, i);
  }
```

```
return 1;
}

/* Every method to be exported to the workbench should be registred here. */
pwr_dExport pwr_BindIoMethods(Ssab_Di) = {
   pwr_BindIoMethod(IoCardInit),
   pwr_BindIoMethod(IoCardClose),
   pwr_BindIoMethod(IoCardRead),
   pwr_NullMethod
};
```

Example of the methods of a digital output card

```
#include <stdio.h>
#include <errno.h>
#include <unistd.h>
#include <fcntl.h>
#include <string.h>
#include <stdlib.h>
#include "pwr.h"
#include "rt errh.h"
#include "pwr baseclasses.h"
#include "pwr ssaboxclasses.h"
#include "rt io base.h"
#include "rt io msg.h"
#include "rt io filter po.h"
#include "rt_io_ssab.h"
#include "rt_io_card_init.h"
#include "rt_io_card_close.h"
#include "rt io card write.h"
#include "qbus_io.h"
#include "rt io m ssab locals.h"
/* Local data */
typedef struct {
     unsigned int
                      Address[2];
                Qbus_fp;
     struct {
       pwr sClass Po *sop[16];
                *Data[16];
       pwr tBoolean Found;
     } Filter[2];
     pwr tTime
                      ErrTime;
} io_sLocal;
/* Init method */
static pwr tStatus IoCardInit( io_tCtx
                                         ctx,
                               io sAgent *ap,
                               io sRack *rp,
                               io sCard *cp)
 pwr sClass Ssab BaseDoCard *op;
  io sLocal *local;
  int
                i, j;
 op = (pwr_sClass_Ssab_BaseDoCard *) cp->op;
  local = calloc( 1, sizeof(*local));
 cp->Local = local;
 errh Info( "Init of do card '%s'", cp->Name);
```

```
local->Address[0] = op->RegAddress;
  local->Address[1] = op->RegAddress + 2;
  local->Qbus fp = ((io sRackLocal *)(rp->Local))->Qbus fp;
  /* Init filter for Po signals */
  for (i = 0; i < 2; i++) {
    /* The filter handles one 16-bit word */
   for (j = 0; j < 16; j++) {
      if ( cp->chanlist[i*16+j].SigClass == pwr_cClass_Po)
       local->Filter[i].sop[j] = cp->chanlist[i*16+j].sop;
    io InitPoFilter( local->Filter[i].sop, &local->Filter[i].Found,
            local->Filter[i].Data, ctx->ScanTime);
  }
 return 1;
}
/* Close method */
static pwr tStatus IoCardClose( io tCtx ctx,
                                io sAgent *ap,
                                io_sRack *rp,
                                io_sCard *cp)
  io sLocal
                        *local;
  int
                  i;
  local = (io_sLocal *) cp->Local;
 errh Info( "IO closing do card '%s'", cp->Name);
  /* Free filter data */
  for (i = 0; i < 2; i++) {
    if ( local->Filter[i].Found)
      io ClosePoFilter( local->Filter[i].Data);
  free( (char *) local);
 return 1;
/* Write method */
static pwr_tStatus IoCardWrite( io_tCtx ctx,
                                io_sAgent *ap,
                                io_sRack *rp,
                                io_sCard *cp)
  io sLocal
                        *local;
  io sRackLocal
                        *r local = (io sRackLocal *)(rp->Local);
 pwr tUInt16
                        data = 0;
 pwr sClass Ssab BaseDoCard *op;
 pwr tUInt16
                       invmask;
 pwr_tUInt16
                       testmask;
 pwr tUInt16
                        testvalue;
 int
 qbus_io_write
                  sts;
 int
 pwr_tTime
                        now;
 local = (io_sLocal *) cp->Local;
 op = (pwr sClass Ssab BaseDoCard *) cp->op;
```

```
for (i = 0; i < 2; i++) {
 if ( ctx->Node->EmergBreakTrue && ctx->Node->EmergBreakSelect == FIXOUT) {
    if (i == 0)
      data = op->FixedOutValue1;
     data = op->FixedOutValue2;
  }
 else
    io DoPackWord( cp, &data, i);
  if (i == 0) {
    testmask = op->TestMask1;
    invmask = op->InvMask1;
 else {
   testmask = op->TestMask2;
    invmask = op->InvMask2;
   if ( op->MaxNoOfChannels == 16)
     break;
  }
  /* Invert */
 data = data ^ invmask;
  /* Filter Po signals */
  if ( local->Filter[i].Found)
    io_PoFilter( local->Filter[i].sop, &data, local->Filter[i].Data);
  /* Testvalues */
  if ( testmask) {
   if (i == 0)
      testvalue = op->TestValue1;
   else
      testvalue = op->TestValue2;
   data = (data & ~ testmask) | (testmask & testvalue);
  /* Write to local Q-bus */
 wb.Data = data;
 wb.Address = local->Address[i];
  sts = write( local->Qbus fp, &wb, sizeof(wb));
  if ( sts == -1) {
    /* Increase error count and check error limits */
   clock_gettime(CLOCK_REALTIME, &now);
    if (op->ErrorCount > op->ErrorSoftLimit) {
      /* Ignore if some time has expired */
      if (now.tv sec - local->ErrTime.tv sec < 600)</pre>
        op->ErrorCount++;
    }
   else
      op->ErrorCount++;
    local->ErrTime = now;
    if ( op->ErrorCount == op->ErrorSoftLimit)
      errh Error( "IO Error soft limit reached on card '%s'", cp->Name);
    if ( op->ErrorCount >= op->ErrorHardLimit)
      errh_Error( "IO Error hard limit reached on card '%s', IO stopped", cp-
```

```
>Name);
    ctx->Node->EmergBreakTrue = 1;
    return IO_ERRDEVICE;
}
    continue;
}
return 1;
}

/* Every method to be exported to the workbench should be registred here. */
pwr_dExport pwr_BindIoMethods(Ssab_Do) = {
    pwr_BindIoMethod(IoCardInit),
    pwr_BindIoMethod(IoCardClose),
    pwr_BindIoMethod(IoCardWrite),
    pwr_NullMethod
};
```

Step by step description

This sections contains an example of how to attach an I/O system to Proview.

The I/O system in the example is USB I/O manufactured by Motion Control. It consists of a card with 21 channels of different type. The first four channels (A1 – A4) are Digital outputs of relay type for voltage up to 230 V. The next four channels (A5 – A8) are Digital inputs with optocouplers. Next eight channels (B1 – B8) can either be configured as digital outputs, digital inputs or analog inputs. The last 5 channels (C1 – C5) can be digital outputs or inputs, where C4 and C5 also can be configured as analog outputs. In our example, not wanting the code to be too complex, we lock the configuration to: channel 0-3 Do, 4-7 Di, 8-15 Ai, 16-18 Di and 19-20 Ao.

Attach to a project

In the first example we attach the I/O system to a project. We will create a classvolume, and insert rack and card classes into it. We will write I/O methods for the classes and link them to the plc program. We create I/O objects i the nodehierachy in the rootvolume, and install the driver for USB I/O, and start the I/O handling on the process station.

Create classes

Create a class volume

The first step is to create classes for the I/O objects. The classes are defined in classvolumes, and first we have to create a classvolume in the project. The classvolume first has to registered in the GlobalVolumeList. We start the aministrator with

```
> pwra
```

and opens the GlobalVolumeList by activating *File/Open/GlobalVolumeList* in the menu. We enter edit mode and create a VolumeReg object with the name *CVolMerk1*. The volume identity for user classvolumes should chosen in the interval 0.0.2-249.1-254 and we choose 0.0.99.20 as the identity for our classvolume. In the attribute Project the name of our project is stated, *mars2*.




Fig Classvolume registration

Open the classvolume

Next step is to configure and create the classvolume in the project. This is done in the directory volume.

We enter the directory volume

> pwrs

in edit mode and create an object of type ClassVolumeConfig in the volumehierarchy. The object is named with the volumename CVolMerk1. After saving and leaving edit mode we can open the classvolume by activating *OpenClassEditor*... in the popup menu of the object.




Fig Configuration of the classvolume in the directory volume och start of classeditor

In the classeditor classes are defined with specific classdefinition objects. We are going to create two classes, a rack class, *MotionControl_USB* and a card class *MotionControl_USBIO*.

Note! The class names has to be unic, which actually is not true for these names any more as they exist in the volume OtherIO.

Create a rack class

In our case the card class will do all the work and contain all the methods. The rack class is there only to inhabit the rack level, and doesn't have any methods or attributes. We will only put a description attribute in the class. We create a \$ClassHier object, and under this a \$ClassDef object for the class rack. The object is named MotionControl_USB and we set the IORack and IO bits in the Flag attribute.




Fig IO och IORack bitarna i Flags

Below the \$ClassDef object the attributes of the class are defined. We create a \$ObjBodyDef object and below this a \$Attribute object with the name Description and with type (TypeRef) pwrs:Type-\$String80.



Fig Attribut object

Create a card class

There is a baseclass for card objects, *Basecomponent:BaseIOCard*, that we can use, and that contains the most common attributes in a card object. We create another \$ClassDef object with the name MotionControl_USBIO, and set the IOCard and IO bits in the Flags attribute.




Fig IO and IOCard bits in Flags

We create an \$ObjBodyDef object and an \$Attribute object to state BaseIOCard as a superclass. The attribute is named Super and in TypeRef Basecomponent:Class-BaseIOCard is set. We will now inherit all attributes and methods defined in the class BaseIOCard.




Fig Configration of the superclass BaseIOCard

We add another attribute for the card status, and for the status we create an enumeration type, MotionControl_StatusEnum, that contains the various status codes that the status attribute can contain.




Fig Definition of an enumeration type

The type of the status attribute is set to the created status type, and in Flags, the bits *State* and *NoEdit* is set, as this attribute is not to be set in the configurator, but will be given a value in the runtime environment.




Fig Status attribute of enumeration type

Normally you also add attributes for the channel objects in the card class, but as the USB I/O device is so flexible, the same channel can be configured as a Di, Do or Ai channel, we choose not to place the channel objects as attributes. They will be configured as individual objects and placed as children to the card object in the root volume.

USB I/O contains a watchdog that will reset the unit if it is not written to within a certain time. We also add the attribute WatchdogTime to configure the timeout time.

When a class is saved for the first time, a Template object is created under the \$ClassDef object. This object is an instance of the actual class where you can set default values of the attributes. We state Specification, insert an URL to the datasheet, and set Process to 1. We also set MaxNoOfChannels to 21, as this card has 21 channels.





Fig Template object

Next step is to add the methods to the class description. While the card contains both inputs and outputs, we need to create Init, Close, Read and Write methods. These will be configured with methodobjects of type \$Method. First we put a \$RtMethod object, named IoMethods, under the \$ClassDef object. Below this, we create one \$RtMethod object for each method. The objects are named IoCardInit, IoCardClose, IoCardRead and IoCardWrite. In the attribute MethodName we state the string with witch the methods will be registred in the c-code, i.e. "MotionControl_USBIO-IoCardInit", etc.



FigI/O method configuration

From the superclass BaseIOCard we inherit a method to connect the object to a plc thread in the configurator.

Build the classvolume

Now the classes are created, and we save, leave edit mode, and create loadfiles for the classvolume by activating *Functions/Build Volume* in the menu. An include-file containing c structs for the classes, \$pwrp_inc/pwr_cvolmerk1classes.h, is also created when building the volume.

Install the driver

Download the driver and unpack the tar-file for the driver

> tar -xvzf usbio.tar.tz

Build the driver with make

- > cd usbio/driver/linux-2.6
- > make

Install the driver usbio.ko as root

> insmod usbio.ko

Allow all users to read and write to the driver

> chmod a+rw /dev/usbio0

Write methods

The next step is to write the c-code for the methods.

The c-file ra_io_m_motioncontrol_usbio.c are created on \$pwrp_src.

As Proview has a GPL license, also the code for the methods has to be GPL licensed if the program is distributed to other parties. We therefor put a GPL header in the beginning of the file.

To simplify the code we limit our use of USB I/O to a configuration where channel 0-3 are digital outputs, 4-7 digital inputs, 8-15 analog inputs, 16-18 digital inputs and 19-20 analog outputs.

ra_io_m_motioncontrol_usbio.c

```
* Proview
            $Id$
 * Copyright (C) 2005 SSAB Oxelösund.
 * This program is free software; you can redistribute it and/or
 * modify it under the terms of the GNU General Public License as
 * published by the Free Software Foundation, either version 2 of
 * the License, or (at your option) any later version.
 * This program is distributed in the hope that it will be useful
 * but WITHOUT ANY WARRANTY; without even the implied warranty of
 * MERCHANTABILITY or FITNESS FOR A PARTICULAR PURPOSE. See the
 * GNU General Public License for more details.
 * You should have received a copy of the GNU General Public License
 * along with the program, if not, write to the Free Software
 * Foundation, Inc., 675 Mass Ave, Cambridge, MA 02139, USA.
#include "pwr.h"
#include "pwr basecomponentclasses.h"
#include "pwr_cvolmerk1classes.h"
#include "rt io base.h"
#include "rt io card init.h"
#include "rt io card_close.h"
#include "rt_io_card_read.h"
#include "rt_io_card_write.h"
#include "rt io msg.h"
#include "libusbio.h"
typedef struct {
 int USB Handle;
} io sLocal;
// Init method
static pwr tStatus IoCardInit( io tCtx ctx,
                               io sAgent *ap,
                               io sRack *rp,
                               io sCard *cp)
  int i;
  int timeout;
  io sLocal *local;
 pwr sClass MotionControl USBIO *op = (pwr sClass MotionControl USBIO *)cp->op;
 local = (io_sLocal *) calloc( 1, sizeof(io sLocal));
 cp->Local = local;
```

```
// Configure 4 Do and 4 Di on Port A
 op->Status = USBIO ConfigDIO( &local->USB Handle, 1, 240);
  if (op->Status)
   errh Error( "IO Init Card '%s', Status %d", cp->Name, op->Status);
  // Configure 8 Ai on Port B
 op->Status = USBIO ConfigAI( &local->USB_Handle, 8);
 if ( op->Status)
   errh_Error( "IO Init Card '%s', Status %d", cp->Name, op->Status);
 // Configure 3 Di and 2 Ao on Port C
 op->Status = USBIO_ConfigDIO( &local->USB_Handle, 3, 7);
 if ( op->Status)
   errh_Error( "IO Init Card '%s', Status %d", cp->Name, op->Status);
 op->Status = USBIO_ConfigAO( &local->USB_Handle, 3);
 if ( op->Status)
   errh Error( "IO Init Card '%s', Status %d", cp->Name, op->Status);
 // Calculate conversion coefficients for Ai
 for ( i = 8; i < 16; i++) {
   if (cp->chanlist[i].cop &&
        cp->chanlist[i].sop &&
        cp->chanlist[i].ChanClass == pwr cClass ChanAi)
      io AiRangeToCoef( &cp->chanlist[i]);
  }
  // Calculate conversion coefficients for Ao
 for ( i = 19; i < 21; i++) {
   if (cp->chanlist[i].cop &&
        cp->chanlist[i].sop &&
        cp->chanlist[i].ChanClass == pwr cClass ChanAo)
      io AoRangeToCoef( &cp->chanlist[i]);
  }
 // Configure Watchdog
 timeout = 1000 * op->WatchdogTime;
 op->Status = USBIO ConfigWatchdog( &local->USB Handle, 1, timeout, 1,
                                     port mask, port, 3);
 errh Info( "Init of USBIO card '%s'", cp->Name);
 return IO SUCCESS;
// Close method
static pwr tStatus IoCardClose( io tCtx ctx,
                                io sAgent *ap,
                                io_sRack *rp,
                                io_sCard *cp)
 free( cp->Local);
 return IO SUCCESS;
// Read Method
static pwr_tStatus IoCardRead( io_tCtx ctx,
                               io_sAgent *ap,
                               io_sRack *rp,
```

}

```
io sCard *cp)
io sLocal *local = cp->Local;
pwr sClass MotionControl USBIO *op = (pwr sClass MotionControl USBIO *)cp->op;
int value = 0;
int i;
unsigned int m;
pwr_tUInt32 error_count = op->Super.ErrorCount;
// Read Di on channel 4 - 8
op->Status = USBIO_ReadDI( &local->USB_Handle, 1, &value);
if ( op->Status)
  op->Super.ErrorCount++;
else {
  // Set Di value in area object
  m = 1 << 4;
  for ( i = 4; i < 8; i++) {
    *(pwr tBoolean *)cp->chanlist[i].vbp = ((value & m) != 0);
   m = m << 1;
  }
}
// Read Ai on channel 8 - 16
for ( i = 0; i < 8; i++) {
  io sChannel *chanp = &cp->chanlist[i + 8];
  pwr_sClass_ChanAi *cop = (pwr_sClass_ChanAi *)chanp->cop;
  pwr_sClass_Ai *sop = (pwr_sClass_Ai *)chanp->sop;
  if ( cop->CalculateNewCoef)
    // Request to calculate new coefficients
    io_AiRangeToCoef( chanp);
    op->Status = USBIO ReadADVal( &local->USB Handle, i + 1, &ivalue);
    if ( op->Status)
     op->Super.ErrorCount++;
    else {
      io ConvertAi( cop, ivalue, &actvalue);
    // Filter the Ai value
    if ( sop->FilterType == 1 &&
         sop->FilterAttribute[0] > 0 &&
         sop->FilterAttribute[0] > ctx->ScanTime) {
      actvalue = *(pwr_tFloat32 *)chanp->vbp +
                 ctx->ScanTime / sop->FilterAttribute[0] *
                 (actvalue - *(pwr_tFloat32 *)chanp->vbp);
    }
    // Set value in area object
    *(pwr tFloat32 *)chanp->vbp = actvalue;
    sop->SigValue = cop->SigValPolyCoef1 * ivalue + cop->SigValPolyCoef0;
    sop->RawValue = ivalue;
  }
}
// Check Error Soft and Hard Limit
// Write warning message if soft limit is reached
if ( op->Super.ErrorCount >= op->Super.ErrorSoftLimit &&
     error count < op->Super.ErrorSoftLimit)
  errh_Warning( "IO Card ErrorSoftLimit reached, '%s'", cp->Name);
// Stop I/O if hard limit is reached
```

```
if ( op->Super.ErrorCount >= op->Super.ErrorHardLimit) {
    errh Error( "IO Card ErrorHardLimit reached '%s', IO stopped", cp->Name);
   ctx->Node->EmergBreakTrue = 1;
   return IO ERRDEVICE;
 return IO SUCCESS;
}
// Write method
static pwr tStatus IoCardWrite( io tCtx ctx,
                                io sAgent *ap,
                                io_sRack *rp,
                                io_sCard *cp)
  io sLocal *local = cp->Local;
 pwr sClass MotionControl USBIO *op = (pwr sClass MotionControl USBIO *)cp->op;
 int value = 0;
 float fvalue;
 int i;
 unsigned int m;
 pwr tUInt32 error count = op->Super.ErrorCount;
 pwr sClass ChanAo *cop;
 // Write Do on channel 1 - 4
 m = 1;
 value = 0;
  for ( i = 0; i < 4; i++) {
    if ( *(pwr tBoolean *)cp->chanlist[i].vbp)
     value |= m;
   m = m << 1;
  op->Status = USBIO WriteDO( &local->USB Handle, 1, value);
  if ( op->Status) op->Super.ErrorCount++;
  // Write Ao on channel 19 and 20
  if (cp->chanlist[19].cop &&
      cp->chanlist[19].sop &&
      cp->chanlist[19].ChanClass == pwr cClass ChanAo) {
   cop = (pwr sClass ChanAo *)cp->chanlist[19].cop;
    if ( cop->CalculateNewCoef)
      // Request to calculate new coefficients
     io_AoRangeToCoef( &cp->chanlist[19]);
    fvalue = *(pwr tFloat32 *)cp->chanlist[19].vbp * cop->OutPolyCoef1 +
             cop->OutPolyCoef0;
   op->Status = USBIO WriteAO( &local->USB Handle, 1, fvalue);
    if ( op->Status) op->Super.ErrorCount++;
  }
  if (cp->chanlist[20].cop &&
      cp->chanlist[20].sop &&
      cp->chanlist[20].ChanClass == pwr_cClass_ChanAo) {
   cop = (pwr_sClass_ChanAo *)cp->chanlist[20].cop;
    if ( cop->CalculateNewCoef)
      // Request to calculate new coefficients
     io AoRangeToCoef( &cp->chanlist[20]);
    fvalue = *(pwr tFloat32 *)cp->chanlist[20].vbp * cop->OutPolyCoef1 +
```

```
cop->OutPolyCoef0;
   op->Status = USBIO WriteAO( &local->USB Handle, 2, fvalue);
   if ( op->Status) op->Super.ErrorCount++;
  // Check Error Soft and Hard Limit
  // Write warning message if soft limit is reached
  if ( op->Super.ErrorCount >= op->Super.ErrorSoftLimit &&
       error_count < op->Super.ErrorSoftLimit)
    errh Warning( "IO Card ErrorSoftLimit reached, '%s'", cp->Name);
  // Stop I/O if hard limit is reached
  if ( op->Super.ErrorCount >= op->Super.ErrorHardLimit) {
   errh Error( "IO Card ErrorHardLimit reached '%s', IO stopped", cp->Name);
   ctx->Node->EmergBreakTrue = 1;
   return IO ERRDEVICE;
  }
 return IO SUCCESS;
}
// Every method should be registred here
pwr dExport pwr BindIoUserMethods(MotionControl USBIO) = {
 pwr BindIoUserMethod(IoCardInit),
 pwr BindIoUserMethod(IoCardClose),
 pwr BindIoUserMethod(IoCardRead),
 pwr_BindIoUserMethod(IoCardWrite),
 pwr_NullMethod
};
```

Class registration

To make it possible for the I/O framework to find the methods of the class, the class has to be registred. This is done by creating the file <code>pwrp_src/rt_io_user.c</code>. You use the macros <code>pwr_BindIoUserMethods</code> and <code>pwr_BindIoUserClass</code> for each class that contains methods.

rt_io_user.c

```
#include "pwr.h"
#include "rt_io_base.h"

pwr_dImport pwr_BindIoUserMethods(MotionControl_USBIO);

pwr_BindIoUserClasses(User) = {
   pwr_BindIoUserClass(MotionControl_USBIO),
   pwr_NullClass
};
```

Makefile

To compile the c-files we create a make-file on \$pwrp_src, \$pwrp_src/makefile. This will compile ra_io_m_motioncontro_usbio.c and rt_io_user.c, and place the object modules on the directory \$pwrp_obj.

makefile

```
mars2_top : mars2
include $(pwr_exe)/pwrp_rules.mk
```

Link file

We choose to call the methods from the plc process, and have to link the plc program with the object modules of the methods. To do this, we create a link file on \$pwrp_exe. We also have to add the archive with the USB I/O driver API, libusbio.a. The name fo the link file contains nodename and busnumber.

plc mars2 0507.opt

```
$pwrp_obj/rt_io_user.o $pwrp_obj/ra_io_m_motioncontrol_usbio.o -lusbio
```

Configure the node hierarchy

Now its time to configure the I/O objects in the node hierarchy with objects of the classes that we have created.

The rootvolume in our project is VolMerk1 and we open the configurator with

```
> pwrs volmerk1
```

In the palette to the left, under the map AllClasses we find the classvolme of the project, and under this the two classes for the USB I/O that we have created. Below the \$Node object we place a rack-object of class MotionControl_USB, and below this a card object of class MotionControl_USBIO. As the channelobjects are not internal objects in the cardobject, we have to create channel objects for the channels that we are going to use, below the card object. See the result in *Fig The Nodehierarchy*.




Fig The Nodehierarchy

We set the attribute Number, which states the index in the channel list, to 0 for the first channel object, 1 for the second etc. We set Process to 1 in the rack and card objects, and connects these objects to a plc thread by selecting a PlcThread object, and activating Connect PlcThread in the popupmenu for the rack and card object.

For the analog channels, ranges for conversion to/from ActualValue unit, has to be stated. The RawValue range for Ai channels are 0-1023, and the signal range 0-5 V. We configure the channels with an ActualValue range 0-100 in *Fig Ai channel*.




Fig Ai channel

When reading the Ao channels, you receive the signal value 0-5 V, and a configuration for ActualValue range 0-100 can be seen in *Fig Ao channel*.




Fig Ao channel

We also have to create signal objects in the plant hierarchy of types Di, Do, Ai and Ao, and connect these to each channel respectively. There also has to be a PlcPgm on the selected thread, to really create a thread in runtime. The remaining activities now are to build the node, distribute, check the linkage of the USB I/O device, connect it to the USB port and start Proview.