



SANITARY CERTIFICATE

Ref: L.Dis.No.8607/A9/2020, Office of the Deputy Director of Health Services,
Thoothukudi. Dt: 06.11.2020

THE TAMILNADU EDUCATIONAL RULES CHAPTER - III Rule 24 & Appendix - 3

I hereby declare that I have caused to inspect the building and premises of **SERVITE SCHOOL, MARAVANMADAM, Thoothukudi District** on 22-10-2020 and certify that the accommodation provided for each of the several classes is sufficient for the maximum number of pupil taught therein and the rooms are properly ventilated and lighted. That the building is maintained with substantial repairs, and is neat and clean that the latrine arrangements are adequate and satisfactory that in all other necessary aspects the sanitation is good.

This certificate valid upto May 2021

Certificate is issued with the Following Conditions:

1. Hand Wash facility should be established at the entrance of the School.
2. All the students and teachers should be wear face mask.
3. Social distancing should be maintained in all places.
4. Cough etiquette should be practiced properly.
5. Floors and frequent touched surfaces should be disinfected as per the Infection prevention guidelines.
6. Provide safe and protected drinking water regularly.
7. Environment and campus should be kept clean and neat free from Aedes larva.

Countersigned on the basis of the BHS inspection findings.

h. w. c.
BLOCK HEALTH SUPERVISOR
GOVT. PRIMARY HEALTH CENTRE
PUDUKOTTAI - 628 103.
THOOTHUKUDI DISTRICT

800 6.11.20
DEPUTY DIRECTOR
OF HEALTH SERVICES
TUTICORIN.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
DISTRICT WATER TESTING LABORATORY
Manjalneerkayal, Thoothukudi - 628 152

From

J. Amala Lourdu Mary B.Sc(Spl), B.Ed.,
 Junior Water Analyst, (a/c),
 IWAD Board, D.W.T. Laboratory,
 Manjalneerkayal, Thoothukudi.

To

Servite School CBSE,
 3/222 Palay Main Road,
 Indira Nagar, Maravan Madam Post,
 Thoothukudi.

Lr No:44105-44106-F.Report/IWA/DWTL/MNKayal/2019-20/ Dt. .02.2021.

Sir,

Sub : Examination of Water Sample report -furnished - reg.

Ref : 1. Your Lr.No/ Dt.28.01.2021.

2. T.O Invoice No. 4739/ Dated.28.01.2021 for Rs.1652/-

The result of analysis for the water sample sent under reference is furnished below.

Scheme : Private,

Date of Collection : 28.01.2021

Source: River Water,

Date of Receipt : 28.01.2021

Location : 44105-44106: School Campus,

BIS 10500 : 2012	Acceptable limit	Permissible limit in the absence of alternate source	Result
I. PHYSICAL EXAMINATION.			44105
1. Appearance	-	-	Clear
2. Colour	-	-	Colourless
3. Odour	Agreeable	Agreeable	None
4. Turbidity NT Units	1	5	0.0
5. Total dissolved Solids mg/L	500	2000	144
6. Electrical Conductivity Micro mho/cm	-	-	209
II. CHEMICAL EXAMINATION:			
7. pH	6.5-8.5	6.5-8.5	7.45
8. Ph. Alkalinity as CaCO ₃ mg/L	-	-	-
9. Total Alkalinity. as CaCO ₃ mg/L	200	600	80
10. Total Hardness as CaCO ₃ mg/L	200	600	50
11. Calcium as Ca mg/L	75	200	12
12. Magnesium as Mg mg/L	30	100	5
13. Sodium as Na mg/L	-	-	25
14. Potassium as K mg/L	-	-	2
15. Iron as Fe mg/L	0.3	1.0	0.00
16. Manganese mg/L	0.1	0.3	-
17. Free Ammonia as NH ₃ mg/L	0.5	0.5	0
18. Nitrite as NO ₂ mg/L	-	-	0.00
19. Nitrate as NO ₃ mg/L	45	45	1
20. Chloride as Cl mg/L	250	1000	18
21. Fluoride as F mg/L	1.0	1.5	0.0
22. Sulphate as SO ₄ mg/L	200	400	4
23. Phosphate as PO ₄ mg/L	-	-	0.00
24. Tidy's Test 4 hrs. as O ₂ mg/L	-	-	0.72
III BACTERIOLOGICAL EXAMINATION :			B44106
1. Faecal coliforms per 100 ml	Nil/100 ml	Nil/100 ml	Nil

Report 44105: The water is chemically potable.

B44106: The water is bacteriologically safe.

for *G. Mahesh Kumar*
 01/02/2021
 Junior Water Analyst (TWAD Board)
 District Water Testing Laboratory
 Manjalneerkayal, Thoothukudi.