

TAMILNADU WATER SUPPLY AND DRAINAGE BOARD DISTRICT WATER TESTING LABORATORY Manjalneerkayal, Thoothukudi - 628 152

J. Amala Lourdu Mary B.Sc(Spl), B.Ed., Junior Water Analyst,(a/c), TWAD Board, D.W.T. Laboratory,

To

Servite School CBSE, 3/222 Palay Main Road, Indira Nagar, Maravan Madam Post, Thoothukudi.

<u>Lr No:44105-44106-F.Report/JWA/DWTL/MNKayal/2019-20/ Dt. .02.2021.</u>

Sir,

Sub: Examination of Water Sample report -furnished - reg.

Ref: 1. Your Lr.No/ Dt.28.01.2021.

2. T.O Invoice No. 4739/ Dated.28.01.2021 for Rs.1652/-

The result of analysis for the water sample sent under reference is furnished below.

Scheme: Private,

Date of Collection: 28.01.2021

Date of Receipt

Source: River Water,

:28.01.2021

Location: 44105-44106: School Campus,

Manjalneerkayal, Thoothukudi.

BIS 10500 : 2012 I. PHYSICAL EXAMINATION.	Acceptable limit	Permissible limit in the absence of alternate source	Result
			44105
1. Appearance	-		Clear
2. Colour			Colourless
3. Odour	Agreeable	Agreeable	None
4. Turbidity NT Units	1	5	0.0
5. Total dissolved Solids mg/L	500	2000	144
6. Electrical Conductivity Micro mho/cm	-		209
II.CHEMICAL EXAMINATION:			
7. pH	6.5-8.5	6.5-8.5	7.45
8. Ph. Alkalinity as CaCo _{3 mg/L}	•		
9. Total Alkalinity. as CaCo _{3 mg/L}	200	600	80
10. Total Hardness as CaCo _{3 mg/L}	200	600	50
11. Calcium as Ca mg/L	75	200	12
12. Magnesium as Mg mg/L	30	100	5
13. Sodium as Na mg/L			25
14. Potassium as K mg/L			2
15. Iron as Fe mg/L	0.3	1.0	0.00
16. Manganese mg/L	0.1	0.3	_
17. Free Ammonia as NH _{3 mg/L}	0.5	0.5	0
18. Nitrite as NO _{2 mg/L}	2	2.00	0.00
19. Nitrate as NO _{3 mg/L}	45	45	1
20. Chloride as Cl mg/L	250	1000	18
21. Fluoride as F mg/L	1.0	1.5	0.0
22. Sulphate as SO _{4 mg/L}	200	400	4
23. Phosphate as PO _{4 mg/L}	_		0.00
24. Tidys Test 4 hrs.as O _{2 mg/L}			
III BACTERIOLOGICAL EXAMINATION:			0.72
1. Faecal coliforms per 100 ml	Nil/100 ml	N:1/1001	B44106
Report 44105:The water is chemically	1 MIN TOO IMI	Nil/100 ml	Nil

Report 44105: The water is chemically potable.

B44106: The water is bacteriologically safe.

Junior Water Analyst (TWAD Board) District Water Testing Laboratory Manjalneerkayal, Thoothukudi.