

School Name: **Bryant Elementary School**

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
1230-00-DW-006	Basement - Across Corridor from Fan Room - Right	10/6/2016	2.9	BA
1230-00-DW-007	Basement - Across Corridor from Fan Room	10/6/2016	1.1	BA
1230-00-DW-008	Basement - Across Corridor from Fan Room	10/6/2016	1.9	BA
1230-00-DW-009	Basement - Across Corridor from Fan Room	10/6/2016	0.84	BA
1230-00-DW-010	Basement - Across Corridor from Fan Room	10/6/2016	1.5	BA
1230-00-DW-011	Basement - Across Corridor from Fan Room - Left	10/6/2016	0.65	BA
1230-00-DW-012	Basement Fountains Adj from Girls Room - Right	10/6/2016	0.91	BA
1230-00-DW-014	Basement Fountains Adj from Girls Room	10/6/2016	0.48	BA
1230-00-DW-015	Basement Fountains Adj from Girls Room	10/6/2016	1.6	BA
1230-00-DW-017	Basement Fountains Adj from Girls Room - Left	10/6/2016	0.96	BA
1230-00-DW-027	Basement - Corridor Across from Gym - Right	10/6/2016	1.3	BA
1230-00-DW-028	Basement - Corridor Across from Gym	10/6/2016	19.2	AA
1230-00-DW-029	Basement - Corridor Across from Gym	10/6/2016	2.4	BA
1230-00-DW-030	Basement - Corridor Across from Gym	10/6/2016	4.1	BA
1230-00-DW-031	Basement - Corridor Across from Gym	10/6/2016	1.8	BA
1230-00-DW-032	Basement - Corridor Across from Gym - Left	10/6/2016	2.6	BA
1230-01-WC-038	Corridor by Boys and Girls Bathrooms - Right	10/6/2016	0.18	BA
1230-01-WC-039	Corridor by Boys and Girls Bathrooms - Left	10/6/2016	0.69	BA
1230-01-HS-045	Corridor between Rm 107 & 108	10/6/2016	<0.054	BA
1230-01-WC-047	Corridor by Room 103	10/6/2016	0.44	BA
1230-01-WC-049	Room 103 - near bathroom	10/6/2016	4.9	BA
1230-01-WC-050	Room 102 - near bathroom	10/6/2016	0.48	BA
1230-01-WC-052	Room 101 - outside bathroom	10/6/2016	1.9	BA
1230-02-WC-055	Corridor across from Room 213 - Right	10/6/2016	0.74	BA
1230-02-WC-056	Corridor across from Room 213 - Left	10/6/2016	1.1	BA
1230-02-WC-061	Teachers Lounge	10/6/2016	0.39	BA
1230-02-HS-064	Corridor adj. to Room 207	10/6/2016	<0.054	BA
1230-02-WC-067	Corridor adj. to Room 203	10/6/2016	3.2	BA
1230-03-WC-068	Corridor across from Room 313 - Right	10/6/2016	0.16	BA
1230-03-WC-069	Corridor across from Room 313 - Left	10/6/2016	0.41	BA
1230-03-WC-074	Teachers Lounge	10/6/2016	0.64	BA
1230-03-HS-077	Corridor Adj to Room 307	10/6/2016	<0.054	BA
1230-03-WC-080	Corridor Adj to Room 303	10/6/2016	0.52	BA
1230-01-WC-087	Main Lobby - outside of Auditorium	10/6/2016	4.8	BA
1230-01-WC-089	Lunch Room/Auditorium - Southeast Corner - Right	10/6/2016	0.67	BA
1230-01-WC-090	Lunch Room/Auditorium - Southeast Corner - Left	10/6/2016	1.2	BA
1230-01-WC-093	Lunch Room/Auditorium - Northwest Corner	10/6/2016	1.3	BA

DISTRICT ACTION LEVEL FOR LEAD IS 15 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 15 ppb

AA - Above District Action Level of 15 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb