

School Name: Steel Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
6390-01-DW-001	in Gymnasium	8/5/2016	0.31	BA
6390-01-WC-002	Room 113	8/5/2016	0.58	BA
6390-01-WC-005	Room 107	8/5/2016	0.61	BA
6390-01-WC-007	Across from Room 105	8/5/2016	0.17	BA
6390-01-WC-008	Cafeteria - opposite kitchen	8/5/2016	0.098	BA
6390-01-WC-009	Cafeteria - kitchen side (near wall outside of teacher's dining room)	8/5/2016	0.19	BA
6390-01-WC-010	Across from Main Office	8/5/2016	0.97	BA
6390-01-DW-012	Teachers Dining Room	8/5/2016	0.097	BA
6390-02-WC-020	Outside Room 214	8/5/2016	0.93	BA
6390-02-WC-033	Outside Room 211	8/5/2016	0.20	BA
6390-03-WC-034	Outside Room 311	8/5/2016	0.39	BA
6390-03-WC-047	Outside Room 314	8/5/2016	0.43	BA

DISTRICT ACTION LEVEL FOR LEAD IS 15 ppb*

SPREADSHEET LEGEND

BA - Below EPA Action Level of 15 ppb

AA - Above EPA Action Level

*EPA ACTION LEVEL FOR LEAD IS 20 ppb