

School Name: Pollock Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
8410-01-WC-010	In cafeteria - near exit to parking lot - left	8/5/2016	1.2	BA
8410-01-WC-011	In cafeteria - near exit to parking lot - right	8/5/2016	5.8	BA
8410-01-DW-012	In cafeteria - near cafeteria exit - left (center is no longer)	8/5/2016	2.6	BA
8410-01-DW-014	In cafeteria - near cafeteria exit - right (center is no longer)	8/5/2016	2.1	BA
8410-01-WC-015	Across from Room 10	8/5/2016	0.16	BA
8410-01-WC-020	Across from Room 17	8/5/2016	7.7	BA
8410-01-WC-036	Outside boy's room	8/5/2016	2.8	BA
8410-02-DW-040	Room 100	8/5/2016	7.9	BA
8410-02-DW-045	Room 101	8/5/2016	9.1	BA
8410-02-WC-049	Across from Room 105	8/5/2016	3.4	BA
8410-02-WC-059	Across from Main Office	8/5/2016	35.0	AA
8410-02-DW-063	In Gymnasium	8/5/2016	9.8	BA
8410-02-WC-067	Outside Room 111	8/5/2016	0.34	BA
8410-02-WC-072	Across from Room 119	8/5/2016	0.64	BA
8410-01-WC-077	Element 2 - Portable Building - Room 005	8/5/2016	0.88	BA
8410-01-WC-079	Element 2 - Room 006M Bright Futures area (middle room)	8/5/2016	0.54	BA
8410-01-WC-085	Element 2 - Room 007	8/5/2016	0.46	BA

DISTRICT ACTION LEVEL FOR LEAD IS 15 ppb*

SPREADSHEET LEGEND

BA - Below EPA Action Level of 15 ppb

AA - Above EPA Action Level

*EPA ACTION LEVEL FOR LEAD IS 20 ppb