

School Name: **Houston Elementary School**

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
6260-00-DW-001	Outside boy's room - left	10/20/2016	3.6	BA
6260-00-DW-002	Outside boy's room - right	10/20/2016	1.1	BA
6260-00-DW-003	Outside girl's room - left	10/20/2016	2.4	BA
6260-00-DW-004	Outside girl's room - center	10/20/2016	0.75	BA
6260-00-DW-005	Outside girl's room - right	10/20/2016	1.0	BA
6260-00-DW-006	Outside mechanical room	10/20/2016	3.9	BA
6260-00-DW-007	On column in lunch room	10/20/2016	2.9	BA
6260-01-DW-011	Hall next to auditorium	10/20/2016	5.7	BA
6260-01-DW-012	Outside Room 102	10/20/2016	0.93	BA
6260-01-DW-013	In Room 109	10/20/2016	14.5	BA
6260-01-WC-014	In main office	10/20/2016	0.97	BA
6260-01-DW-016	Outside Room 107	10/20/2016	1.6	BA
6260-02-DW-017	Outside Room 207	10/20/2016	1.5	BA
6260-02-WC-018	Room 211B - lounge - next to Room 209	10/20/2016	7.5	BA
6260-02-DW-019	Outside of Room 202	10/20/2016	1.6	BA
6260-02-DW-020	Outside of Room 210	10/20/2016	4.8	BA
6260-03-DW-021	Outside of Room 302	10/20/2016	0.92	BA
6260-03-DW-023	Outside of Room 307	10/20/2016	4.7	BA
6260-01-WC-024	Room 122 - Element 3	10/20/2016	0.26	BA

DISTRICT ACTION LEVEL FOR LEAD IS 15 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 15 ppb

AA - Above District Action Level of 15 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb