

School Name: Fox Chase Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
8260-00-WC-004	In Element 2 - Laboratory A	1/11/2017	0.83	BA
8260-00-KC-013	Kitchen - right side	1/11/2017	7.2	BA
8260-00-DW-015	Inside Cafeteria	1/11/2017	1.7	BA
8260-00-WC-023	In Element 3 - outside of Room A4	1/11/2017	1.1	BA
8260-00-WC-024	In Element 3 - outside of Room A5	1/11/2017	1.2	BA
8260-00-DW-035	Outside of the Gym office and Boy's Room	1/11/2017	2.0	BA
8260-01-CF-048	Nurse's Office	1/11/2017	4.6	BA
8260-01-DW-050	Across from the main Office	1/11/2017	1.1	BA
8260-01-KC-054	Teacher's Lounge	1/11/2017	4.2	BA
8260-01-DW-058	Room 102 at door to Room 101	1/11/2017	2.2	BA
8260-01-CF-063	Room 103 - kindergarten	1/11/2017	6.9	BA
8260-01-CF-065	Room 104 - kindergarten	1/11/2017	3.7	BA
8260-02-DW-077	Outside Room 205	1/11/2017	1.2	BA
8260-00-DW-085N	Inside IMC/Music Room	1/11/2017	3.6	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb