

School Name: Bregy Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
2240-00-WC-008	Basement hall bubbler - near Room 010X	12/2/2016	1.1	BA
2240-00-KC-010	Cafeteria - left sink	12/2/2016	4.0	BA
2240-00-KC-011	Cafeteria - right sink	12/2/2016	3.0	BA
2240-00-WC-015	Basement bubbler - outside Room 008 - left	12/2/2016	0.96	BA
2240-01-DW-020	1st floor kindergarten -Room 001K	12/2/2016	1.1	BA
2240-01-DW-022	Outside of Room 001K	12/2/2016	1.1	BA
2240-01-DW-025	Room No. 3	12/2/2016	1.2	BA
2240-01-WC-031	In hallway - outside Rooms 5 & 6	12/2/2016	1.4	BA
2240-02-DW-035	Outside Room 14	12/2/2016	1.5	BA
2240-02-WC-039	Outside Room 10	12/2/2016	0.52	BA
2240-03-WC-048	Outside Room 27	12/2/2016	1.3	BA
2240-01-CF-054	Room 004; Pre-Kindergarten	12/2/2016	2.0	BA
2240-00-DW-060	Outside basement boys room - near Room 005X - left	12/2/2016	2.1	BA
2240-00-DW-061	Outside basement boys room - near Room 005X - middle	12/2/2016	1.2	BA
2240-00-DW-062	Outside basement boys room - near Room 005X - right	12/2/2016	1.0	BA
2240-01-CF-063N	Room 001 - Autistic Support	12/2/2016	0.60	BA
2240-01-CF-064N	Room 002 - Autistic Support	12/2/2016	0.71	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb\*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

\*EPA ACTION LEVEL FOR LEAD IS 20 ppb