

School Name: Feltonville Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
7310-00-DW-037N	Outside Girl's Room - Left	9/30/2016	0.92	BA
7310-00-DW-038N	Outside Girls Room - Center	9/30/2016	0.19	BA
7310-00-DW-039N	Outside Girls Room - Right	9/30/2016	0.97	BA
7310-00-WC-040N	Proximate to Boy's Room - Left	9/30/2016	2.4	BA
7310-00-WC-041N	Proximate to Boy's Room - Center	9/30/2016	2.1	BA
7310-00-WC-042N	Proximate to Boy's Room - Right	9/30/2016	6.7	BA
7310-01-WC-043N	Outside Room 004 - Left	9/30/2016	0.16	BA
7310-01-WC-044N	Outside Room 004 - Right	9/30/2016	0.17	BA
7310-02-WC-045N	Outside Rooms 9 and 10 - Left	9/30/2016	0.18	BA
7310-02-WC-046N	Outside Rooms 9 and 10 - Right	9/30/2016	1.1	BA

DISTRICT ACTION LEVEL FOR LEAD IS 15 ppb\*

SPREADSHEET LEGEND

BA - Below District Action Level of 15 ppb

AA - Above District Action Level of 15 ppb

\*EPA ACTION LEVEL FOR LEAD IS 20 ppb