

**School Name:** Bridesburg Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
7470-01-HS-001	Cafeteria - Left	12/2/2016	0.074	BA
7470-01-HS-003	Outside Room 109 - Left	12/2/2016	0.074	BA
7470-01-WC-005	By Boys Room by Gym - Left	12/2/2016	17.5	AA
7470-01-WC-006	By Boys Room by Gym - Right	12/2/2016	11.1	AA
7470-01-DW-007	Gym - Left	12/2/2016	7.6	BA
7470-01-DW-008	Gym - Right	12/2/2016	6.9	BA
7470-01-WC-009	Kindergarten Room 102	12/2/2016	0.063	BA
7470-01-WC-010	Kindergarten Room 104	12/2/2016	0.067	BA
7470-01-WC-011	Kindergarten Room 106	12/2/2016	0.097	BA
7470-02-HS-012	Outside Room 205 by Staircase	12/2/2016	0.054	BA
7470-02-WC-013	Across from Room 208 - left	12/2/2016	0.15	BA
7470-01-KC-014	Kitchen	12/2/2016	0.60	BA
7470-01-CF-015	Nurse's Front Office	12/2/2016	0.32	BA
7470-01-CF-016	Nurse's Rear Office	12/2/2016	1.4	BA
7470-02-WC-017	Across from Room 208 - right	12/2/2016	0.20	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb\*

**SPREADSHEET LEGEND**

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

\*EPA ACTION LEVEL FOR LEAD IS 20 ppb