

School Name: J. H. Brown Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
8210-01-KC-012	Cafeteria - kitchen left	12/6/2016	2.3	BA
8210-01-KC-013	Cafeteria - kitchen center	12/6/2016	1.9	BA
8210-01-KC-014	Cafeteria - kitchen right	12/6/2016	7.2	BA
8210-01-DW-024	Room 108 - kindergarten	12/6/2016	3.3	BA
8210-01-DW-027	Room 107 - kindergarten	12/6/2016	2.6	BA
8210-01-DW-031	Room 106 - kindergarten	12/6/2016	3.8	BA
8210-01-DW-035	Outside Room 111	12/6/2016	0.89	BA
8210-01-DW-038	Across from Room 102	12/6/2016	4.4	BA
8210-02-DW-043	Across from Room 203 - left (right has been removed)	12/6/2016	1.2	BA
8210-02-DW-049	Across from Rm 206 & 207 - left (right removed)	12/6/2016	0.88	BA
8210-03-DW-057	Outside Room 307	12/6/2016	9.5	BA
8210-03-DW-062	Outside Room 306 - across from Room 303	12/6/2016	1.5	BA
8210-01-CF-064N	Room 110 - Nurse's Office	12/6/2016	5.5	BA
8210-02-WC-065N	Teacher's Lounge - next to sink; next to Room 201	12/6/2016	11.2	AA
8210-00-DW-066	Outside boy's room - left	12/6/2016	0.16	BA
8210-00-DW-067	Outside boy's room - center	12/6/2016	0.13	BA
8210-00-DW-068	Outside boy's room - right	12/6/2016	0.22	BA
8210-00-DW-069	Outside girl's room - left	12/6/2016	0.16	BA
8210-00-DW-070	Outside girl's room - center	12/6/2016	0.22	BA
8210-00-DW-071	Outside girl's room - right	12/6/2016	0.21	BA
8210-03-DW-072	Outside Room 308	12/6/2016	0.91	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb