

School Name: **Holme Elementary School**

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
8270-00-DW-009	Room 001 - Head Start	8/12/2016	53.4	AA
8270-00-DW-011	Room 002 - Head Start	8/12/2016	26.2	AA
8270-00-WC-016	Outside Lunch Room - across from Room 001	8/12/2016	5.9	BA
8270-00-DW-017	Outside of Gymnasium	8/12/2016	10.6	BA
8270-00-WC-020	inside IMC	8/12/2016	5.3	BA
8270-01-DW-033	Outside Room 108 - Left	8/12/2016	53.1	AA
8270-01-DW-034	Outside Room 108 - Right	8/12/2016	18.0	AA
8270-01-WC-039	Dressing Room B - (115)	8/12/2016	26.9	AA
8270-01-DW-041	Across from Room 112	8/12/2016	12.2	BA
8270-01-DW-051	Across from Room 101 - Left	8/12/2016	25.6	AA
8270-01-DW-052	Across from Room 101 - Right	8/12/2016	25.5	AA
8270-02-DW-074	Outside Room 207 - Left (right has been removed)	8/12/2016	20.3	AA
8270-02-DW-082	Across from Room 213 - Left	8/12/2016	14.1	BA
8270-02-DW-083	Across from Room 213 - Right	8/12/2016	20.1	AA
8270-02-WC-085	Teacher's Lounge	8/12/2016	5.1	BA
8270-02-DW-092	Outside Room 209 - Left	8/12/2016	19.1	AA
8270-02-DW-093	Outside Room 209 - Right	8/12/2016	31.4	AA
8270-01-WC-099	Element 3 - Room 064 (Room 004 on Drawing)	8/12/2016	1.8	BA
8270-01-WC-102	Element 3 - Room 61 (room 001 on Drawing)	8/12/2016	2.8	BA
8270-01-WC-105	Element 3 - Head Start - Room 62 (Room 002 on Drawing)	8/12/2016	2.6	BA
8270-01-WC-108	Element 3 - Head Start - Room 65 (Room 005 on Drawing)	8/12/2016	2.0	BA
8270-01-WC-111	Element 3 - Head Start - Room 66 (Room 006 on Drawing)	8/12/2016	3.1	BA
8270-01-WC-114	Element 3 - Head Start - Room 63 (Room 003 on Drawing)	8/12/2016	4.1	BA

DISTRICT ACTION LEVEL FOR LEAD IS 15 ppb*

SPREADSHEET LEGEND

BA - Below EPA Action Level of 15 ppb

AA - Above EPA Action Level

*EPA ACTION LEVEL FOR LEAD IS 20 ppb