

School Name: **Hopkinson Elementary School**

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
7300-00-DW-007	Outside Girl's Room - left	9/29/2016	16.9	AA
7300-00-DW-009	Outside Girls Room - right	9/29/2016	3.0	BA
7300-00-DW-021	Outside Boy's Room - Left	9/29/2016	5.1	BA
7300-00-DW-022	Outside Boy's Room	9/29/2016	3.1	BA
7300-00-DW-023	Outside Boy's Room	9/29/2016	1.9	BA
7300-00-DW-025	Outside Boy's Room	9/29/2016	2.6	BA
7300-00-DW-026	Outside Boy's Room - Right	9/29/2016	0.92	BA
7300-01-WC-037	Outside Room 107	9/29/2016	0.64	BA
7300-01-WC-044	Outside IMC	9/29/2016	4.2	BA
7300-01-DW-049	Room 102	9/29/2016	8.0	BA
7300-01-WC-050	Room 101	9/29/2016	0.64	BA
7300-02-WC-058	Outside of Room 204	9/29/2016	6.1	BA
7300-02-WC-059	Outside of Room 207	9/29/2016	0.99	BA
7300-03-WC-065	Outside of Room 307	9/29/2016	0.75	BA
7300-03-WC-068	Outside of Room 304	9/29/2016	0.91	BA

DISTRICT ACTION LEVEL FOR LEAD IS 15 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 15 ppb

AA - Above District Action Level of 15 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb