

School Name: Benjamin Franklin High School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
2010-01-HS-032	Outside Room 115 - Right	9/1/2016	0.054	BA
2010-03-DW-051	Outside Room 317	9/1/2016	0.18	BA
2010-03-HS-053	Outside Room 321 - Right (left side has been removed)	9/1/2016	21.4	AA
2010-05-DW-061	Across From Room 503	9/1/2016	43.0	AA
2010-06-DW-062	Cafeteria - Kitchen end of room	9/1/2016	276	AA
2010-06-WC-074	Cafeteria - Elevator end of room - facing kitchen	9/1/2016	74.1	AA
2010-00-DW-298N	Across from Room 13	9/1/2016	18.2	AA
2010-00-DW-299N	Outside of Room 17 - left	9/1/2016	19.9	AA
2010-05-HS-302N	Across From Room 508	9/1/2016	0.057	BA
2010-06-HS-303N	In the cafeteria - on the far wall past the kitchen	9/1/2016	0.11	BA
2010-01-HS-305N	Basement - outside of Room 5D	9/1/2016	0.054	BA

DISTRICT ACTION LEVEL FOR LEAD IS 15 ppb\*

SPREADSHEET LEGEND

BA - Below EPA Action Level of 15 ppb

AA - Above EPA Action Level

\*EPA ACTION LEVEL FOR LEAD IS 20 ppb