

School Name: The U School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
5290-01-WC-034	Across from Room 102	12/6/2016	6.0	BA
5290-01-BF-035	Nurse's Office - bathroom	12/6/2016	1.9	BA
5290-01-WC-039	Room 103	12/6/2016	1.5	BA
5290-01-WC-043	Across from Room 107	12/6/2016	1.1	BA
5290-02-WC-044	Across from Room 206	12/6/2016	2.1	BA
5290-03-WC-056	Across from Room 306	12/6/2016	10.5	AA
5290-00-DW-057N	Outside Building Engineer's office - left	12/6/2016	5.1	BA
5290-00-DW-058N	Outside Girl's Room - far right side	12/6/2016	130	AA
5290-00-DW-059N	Element 2 - across from Girl's Room	12/6/2016	1.6	BA
5290-01-WC-061N	Element 2 - outside Boy's Room - right side	12/6/2016	1.8	BA
5290-02-WC-063N	Across from Room 202	12/6/2016	1.8	BA
5290-03-WC-064N	Across from Room 302	12/6/2016	4.7	BA
5290-03-HS-065N	Element 2 - outside utility closet	12/6/2016	0.074	BA
5290-00-DW-069N	Outside kitchen - right side	12/6/2016	2.6	BA
5290-00-DW-070N	Outside Building Engineer's office - 2nd from the left	12/6/2016	4.1	BA
5290-00-DW-071N	Outside Building Engineer's office - 3rd from the left	12/6/2016	41.7	AA
5290-00-DW-072N	Outside Building Engineer's office - right	12/6/2016	96.3	AA
5290-00-DW-073N	Outside Girl's Room - left	12/6/2016	286	AA
5290-00-DW-074N	Outside Girl's Room - middle	12/6/2016	70.8	AA
5290-01-HS-076N	Element 2 - outside Boy's Room - left side	12/6/2016	0.15	BA
5290-02-WC-078N	Main office	12/6/2016	7.8	BA
5290-02-KC-081N	Main Office - kitchenette	12/6/2016	8.2	BA
5290-02-HS-082N	Element 2 - outside Boy's Room - right side	12/6/2016	0.074	BA
5290-03-WC-083N	Element 2 - outside Boy's Room - right side	12/6/2016	9.4	BA
5290-00-KC-131N	Kitchen - left	12/6/2016	1.3	BA
5290-00-KC-132N	Kitchen - right	12/6/2016	1.1	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb