School Name: Overbrook Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
4370-00-HS-005	Outside boy's room	12/22/2016	0.054	BA
4370-00-WC-007	Outside girl's room	12/22/2016	0.70	BA
4370-00-KC-011	In Cafeteria	12/22/2016	3.6	BA
4370-01-WC-014	Outside main office	12/22/2016	0.50	BA
4370-01-HS-018	Outside Room 006	12/22/2016	0.054	BA
4370-02-HS-026	Outside Teachers Room - Room 20C	12/22/2016	0.054	BA
4370-02-BF-028	Nurse's Office - mezzanine level on stairwell	12/22/2016	3.7	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

 $\ensuremath{\mathsf{BA}}$ - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

^{*}EPA ACTION LEVEL FOR LEAD IS 20 ppb