

School Name: Dobson Elementary School

| Outlet ID # | Outlet Location | Sample Collection Date | Test Result (ppb) | Test Results |
|----------------|--|------------------------|-------------------|--------------|
| 6450-00-KC-012 | Kitchen/Lunch Room | 12/21/2016 | 3.0 | BA |
| 6450-01-HS-027 | Outside Room 101 | 12/21/2016 | 0.054 | BA |
| 6450-01-CF-028 | Nurse's Office | 12/21/2016 | 0.75 | BA |
| 6450-01-KC-033 | Room 106 - special needs | 12/21/2016 | 1.0 | BA |
| 6450-01-WC-037 | Outside Room 108 | 12/21/2016 | 0.34 | BA |
| 6450-02-WC-039 | Outside Room 209 | 12/21/2016 | 0.62 | BA |
| 6450-02-HS-042 | Outside Room 202 | 12/21/2016 | 0.054 | BA |
| 6450-03-HS-043 | Outside Room 302 | 12/21/2016 | 0.054 | BA |
| 6450-03-KC-047 | Teacher's Lounge | 12/21/2016 | 1.2 | BA |
| 6450-03-WC-049 | Outside Room 308 | 12/21/2016 | 0.18 | BA |
| 6450-00-DW-057 | Outside Building Engineer's Office - left | 12/21/2016 | 1.8 | BA |
| 6450-00-DW-058 | Outside Building Engineer's Office - right | 12/21/2016 | 1.7 | BA |
| 6450-00-DW-059 | Outside Basement boy's room - left | 12/21/2016 | 0.76 | BA |
| 6450-00-DW-060 | Outside Basement boy's room - right | 12/21/2016 | 1.1 | BA |

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb