

School Name: Elkin Elementary School and Little School House

| Outlet ID # | Outlet Location | Sample Collection Date | Test Result (ppb) | Test Results |
|---|--|------------------------|-------------------|--------------|
| 5260-01-HS-004 | Outside of the Lunch Room | 12/20/2016 | 0.054 | BA |
| 5260-01-DW-007 | Room B02 | 12/20/2016 | 2.8 | BA |
| 5260-01-DW-008 | Outside Room B01 | 12/20/2016 | 2.7 | BA |
| 5260-01-DW-013 | Lunch Room | 12/20/2016 | 0.24 | BA |
| 5260-01-KC-024 | Kitchen - left | 12/20/2016 | 2.5 | BA |
| 5260-01-KC-025 | Kitchen - right | 12/20/2016 | 1.4 | BA |
| 5260-01-WC-026 | Teachers Lounge | 12/20/2016 | 10.2 | AA |
| 5260-01-DW-030 | Gymnasium | 12/20/2016 | 0.76 | BA |
| 5260-02-DW-037 | Security Office | 12/20/2016 | 15.2 | AA |
| 5260-02-HS-045 | Outside of Room 111 | 12/20/2016 | 0.054 | BA |
| 5260-02-DW-049 | Room 114 | 12/20/2016 | 6.3 | BA |
| 5260-02-DW-054 | Room 109 | 12/20/2016 | 5.0 | BA |
| 5260-02-DW-058 | Room 110 | 12/20/2016 | 3.3 | BA |
| 5260-02-WC-059 | Outside Room 107 | 12/20/2016 | 0.37 | BA |
| 5260-02-DW-064 | Room 108 | 12/20/2016 | 5.4 | BA |
| 5260-02-CF-078 | Nurse's Office | 12/20/2016 | 1.8 | BA |
| 5260-03-HS-092 | Outside Room 213 | 12/20/2016 | 0.054 | BA |
| 5260-03-DW-103 | Outside Room 209 | 12/20/2016 | 1.1 | BA |
| 5260-03-DW-104 | Room 209 | 12/20/2016 | 3.0 | BA |
| 5260-03-DW-108 | Room 207 | 12/20/2016 | 5.2 | BA |
| 5260-03-DW-113 | Room 205 | 12/20/2016 | 13.5 | AA |
| 5260-02-DW-126 | Room 115 | 12/20/2016 | 56.2 | AA |
| 5260-02-DW-129 | Room 105 | 12/20/2016 | 10.4 | AA |
| 5260-02-DW-130 | Room 104 | 12/20/2016 | 4.7 | BA |
| 5260-02-DW-131 | Room 103 | 12/20/2016 | 16.4 | AA |
| 5260-02-DW-132 | Room 102 | 12/20/2016 | 5.7 | BA |
| <u>Little School House/Portable @ Elkin Elementary School</u> | | | | |
| 5260-01-HS-137N | Across from Multi-Purpose Room - left | 12/20/2016 | 0.054 | BA |
| 5260-01-WC-138N | Across from Multi-Purpose Room - right | 12/20/2016 | 0.070 | BA |
| 5260-01-DW-139N | Little School House - Classroom 1 | 12/20/2016 | 2.6 | BA |
| 5260-01-DW-140N | Little School House - Classroom 2 | 12/20/2016 | 0.45 | BA |
| 5260-01-DW-141N | Little School House - Classroom 3 | 12/20/2016 | 0.68 | BA |
| 5260-01-DW-142N | Little School House - Classroom 4 | 12/20/2016 | 8.8 | BA |
| 5260-01-DW-143N | Little School House - Classroom 5 | 12/20/2016 | 0.25 | BA |
| 5260-01-DW-144N | Little School House - Classroom 6 | 12/20/2016 | 0.38 | BA |
| 5260-01-DW-145N | Little School House - Classroom 7 | 12/20/2016 | 36.3 | AA |
| 5260-01-DW-146N | Little School House - Classroom 8 | 12/20/2016 | 0.41 | BA |
| 5260-01-KC-147N | Little School House - Kitchen - left | 12/20/2016 | 1.2 | BA |
| 5260-01-KC-148N | Little School House - Kitchen - right | 12/20/2016 | 1.2 | BA |

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb