

School Name: Barry Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
1200-01-WC-001	Main Lobby across from Main Office – Left Side	11/30/2016	0.55	BA
1200-01-WC-002	Main Lobby across from Main Office – Right Side	11/30/2016	0.58	BA
1200-01-WC-003	Hall at Boys Restroom and Room 109 – Left Side	11/30/2016	0.32	BA
1200-01-WC-004	Hall at Boys Restroom and Room 109 – Right Side	11/30/2016	0.34	BA
1200-01-WC-005	Room 109 – Left Side	11/30/2016	0.16	BA
1200-01-WC-006	Room 109 – Right Side	11/30/2016	0.16	BA
1200-01-WC-007	Room 108	11/30/2016	0.18	BA
1200-01-WC-008	Room 107	11/30/2016	0.18	BA
1200-01-WC-009	Room 106	11/30/2016	0.20	BA
1200-01-WC-010	Room 105	11/30/2016	0.44	BA
1200-01-WC-011	Room 104	11/30/2016	0.16	BA
1200-01-WC-012	Cafetorium – Left Side	11/30/2016	0.37	BA
1200-01-WC-013	Cafetorium – Right Side	11/30/2016	0.46	BA
1200-02-WC-014	Between Restrooms – North Side of Building – Left	11/30/2016	0.11	BA
1200-02-WC-015	Between Restrooms – North Side of Building – Right	11/30/2016	0.11	BA
1200-02-WC-016	Room 203	11/30/2016	0.58	BA
1200-02-WC-017	Room 202	11/30/2016	0.56	BA
1200-03-WC-018	Hallway B/T Rooms 311 & 310 – B/T Restrooms – Left	11/30/2016	0.64	BA
1200-03-WC-019	Hallway B/T Rooms 311 & 310 – B/T Restrooms – Right	11/30/2016	0.96	BA
1200-03-WC-020	Room 320	11/30/2016	0.17	BA
1200-03-WC-021	Room 303	11/30/2016	0.21	BA
1200-03-WC-022	Room 301	11/30/2016	0.15	BA
1200-04-WC-023	Hallway at Room 406 – B/T Restrooms – Left	11/30/2016	0.53	BA
1200-04-WC-024	Hallway at Room 406 – B/T Restrooms – Right Side	11/30/2016	0.65	BA
1200-04-WC-025	Room 401	11/30/2016	0.15	BA
1200-04-WC-026	Room 407	11/30/2016	0.20	BA
1200-01-KC-027	Cafetorium - Kitchen - Rear Wall	11/30/2016	1.2	BA
1200-01-KC-029	Cafetorium - Kitchen - Right Wall - Sink - Left	11/30/2016	1.2	BA
1200-01-KC-030	Cafetorium - Kitchen - Right Wall - Sink - Right	11/30/2016	18.7	AA
1200-02-CF-032	Room 211 - Kindergarten	11/30/2016	0.40	BA
1200-02-CF-033	Nurse's Office Exam Room	11/30/2016	1.5	BA
1200-04-CF-034	Room 402 - Teacher's Lounge	11/30/2016	0.71	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb