

School Name: Benjamin Franklin High School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
2010-00-DW-006	Center of Lobby Area - Left - Used by Day Care	8/18/2016	7.4	BA
2010-00-DW-007	Center of Lobby Area - Right - Used by Day Care	8/18/2016	6.9	BA
2010-01-DW-015	Outside Room 100	8/18/2016	5.4	BA
2010-01-DW-021	Gymnasium - East End	8/18/2016	2.4	BA
2010-01-DW-031	Outside Room 115 - Left	8/18/2016	12.5	BA
2010-01-DW-032	Outside Room 115 - Right	8/18/2016	36.0	AA
2010-02-DW-041	Outside Room 211 - Left	8/18/2016	13.1	BA
2010-02-DW-042	Outside Room 211 - Right	8/18/2016	10.9	BA
2010-02-DW-045	Outside Room 203 - Left (right side has been removed)	8/18/2016	5.8	BA
2010-03-DW-050	Outside Room 305 - Right (left side has been removed)	8/18/2016	12	BA
2010-03-DW-051	Outside Room 317	8/18/2016	15.2	AA
2010-03-DW-053	Outside Room 321 - Right (left side has been removed)	8/18/2016	28.1	AA
2010-04-DW-054	Outside Room 414	8/18/2016	13.2	BA
2010-04-DW-056	Outside Room 406	8/18/2016	7.6	BA
2010-04-DW-057	Across from Room 403	8/18/2016	6.9	BA
2010-05-DW-060	Outside Room 505	8/18/2016	7.4	BA
2010-05-DW-061	Across From Room 503	8/18/2016	16.6	AA
2010-06-DW-062	Cafeteria - Kitchen end of room	8/18/2016	16.2	AA
2010-06-WC-074	Cafeteria - Elevator end of room - facing kitchen	8/18/2016	15.2	AA
2010-06-DW-077	Teachers Lounge - Left	8/18/2016	32.8	AA
2010-00-DW-296N	Across from Room 7C - left	8/18/2016	7.9	BA
2010-00-DW-297N	Across from Room 7C - right	8/18/2016	5.4	BA
2010-00-DW-298N	Across from Room 13	8/18/2016	16.0	AA
2010-00-DW-299N	Outside of Room 17 - left	8/18/2016	19.7	AA
2010-00-DW-300N	Outside of Room 17 - right	8/18/2016	8.7	BA
2010-03-DW-301N	Across from Room 303	8/18/2016	12.9	BA
2010-05-DW-302N	Across From Room 508	8/18/2016	56.1	AA
2010-06-DW-303N	In the cafeteria - on the far wall past the kitchen	8/18/2016	22.1	AA
2010-01-DW-304N	On the west side of the gym	8/18/2016	5.8	BA
2010-01-DW-305N	Basement - outside of Room 5D	8/18/2016	36.0	AA

DISTRICT ACTION LEVEL FOR LEAD IS 15 ppb*

SPREADSHEET LEGEND

BA - Below EPA Action Level of 15 ppb

AA - Above EPA Action Level