

School Name: **Forrest Elementary School**

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
8250-00-WC-001	Outside girl's room - left	1/10/2017	1.5	BA
8250-00-WC-002	Outside girl's room - right	1/10/2017	0.36	BA
8250-00-DW-003	Inside Room B-1	1/10/2017	3.1	BA
8250-00-WC-008	Outside Boy's Room; Across from B-3	1/10/2017	1.1	BA
8250-01-WC-009	Between Boy's Room and Room 107	1/10/2017	3.0	BA
8250-01-HS-010	Between Girl's Room and Room 104	1/10/2017	0.054	BA
8250-01-WC-011	Room 103	1/10/2017	2.2	BA
8250-02-WC-013	Teacher's Lounge, Room 213	1/10/2017	0.25	BA
8250-02-HS-016	Between Girl's Room and Room 204	1/10/2017	0.054	BA
8250-02-WC-017	Between Boy's Room and Room 207	1/10/2017	0.80	BA
8250-03-WC-018	Between Boy's Room and Room 307	1/10/2017	0.70	BA
8250-03-HS-019	Between Girl's Room and Room 304	1/10/2017	0.054	BA
8250-01-DW-020	Within Modular Building - near bathroom	1/10/2017	1.6	BA
8025-02-CF-055	Nurse's Office	1/10/2017	2.4	BA
8250-01-WC-070N	In PEC Bldg - all purpose room - left	1/10/2017	0.057	BA
8250-01-WC-071N	In PEC Bldg - all purpose room - right	1/10/2017	0.13	BA
8250-01-HS-072N	In PEC Bldg - outside bathroom - left	1/10/2017	0.054	BA
8250-01-WC-074N	In PEC Bldg - between P9 & P11 - left	1/10/2017	0.082	BA
8250-01-WC-075N	In PEC Bldg - between P9 & P11 - right	1/10/2017	0.090	BA
8250-01-WC-076N	In PEC Bldg - Room P1	1/10/2017	0.11	BA
8250-01-WC-077N	In PEC Bldg - Room P2	1/10/2017	0.16	BA
8250-01-WC-078N	In PEC Bldg - Room P3	1/10/2017	0.36	BA
8250-01-WC-079N	In PEC Bldg - Room P4	1/10/2017	0.18	BA
8250-01-WC-080N	In PEC Bldg - Room P5	1/10/2017	0.061	BA
8250-01-KC-081N	In PEC Bldg - Kitchen left	1/10/2017	0.62	BA
8250-01-KC-082N	In PEC Bldg - Kitchen right	1/10/2017	8.2	BA
8250-01-KC-083N	In PEC Bldg - Teacher's Lounge	1/10/2017	0.37	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb