

School Name: Clara Barton Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
7200-00-KC-011	Kitchen - left	12/1/2016	8.0	BA
7200-00-KC-013	Kitchen - right	12/1/2016	4.5	BA
7200-01-WC-037	Room 111	12/1/2016	1.8	BA
7200-01-CF-039	Nurse's Office - next to Room 111	12/1/2016	1.5	BA
7200-01-WC-040	Outside of Room 110, by nurse	12/1/2016	18.7	AA
7200-01-WC-046	Outside of Room 104 (between Rooms 103 & 104)	12/1/2016	0.56	BA
7200-01-KC-054	Room 214 - Teacher's Lounge	12/1/2016	3.7	BA
7200-02-WC-056	Outside of Room 203	12/1/2016	9.8	BA
7200-02-WC-059	Outside of Room 210	12/1/2016	1.0	BA
7200-03-WC-062	Next to Room 311	12/1/2016	4.2	BA
7200-03-WC-065	Next to Room 307B	12/1/2016	0.41	BA
7200-03-WC-066	Outside of Room 304	12/1/2016	6.4	BA
7200-02-WC-072	Teacher's Lounge - next to soda machine; across from Room 201	12/1/2016	9.3	BA
7200-00-DW-075N	Outside boy's room and room B-8 - left	12/1/2016	0.81	BA
7200-00-DW-076N	Outside boy's room and room B-8 - center	12/1/2016	0.81	BA
7200-00-DW-077N	Outside boy's room and room B-8 - right	12/1/2016	0.77	BA
7200-00-WC-078N	Inside Gymnasium - left	12/1/2016	0.30	BA
7200-00-WC-079N	Inside Gymnasium - middle	12/1/2016	2.5	BA
7200-00-WC-080N	Inside Gymnasium -right	12/1/2016	0.44	BA
7200-02-WC-081N	Outside Room 206	12/1/2016	0.21	BA
7200-00-WC-082N	Outside the Cafeteria, by Boy's Room - left	12/1/2016	3.5	BA
7200-00-WC-083N	Outside the Cafeteria, by Boy's Room -center	12/1/2016	2.0	BA
7200-00-WC-084N	Outside the Cafeteria, by Boy's Room - right	12/1/2016	2.5	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb