

School Name: Dunbar Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
5250-00-DW-005	Outside physical education office	10/21/2016	1.2	BA
5250-00-DW-013	Outside boys room - left	10/21/2016	0.93	BA
5250-00-DW-015	Outside boys room - middle	10/21/2016	1.7	BA
5250-00-DW-016	Outside boys room - right	10/21/2016	0.49	BA
5250-01-DW-021	Across from Room 108	10/21/2016	7.3	BA
5250-01-DW-023	Room 107	10/21/2016	7.5	BA
5250-01-HS-026	Outside Room 103	10/21/2016	<0.054	BA
5250-02-WC-036	Across from Room 208	10/21/2016	0.30	BA
5250-02-DW-040	Room 207	10/21/2016	7.2	BA
5250-03-WC-042	Across from Room 308	10/21/2016	0.40	BA
5250-03-DW-049	Across from IMC - remaining outlet on the right	10/21/2016	10	BA
5250-03-HS-050	Across from IMC - right of DW-049	10/21/2016	<0.054	BA
5250-04-DW-068	Room 401 - girls side roof top horitculture	10/21/2016	1.1	BA
5250-02-HS-069N	Outside Room 203	10/21/2016	<0.054	BA

DISTRICT ACTION LEVEL FOR LEAD IS 15 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 15 ppb

AA - Above District Action Level of 15 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb