

School Name: Gompers Elementary School

Outlet ID #	Sample Location	Sample Collection Date	Test Result (ppb)	Test Results
4280-01-DW-004	In Room 101	7/21/2016	12.6	BA
4280-01-DW-009	Outside Room 103 - right	7/21/2016	151	AA
4280-01-WC-018	Outside Main Office	7/21/2016	0.99	BA
4280-02-DW-038	Outside Room 207 - Left	7/21/2016	3.3	BA
4280-02-DW-039	Outside Room 207 - Right	7/21/2016	4.2	BA
4280-02-DW-053	In Gym - on the hallway wall	7/21/2016	16.4	AA
4280-02-DW-054	In Gym - outside of Boy's Room	7/21/2016	11.9	BA
4280-02-DW-060	In Lunchroom	7/21/2016	4.9	BA
4280-02-WC-067	Outside Room 203	7/21/2016	3.0	BA
4280-01-WC-070	Element 2 - Left side - comprehensive day care room	7/21/2016	0.26	BA
4280-01-WC-073	Element 2 - Right side - comprehensive day care room	7/21/2016	0.23	BA
4280-01-WC-086	Element 4 - portable 2 - outside of bathrooms	7/21/2016	1.4	BA
4280-01-WC-090	Principal's office - bottled water dispenser - Hot side	7/21/2016	0.054	BA
4280-01-WC-091	Principal's office - bottled water dispenser - Cold side	7/21/2016	0.054	BA

DISTRICT ACTION LEVEL FOR LEAD IS 15 ppb\*

SPREADSHEET LEGEND

BA - Below EPA Action Level of 15 ppb

AA - Above EPA Action Level

\*EPA ACTION LEVEL FOR LEAD IS 20 ppb