

School Name: Julia De Burgos Elementary School

| Outlet ID # | Outlet Location | Sample Collection Date | Test Result (ppb) | Test Results |
|----------------|---|------------------------|-------------------|--------------|
| 5170-01-DW-001 | Hallway at Room 102- Left | 12/15/2016 | 0.16 | BA |
| 5170-01-DW-002 | Hallway at Room 102 | 12/15/2016 | 0.22 | BA |
| 5170-01-DW-003 | Hallway at Room 102 | 12/15/2016 | 0.18 | BA |
| 5170-01-DW-004 | Hallway at Room 102-Right | 12/15/2016 | 0.12 | BA |
| 5170-02-DW-007 | Across from Room 213-Left | 12/15/2016 | 0.28 | BA |
| 5170-02-DW-008 | Across from Room 213-Right | 12/15/2016 | 0.23 | BA |
| 5170-03-DW-009 | Across from Room 312-Left | 12/15/2016 | 0.32 | BA |
| 5170-03-DW-010 | Across from Room 312-Right | 12/15/2016 | 0.35 | BA |
| 5170-01-KC-011 | Room 102 Teacher's Lounge | 12/15/2016 | 0.32 | BA |
| 5170-01-IM-012 | Cafeteria Kitchen Ice Machine | 12/15/2016 | 0.054 | BA |
| 5170-01-KC-013 | Cafeteria Kitchen at Entrance-Left | 12/15/2016 | 6.3 | BA |
| 5170-01-KC-014 | Cafeteria Kitchen at Entrance-Center Pot Fill | 12/15/2016 | 0.76 | BA |
| 5170-01-KC-015 | Cafeteria Kitchen at Entrance-Right | 12/15/2016 | 0.76 | BA |
| 5170-01-KC-016 | Cafeteria Kitchen-Far Wall | 12/15/2016 | 0.36 | BA |
| 5170-01-CF-017 | Room 151C-Nurse's Exam Room | 12/15/2016 | 0.3 | BA |
| 5170-01-CF-018 | Room120-Kindergarten | 12/15/2016 | 0.26 | BA |
| 5170-01-CF-019 | Room 121-Kindergarten | 12/15/2016 | 0.71 | BA |
| 5170-01-CF-020 | Room 123-Autistic Support | 12/15/2016 | 0.42 | BA |
| 5170-01-CF-021 | Room 125-Kindergarten | 12/15/2016 | 1.7 | BA |
| 5170-01-CF-022 | Room 129-Special Ed Life Skills | 12/15/2016 | 0.33 | BA |
| 5170-01-CF-023 | Room 130-Special Ed Life Skills | 12/15/2016 | 0.89 | BA |
| 5170-01-CF-024 | Room 132-Autistic Support | 12/15/2016 | 0.64 | BA |
| 5170-01-CF-025 | Room 133-Autistic Support | 12/15/2016 | 1.7 | BA |
| 5170-01-CF-026 | Room 135-Kindergarten | 12/15/2016 | 0.38 | BA |
| 5170-01-CF-027 | Room 136-Kindergarten | 12/15/2016 | 0.30 | BA |

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb