

School Name: Day Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
6200-01-DW-021	Outside Room 104	12/14/2016	2.5	BA
6200-01-CF-030	Nurse's Office	12/14/2016	2.0	BA
6200-01-HS-034	In the hallway, outside of nurse's office	12/14/2016	0.054	BA
6200-01-HS-035	In the hallway, next to auditorium - right	12/14/2016	0.062	BA
6200-01-KC-037	Kitchen	12/14/2016	2.4	BA
6200-01-DW-038	Within the gymnasium	12/14/2016	3.6	BA
<i>outlets below are within the new building</i>		12/14/2016		BA
6200-01-HS-057N	Outside girl's bathroom and teachers lounge - left	12/14/2016	0.054	BA
6200-01-WC-058N	Outside girl's bathroom and teachers lounge - right	12/14/2016	0.063	BA
6200-01-DW-059N	Room 9	12/14/2016	0.25	BA
6200-01-DW-061N	Room 11	12/14/2016	0.26	BA
6200-01-DW-062N	Room 12	12/14/2016	0.12	BA
6200-01-DW-063N	Room 8	12/14/2016	0.15	BA
6200-01-DW-064N	Room 7	12/14/2016	0.27	BA
6200-01-DW-068N	Room 3 - kindergarten	12/14/2016	0.23	BA
6200-01-DW-069N	Room 2 - head start	12/14/2016	0.13	BA
6200-01-KC-070N	kitchen - left	12/14/2016	2.6	BA
6200-01-KC-071N	Kitchen - right	12/14/2016	3.5	BA
6200-01-DW-072N	Teacher's Lounge	12/14/2016	0.22	BA
6200-01-CF-073N	Room 1 - head start	12/14/2016	0.11	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb