

School Name: Gideon Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
4530-01-DW-009	Outside Bathroom - Left	1/12/2017	5.9	BA
4530-01-DW-010	Outside Bathroom - Right	1/12/2017	5.4	BA
4530-01-DW-017	Inside Room 103, Head-Start Room (room not currently used)	1/12/2017	58.9	AA
4530-01-KC-022	Teacher's Dining Room - single lever faucet	1/12/2017	3.6	BA
4530-01-CF-029	Front Room of Nurse's Office	1/12/2017	2.1	BA
4530-01-HS-039	In hallway, outside Girl's Bathroom	1/12/2017	0.054	BA
4530-02-HS-048	In hallway, across from Room 207	1/12/2017	0.054	BA
4530-03-WC-065	Outside Room 308	1/12/2017	3.3	BA
4530-03-HS-074	In hallway, outside Men's and Women's bathroom	1/12/2017	0.054	BA
4530-03-KC-079	Room 316 A, Kitchen	1/12/2017	2.2	BA
4530-01-DW-086N	Room 104, kindergarten	1/12/2017	12.8	AA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb