

School Name: Benjamin Comegys Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
1260-03-DW-009	Outside Room 301	12/9/2016	2.5	BA
1260-03-HS-014	Outside Room 302	12/9/2016	0.074	BA
1260-02-DW-018	Outside Room 208	12/9/2016	1.1	BA
1260-02-DW-019	Outside Room 209	12/9/2016	1.5	BA
1260-01-HS-029	Between Auditorium and Stairway 2	12/9/2016	0.074	BA
1260-01-CF-035	Nurse's Office	12/9/2016	1.2	BA
1260-01-DW-038	Gymnasium - nearest kitchen	12/9/2016	118	AA
1260-01-DW-039	Gymnasium - opposite wall from kitchen	12/9/2016	1.1	BA
1260-02-HS-047	Outside Room 206	12/9/2016	0.054	BA
1260-02-DW-048	Outside Room 201	12/9/2016	1.5	BA
1260-01-DW-050	Across from Room 104	12/9/2016	0.96	BA
1260-01-DW-051	Across from Room 106	12/9/2016	1.0	BA
1260-00-DW-054	Outside Art Room - left	12/9/2016	2.1	BA
1260-00-DW-055	Outside Art Room - center	12/9/2016	2.2	BA
1260-00-DW-066	Kindergarten Room K-1	12/9/2016	2.5	BA
1260-00-DW-067	Kindergarten Room K-2	12/9/2016	3.3	BA
1260-00-DW-072	Across from Boy's Room - left outlet group - furthest right	12/9/2016	275	AA
1260-00-DW-073	Across from Boy's Room - right outlet group - furthest left	12/9/2016	6.3	BA
1260-00-DW-074	Across from Boy's Room - right outlet group - 2nd from left	12/9/2016	12.3	AA
1260-02-WC-087	Inside Teacher's Lounge	12/9/2016	0.19	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb