

School Name: Crossan Elementary School

| Outlet ID # | Outlet Location | Sample Collection Date | Test Result (ppb) | Test Results |
|----------------|--------------------------------|------------------------|-------------------|--------------|
| 8230-00-DW-005 | Outside of Girls Room - Left | 12/14/2016 | 2.5 | BA |
| 8230-00-DW-006 | Outside of Girls Room - Right | 12/14/2016 | 3.3 | BA |
| 8230-00-DW-009 | Outside of Boys Room - Left | 12/14/2016 | 12.0 | AA |
| 8230-00-DW-010 | Outside of Boys Room - Right | 12/14/2016 | 1.4 | BA |
| 8230-01-DW-011 | In Portable - pre-kindergarten | 12/14/2016 | 9.0 | BA |
| 8230-01-WC-014 | Outside of Room 6 | 12/14/2016 | 0.28 | BA |
| 8230-01-WC-020 | Outside of Room 3 | 12/14/2016 | 0.19 | BA |
| 8230-01-CF-022 | Nurse's Office | 12/14/2016 | 1.8 | BA |
| 8230-01-WC-024 | Room 1 - kindergarten | 12/14/2016 | 1.7 | BA |
| 8230-02-WC-026 | Outside of Room 9 | 12/14/2016 | 0.62 | BA |
| 8230-02-WC-031 | Outside of Room 13 | 12/14/2016 | 0.65 | BA |

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb