School Name: Nebinger Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
2590-04-WC-001	Outside Room 402	10/21/2016	0.67	BA
2590-04-HS-007	Outside Library Room 407	10/21/2016	<0.074	BA
2590-01-HS-028	Outside Room 106	10/21/2016	<0.074	BA
2590-01-DW-029	Room 106	10/21/2016	2.4	BA
2590-01-DW-038	Room 103	10/21/2016	39.9	AA
2590-01-DW-042	Outside Room 102	10/21/2016	1.4	BA
2590-02-DW-045	Outside Room 202	10/21/2016	1.1	BA
2590-02-DW-055	Outside Room 207	10/21/2016	1.4	BA
2590-03-DW-058	Outside Room 302	10/21/2016	0.96	BA
2590-03-HS-064	Outside Room 307	10/21/2016	<0.074	BA
2590-01-DW-078	Room 104	10/21/2016	2.4	BA
2590-01-DW-079	Room 105	10/21/2016	3.2	BA
2590-00-DW-085	Outside Boy's Room - Left	10/21/2016	0.78	BA
2590-00-DW-086	Outside Boy's Room	10/21/2016	2.0	BA
2590-00-DW-087	Outside Boy's Room	10/21/2016	1.7	BA
2590-00-DW-088	Outside Boy's Room	10/21/2016	1.4	BA
2590-00-DW-089	Outside Boy's Room	10/21/2016	0.61	BA
2590-00-DW-090	Outside Boy's Room - Right	10/21/2016	0.57	BA
2590-00-DW-091	Outside Girl's Room - Left	10/21/2016	2.7	BA
2590-00-DW-092	Outside Girl's Room	10/21/2016	2.2	BA
2590-00-DW-093	Outside Girl's Room	10/21/2016	2.5	BA
2590-00-DW-094	Outside Girl's Room	10/21/2016	5.7	BA
2590-00-DW-095	Outside Girl's Room	10/21/2016	2.2	BA
2590-00-DW-096	Outside Girl's Room - Right	10/21/2016	1.8	BA

DISTRICT ACTION LEVEL FOR LEAD IS 15 ppb\*

## SPREADSHEET LEGEND

BA - Below District Action Level of 15 ppb

AA - Above District Action Level of 15 ppb

<sup>\*</sup>EPA ACTION LEVEL FOR LEAD IS 20 ppb