

School Name: Overbrook High School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
4020-00-DW-009	Locker Room above Gymnasium 4	8/18/2016	21.2	AA
4020-01-DW-024	Outside "B" Cafeteria Site Map Room 114 - Left	8/18/2016	10.8	BA
4020-01-DW-025	Outside "B" Cafeteria Site Map Room 114	8/18/2016	6.7	BA
4020-01-DW-026	Outside "B" Cafeteria Site Map Room 114	8/18/2016	18.9	AA
4020-01-DW-028	Outside "B" Cafeteria Site Map Room 114	8/18/2016	34.8	AA
4020-01-DW-029	Outside "B" Cafeteria Site Map Room 114 - Right	8/18/2016	87.0	AA
4020-01-DW-056	Outside Room 100	8/18/2016	7.7	BA
4020-01-DW-057	Outside Room 100 -	8/18/2016	7.5	BA
4020-01-DW-064	Outside Men's Room - Across from Room 105	8/18/2016	11.4	BA
4020-02-DW-081	Outside Room 217 - Left	8/18/2016	7.8	BA
4020-02-DW-082	Outside Room 217 - Right	8/18/2016	7.9	BA
4020-02-DW-095	Outside Main Office - Left	8/18/2016	11.6	BA
4020-02-DW-096	Outside Main Office - Right	8/18/2016	9.4	BA
4020-03-DW-101	Outside Room 309 - Left	8/18/2016	14.2	BA
4020-03-DW-102	Outside Room 309 - Right	8/18/2016	14.3	BA
4020-03-DW-111	Outside Room 318 - Left	8/18/2016	16.3	AA
4020-03-DW-112	Outside Room 318 - Right	8/18/2016	4.3	BA
4020-03-DW-114	Outside Room 326 - Right	8/18/2016	6.3	BA
4020-01-DW-015	Outside of cafeteria - next to Room 112A - left	8/18/2016	6.3	BA
4020-01-DW-016	Outside of cafeteria - next to Room 112A -right	8/18/2016	9.8	BA
4020-00-DW-167	Inside Girl's Locker Room - Site Map Room 001A	8/18/2016	8.8	BA
4020-00-DW-171	Boy's Locker Room - Gym #2 - Site Map Room 010A	8/18/2016	11.2	BA
4020-01-DW-175	Inside Girls Gymnasium - Site Room Map 014A	8/18/2016	5.7	BA
4020-01-DW-177	Inside Boys Gymnasium - site Room Map 013A	8/18/2016	2.4	BA
4020-01-DW-178	Hallway outside of Boys Gymnasium - Site Map Rm 013A	8/18/2016	6.7	BA
4020-01-DW-181	Outside of Boys Gymnasium - Near Exit to Oxford Avenue	8/18/2016	9.3	BA
4020-00-WC-190	Adjacent to Kitchen (Child Care)	8/18/2016	0.63	BA
4020-00-WC-191	South Classroom - 004 Site Map - Child Care	8/18/2016	0.85	BA
4020-00-DW-212	Bldg Engineer Office Area - companion to conventional sink	8/18/2016	33.6	AA

DISTRICT ACTION LEVEL FOR LEAD IS 15 ppb*

SPREADSHEET LEGEND

BA - Below EPA Action Level of 15 ppb

AA - Above EPA Action Level

*EPA ACTION LEVEL FOR LEAD IS 20 ppb