

School Name: Ethan Allen Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
8200-00-DW-009	Bubbler across from the girl's room - Left	11/29/2016	0.86	BA
8200-00-DW-010	Bubbler across from the girl's room	11/29/2016	0.25	BA
8200-00-DW-011	Bubbler across from the girl's room	11/29/2016	0.35	BA
8200-00-DW-012	Bubbler across from the girl's room	11/29/2016	0.17	BA
8200-00-DW-013	Bubbler across from the girl's room - Right	11/29/2016	0.31	BA
8200-00-KC-016	Kitchen	11/29/2016	0.48	BA
8200-00-DW-017	Gym - Left	11/29/2016	2.4	BA
8200-00-DW-018	Gym - Right	11/29/2016	2.2	BA
8200-00-DW-026	Bubblers outside room 04 - Left	11/29/2016	1.3	BA
8200-00-DW-027	Bubblers outside room 04	11/29/2016	1.4	BA
8200-00-DW-028	Bubblers outside room 04	11/29/2016	1.4	BA
8200-00-DW-029	Bubblers outside room 04	11/29/2016	2.5	BA
8200-00-DW-030	Bubblers outside room 04 - Right	11/29/2016	1.0	BA
8200-01-DW-034	Room 108	11/29/2016	12.1	AA
8200-01-DW-038	Outside Room 107	11/29/2016	0.93	BA
8200-01-DW-041	Outside Room 104	11/29/2016	0.51	BA
8200-01-DW-044	Room 101	11/29/2016	0.13	BA
8200-02-CF-047	Nurse's office	11/29/2016	2.0	BA
8200-02-DW-051	Outside Room 204	11/29/2016	0.48	BA
8200-02-DW-052	Outside Room 207	11/29/2016	0.61	BA
8200-03-DW-057	Outside Room 307	11/29/2016	0.51	BA
8200-03-DW-058	Outside Room304	11/29/2016	0.45	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb\*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

\*EPA ACTION LEVEL FOR LEAD IS 20 ppb