

School Name: **Carnell Elementary School**

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
7220-00-KC-003	Cafeteria Kitchen	12/7/2016	0.56	BA
7220-00-DW-005	Room 2	12/7/2016	4.5	BA
7200-00-DW-006	Outside Girl's Room - left	12/7/2016	1.1	BA
7220-00-DW-007	Outside Girl's Room	12/7/2016	0.52	BA
7220-00-DW-008	Outside Girl's Room	12/7/2016	0.80	BA
7220-00-DW-009	Outside Girl's Room	12/7/2016	1.6	BA
7220-00-DW-010	Outside Girl's Room	12/7/2016	0.40	BA
7220-00-DW-011	Outside Girl's Room - right	12/7/2016	0.83	BA
7220-00-DW-020	Outside Room B4- left	12/7/2016	1.2	BA
7220-00-DW-022	Outside Room B4	12/7/2016	1.4	BA
7220-00-DW-024	Outside Room B4	12/7/2016	0.94	BA
7200-00-DW-025	Outside Room B4 - right	12/7/2016	1.1	BA
7200-00-DW-033	Across from Room 5	12/7/2016	7.7	BA
7220-00-DW-037	Element 2 - Room 7 - right side	12/7/2016	3.4	BA
7220-01-DW-041	Across from Room 111 - right	12/7/2016	3.5	BA
7220-01-DW-046	Hallway, outside Room 107	12/7/2016	2.3	BA
7220-01-HS-049	Outside Room 104	12/7/2016	0.054	BA
7220-01-DW-050	Room 104	12/7/2016	4.1	BA
7220-01-DW-055	Inside Room 103 - classroom	12/7/2016	0.75	BA
7220-01-DW-060	Inside Room 101 - kindergarten	12/7/2016	2.1	BA
7220-02-KC-062	Outside Girl's Room at IMC	12/7/2016	5.1	BA
7220-02-HS-066	Outside Girl's Room at IMC	12/7/2016	0.054	BA
7220-02-CF-071	Nurse's Office - across from Room 202	12/7/2016	2.6	BA
7220-03-DW-077	Element 2 - Hallway at Room 312 - left	12/7/2016	5.8	BA
7220-03-DW-078	Element 2 - Hallway at Room 312 - right	12/7/2016	0.054	BA
7220-03-DW-083	Outside Room 307	12/7/2016	3.4	BA
7220-03-HS-084	Outside Room 304	12/7/2016	0.054	BA
7220-01-HS-090N	Hallway Outside Multi-Purpose Room - left	12/7/2016	0.054	BA
7220-01-WC-091N	Hallway Outside Multi-Purpose Room - right	12/7/2016	0.054	BA
7220-01-KC-092N	Cafeteria Kitchen - left	12/7/2016	3.7	BA
7220-01-KC-093N	Cafeteria Kitchen - right	12/7/2016	1.1	BA
7220-01-DW-094N	Room A1 - Special Education	12/7/2016	0.52	BA
7220-01-DW-095N	Room A2 - Special Education	12/7/2016	0.2	BA
7220-01-DW-096N	Room A3 - Special Education	12/7/2016	0.27	BA
7220-01-DW-097N	Room A4 - Special Education	12/7/2016	0.28	BA
7220-01-DW-098N	Room A5 - Special Education	12/7/2016	0.19	BA
7220-01-DW-099N	Room A6 - Special Education	12/7/2016	0.3	BA
7220-01-DW-100N	Room A7 - Special Education	12/7/2016	0.18	BA
7220-01-DW-101N	Room A8 - Special Education	12/7/2016	0.33	BA
7220-01-DW-104N	Room A11 - Special Education	12/7/2016	0.22	BA
7220-01-DW-105N	Room A-12 - Special Education	12/7/2016	0.12	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb\*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

\*EPA ACTION LEVEL FOR LEAD IS 20 ppb