

School Name: Ludlow Elementary School and Annex

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
5340-00-WC-011	Cafeteria - Right	8/19/2016	2.8	BA
5340-01-WC-022	Across from Room 105	8/19/2016	1.2	BA
5340-02-WC-030	Across from Room 203	8/19/2016	3.6	BA
5340-02-WC-034	Across from Room 207	8/19/2016	1.3	BA
5340-03-WC-038	Across from Room 307	8/19/2016	2.9	BA
5340-03-WC-041	Across From Room 303	8/19/2016	0.48	BA
5340-00-WC-043N	Cafeteria - conventional outlet part of bottle filling station	8/19/2016	0.084	BA
5340-00-WC-044N	Cafeteria - outlet that is the bottle filling station	8/19/2016	0.054	BA
5340-01-WC-045N	Outside Rm 102 - conventional outlet part of bottle filling station	8/19/2016	0.054	BA
5340-01-WC-046N	Outside Rm 102 - outlet that is the bottle filling station	8/19/2016	0.054	BA
5341-01-DW-007	Outside of Girl's Locker Room - Annex	8/19/2016	3.2	BA
5341-01-WC-010	Outside of Girl's Room - Left - Annex	8/19/2016	3.0	BA
5341-01-WC-011	Outside of Girl's Room - Right - Annex	8/19/2016	2.6	BA

DISTRICT ACTION LEVEL FOR LEAD IS 15 ppb*

SPREADSHEET LEGEND

BA - Below EPA Action Level of 15 ppb

AA - Above EPA Action Level

*EPA ACTION LEVEL FOR LEAD IS 20 ppb