

School Name: Cayuga Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
5490-00-DW-002	Gymnasium - Left	12/8/2016	0.48	BA
5490-00-DW-003	Gymnasium - Right	12/8/2016	0.21	BA
5490-00-DW-006	Café adjacent to Boys Room - Left	12/8/2016	0.065	BA
5490-00-DW-007	Café adjacent to Boys Room - Right	12/8/2016	0.054	BA
5490-00-KC-012	Cafeteria Kitchen - left	12/8/2016	0.96	BA
5490-00-KC-014	Cafeteria Kitchen - right	12/8/2016	2.3	BA
5490-01-DW-017	Room 120 - kindergarten	12/8/2016	4.5	BA
5490-01-DW-020	Room 119 - kindergarten	12/8/2016	7.9	BA
5490-01-DW-023	Room 117 - kindergarten	12/8/2016	15.5	AA
5490-01-DW-026	Room 118 - kindergarten	12/8/2016	3.3	BA
5490-01-DW-030	Adjacent Elevator - Left	12/8/2016	0.20	BA
5490-01-DW-031	Adjacent Elevator - Right	12/8/2016	0.11	BA
5490-01-BF-037	Nurse's Suite - Bathroom	12/8/2016	1.8	BA
5490-02-DW-038	Adjacent Elevator - Left	12/8/2016	0.082	BA
5490-02-DW-039	Adjacent Elevator - Right	12/8/2016	0.31	BA
5490-03-DW-046	Adjacent Elevators - Left	12/8/2016	0.054	BA
5490-03-DW-047	Adjacent Elevators - Right	12/8/2016	0.054	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb