

School Name: Penn Alexander Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
1280-00-WC-001	Cafeteria, Room B01 – Left Side	10/28/2016	<0.054	BA
1280-00-WC-002	Cafeteria, Room B01 – Right Side	10/28/2016	<0.054	BA
1280-00-WC-003	Outside Library Room B23 – Left Side	10/28/2016	0.29	BA
1280-00-WC-004	Outside Library Room B23 – Right Side	10/28/2016	1.2	BA
1280-01-WC-005	Main Office Outside Room 125 – Floor 1R	10/28/2016	0.55	BA
1280-01-WC-006	Gym, Room 100 – Left Side (at Boys Restroom)	10/28/2016	<0.054	BA
1280-01-WC-007	Gym, Room 100 – Right Side (at Girls Restroom)	10/28/2016	<0.054	BA
1280-01-WC-008	Between Restrooms across from Room 109	10/28/2016	<0.054	BA
1280-01-WC-009	Between Restrooms across from Room 118	10/28/2016	<0.054	BA
1280-01-WC-010	Next to Room 135 at Elevator – Left Side – Floor 1R	10/28/2016	0.057	BA
1280-01-WC-011	Next to Room 135 at Elevator – Right Side – Floor 1R	10/28/2016	0.12	BA
1280-02-WC-012	Between Restrooms across from Room 209	10/28/2016	0.14	BA
1280-02-WC-013	Between Restrooms across from Room 218	10/28/2016	0.18	BA
1280-02-WC-014	Next to Room 233 at elevator – Left Side – Floor 2R	10/28/2016	0.68	BA
1280-02-WC-015	Next to Room 233 at elevator – Right Side – Floor 2R	10/28/2016	0.82	BA
1280-03-WC-016	Between Restrooms at Room 309	10/28/2016	0.31	BA
1280-03-WC-017	Between Restrooms at Room 318	10/28/2016	<0.054	BA

DISTRICT ACTION LEVEL FOR LEAD IS 15 ppb\*

SPREADSHEET LEGEND

BA - Below District Action Level of 15 ppb

AA - Above District Action Level of 15 ppb

\*EPA ACTION LEVEL FOR LEAD IS 20 ppb