

School Name: Disston Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
8240-00-DW-009	Outside Gym/Lunchroom - right side of the wall - left	8/19/2016	5.9	BA
8240-00-DW-010	Outside Gym/Lunchroom - right side of the wall - center	8/19/2016	11.2	BA
8240-00-DW-011	Outside Gym/Lunchroom - right side of the wall - right	8/19/2016	7.1	BA
8240-01-DW-033	Outside Room 103	8/19/2016	1.3	BA
8240-01-DW-042	Outside Room 106	8/19/2016	5.8	BA
8240-02-DW-046	Outside Rooms 206 and 207	8/19/2016	9.9	BA
8240-02-DW-051	Outside Room 203	8/19/2016	2.5	BA
8240-03-DW-059	Outside Room 303	8/19/2016	1.3	BA
8240-03-DW-065	Outside Room 311	8/19/2016	4.5	BA
8240-01-DW-077N	Room 105 - combined with classroom faucet	8/19/2016	5.2	BA
8240-00-DW-081	Across from Room B6 - left	8/19/2016	4.6	BA
8240-00-DW-082	Across from Room B6 - right	8/19/2016	4.7	BA
8240-00-DW-083	Outside of Gymnasium (near 009, 010 & 011)	8/19/2016	7.0	BA
8240-00-DW-084	Outside Room B-1 (near staircase) - left	8/19/2016	1.7	BA
8240-00-DW-085	Outside Room B-1 (near staircase) - right	8/19/2016	1.7	BA
8240-02-DW-087N	Deans Office - Room 203A	8/19/2016	1.3	BA

DISTRICT ACTION LEVEL FOR LEAD IS 15 ppb\*

SPREADSHEET LEGEND

BA - Below EPA Action Level of 15 ppb

AA - Above EPA Action Level

\*EPA ACTION LEVEL FOR LEAD IS 20 ppb