

School Name: Decatur Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
8420-00-DW-012	Outside bathrooms - near kitchen	7/22/2016	2.1	BA
8420-00-DW-018	In Gym	7/22/2016	5.6	BA
8420-01-DW-021	In IMC - element 2	7/22/2016	0.38	BA
8420-01-WC-022	In IMC - element 2	7/22/2016	0.30	BA
8420-01-DW-040	Across from Main Office	7/22/2016	4.6	BA
8420-01-DW-054	Outside bathrooms (element 1)	7/22/2016	2.9	BA
8420-02-DW-062	Across from Rooms 200 & 202	7/22/2016	4.8	BA
8420-02-DW-068	Across from Room 214	7/22/2016	2.9	BA
8420-02-DW-073	Outside Room 220	7/22/2016	3.9	BA
8420-03-DW-082	Across from Room 320	7/22/2016	4.2	BA
8420-03-DW-087	Across from Room 314	7/22/2016	4.2	BA
8420-03-DW-093	Across from Rooms 300 & 302	7/22/2016	2.8	BA
8420-01-WC-101	Outside bathrooms - element 4	7/22/2016	1.7	BA
8240-01-WC-108	Outside Room A10 - Element 4	7/22/2016	2.0	BA
8240-01-WC-115N	Home and School Room - Element 3	7/22/2016	16.5	AA
8240-01-WC-116N	Music/Psychology Room - Element 3	7/22/2016	2.2	BA

DISTRICT ACTION LEVEL FOR LEAD IS 15 ppb*

SPREADSHEET LEGEND

BA - Below EPA Action Level of 15 ppb

AA - Above EPA Action Level

*EPA ACTION LEVEL FOR LEAD IS 20 ppb