

School Name: Cook Wissahickon School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
6410-00-WC-004	Outside boy's room; across from Boiler Room	12/13/16	1.1	BA
6410-00-KC-007	Kitchen Cold - Left	12/13/16	2.9	BA
6410-00-KC-008	Kitchen Cold - Right	12/13/16	1.5	BA
6410-00-CF-009	Staff Lounge Kitchenette	12/13/16	1.8	BA
6410-00-WC-010	Staff Lounge	12/13/16	89.1	AA
6410-00-HS-011	Outside Staff dining room	12/13/16	0.054	BA
6410-00-DW-030	In gymnasium - next to spittoon	12/13/16	0.26	BA
6410-00-HS-031	Outside Rom 3	12/13/16	0.054	BA
6410-00-DW-034	Room 3	12/13/16	3.9	BA
6410-00-DW-037	Room 2	12/13/16	3.2	BA
6410-00-DW-041	Room K-1	12/13/16	2.6	BA
6410-00-WC-043	Outside Room K-1	12/13/16	8.0	BA
6410-01-CF-044	Nurse's Office	12/13/16	3.6	BA
6410-01-WC-047	Across from Room 101	12/13/16	2.1	BA
6410-01-HS-049	Across from Room 103	12/13/16	0.054	BA
6410-01-WC-059	Outside Room 106	12/13/16	0.97	BA
6410-01-CF-060	Room 108 - Special Needs	12/13/16	39.8	AA
6410-01-HS-063	Outside Room 110	12/13/16	0.054	BA
6410-02-WC-075	Room 200A; Outside Women's Room	12/13/16	2.8	BA
6410-02-HS-079	Outside Room 204; Women's Room	12/13/16	0.33	BA
6410-02-WC-090	Outside Room 206	12/13/16	0.96	BA
6410-02-KC-095	Room 212 - Special Needs	12/13/16	2.3	BA
6410-02-HS-097	Outside Room 212	12/13/16	0.054	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb\*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

\*EPA ACTION LEVEL FOR LEAD IS 20 ppb