

School Name: **Wright Elementary School**

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
4470-01-WC-006	In Café-Auditorium - near Room 104A	10/27/2016	1.3	BA
4470-01-WC-007	In Café-Auditorium - near Room 101B	10/27/2016	1.3	BA
4470-01-WC-011	Cooler outside Womens Room	10/27/2016	0.42	BA
4470-01-DW-033	Corner of Gym near Boys Room	10/27/2016	1.3	BA
4470-01-DW-034	Opposite Corner of 033	10/27/2016	0.39	BA
4470-01-WC-037	Cooler across from Art Room	10/27/2016	1.7	BA
4470-01-WC-039	Across from Room 122	10/27/2016	0.71	BA
4470-01-WC-040	Outside of Room 122	10/27/2016	0.95	BA
4470-01-WC-052	Outside of Room 114	10/27/2016	0.98	BA
4470-02-DW-059	Room 224	10/27/2016	9.9	BA
4470-02-DW-061	Room 223	10/27/2016	5.3	BA
4470-02-WC-065	Across from Rm 221	10/27/2016	0.54	BA
4470-02-DW-070	Room 219	10/27/2016	8.6	BA
4470-02-DW-072	Room 220	10/27/2016	11.9	BA
4470-02-WC-080	Across from Room 216	10/27/2016	0.57	BA
4470-02-DW-081	Room 216	10/27/2016	4.8	BA
4470-02-WC-089	Across from Room 209	10/27/2016	2.2	BA
4470-02-DW-103	Room 207	10/27/2016	9.9	BA
4470-02-DW-109	Room 205	10/27/2016	5.6	BA
4470-02-DW-116	Room 203	10/27/2016	3.6	BA
4470-01-DW-123	Room 114	10/27/2016	2.6	BA

DISTRICT ACTION LEVEL FOR LEAD IS 15 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 15 ppb

AA - Above District Action Level of 15 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb