School Name: Finletter Elementary School

-	<u></u>	1	1	
Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
7270-00-KC-013	Cafeteria Kitchen	12/23/2016	0.35	BA
7270-01-DW-032	Outside Boy's Room	12/23/2016	1.8	BA
7270-01-HS-035	Outside Room 104	12/23/2016	0.054	BA
7270-01-CF-038	Room 102 - Special Education	12/23/2016	2.2	BA
7270-01-DW-042	Room 101	12/23/2016	3.7	BA
7270-02-CF-044	Nurse's Office	12/23/2016	3.6	BA
7270-02-HS-048	Outside Room 204	12/23/2016	0.054	BA
7270-02-WC-049	Outside Room 207	12/23/2016	0.76	BA
7270-02-CF-052	Room 210 - Special Education	12/23/2016	6.6	BA
7270-03-HS-055	Outside Room 307	12/23/2016	0.074	BA
7270-01-WC-060	Portable	12/23/2016	30.4	AA
7270-00-WC-062	In the hallway, outside of the Girl's Room - right	12/23/2016	0.13	BA
7270-00-WC-063	In the hallway, outside of the Girl's Room - left	12/23/2016	0.27	BA
7270-00-WC-064	In the hallway, outside of the Boy's Room - right	12/23/2016	0.39	BA
7270-00-WC-065	In the hallway, outside of the Boy's Room - left	12/23/2016	0.47	BA
Little School House Bui	lding			
7270-01-DW-068N	Room K-2; Kindergarten	12/23/2016	0.23	BA
7270-01-DW-069N	Room K-3; Kindergarten	12/23/2016	2.9	BA
7270-01-DW-070N	Room K-4; Kindergarten	12/23/2016	0.19	BA
7270-01-WC-071N	Outside Multi-Purpose Room - left	12/23/2016	0.099	BA
7270-01-HS-072N	Outside Multi-Purpose Room - right	12/23/2016	0.074	BA
7270-01-KC-073N	Multi-Purpose Room Kitchen- left	12/23/2016	1.5	BA
7270-01-KC-074N	Multi-Purpose Room Kitchen- right	12/23/2016	10.8	AA
7270-01-DW-075N	Room A-5; 1st Grade	12/23/2016	0.13	BA
7270-01-DW-076N	Room A-6; 1st Grade	12/23/2016	0.18	BA
7270-01-DW-077N	Room A-7; 1st Grade	12/23/2016	0.33	BA
7270-01-DW-078N	Room A-8; 1st Grade	12/23/2016	0.28	BA
7270-01-DW-079N	Room A-9; 2nd Grade	12/23/2016	0.13	BA
7270-01-DW-080N	Room A-10; Second Grade	12/23/2016	0.13	BA
7270-01-DW-081N	Room A-11; Second Grade	12/23/2016	0.18	BA
7270-01-DW-082N	Room A-12; Second Grade	12/23/2016	0.20	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb\*

## SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb AA - Above District Action Level of 10 ppb

<sup>\*</sup>EPA ACTION LEVEL FOR LEAD IS 20 ppb