

School Name: Greenberg Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
8430-00-KC-011	Double sink in Kitchen - left	1/13/2017	7.5	BA
8430-00-KC-013	Double sink in Kitchen - right	1/13/2017	7.0	BA
8430-00-WC-015	Cafeteria - left unit	1/13/2017	1.7	BA
8430-00-WC-016	Cafeteria - right unit	1/13/2017	5.8	BA
8430-01-WC-018	Outside kindergarten Room 108	1/13/2017	7.8	BA
8430-01-WC-019	In kindergarten Room 108	1/13/2017	0.29	BA
8430-01-DW-028	Gymnasium	1/13/2017	0.80	BA
8430-01-WC-033	Across from bathrooms - left	1/13/2017	3.3	BA
8430-01-CF-046	Teacher's Lounge	1/13/2017	2.5	BA
8430-01-CF-047	Nurse's Sink	1/13/2017	0.86	BA
8430-01-WC-048	Across from Room 103	1/13/2017	4.3	BA
8430-02-WC-049	Across from Room 203	1/13/2017	2.9	BA
8430-02-WC-060	Across from Room 211	1/13/2017	0.37	BA
8430-02-WC-063	Across from Room 217	1/13/2017	13.7	AA
8430-03-WC-064	Across from Room 321	1/13/2017	1.6	BA
8430-03-WC-075	Across from Room 303	1/13/2017	9.8	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb\*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

\*EPA ACTION LEVEL FOR LEAD IS 20 ppb