

**School Name:** Fell Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
2190-00-KC-012	Lunchroom kitchennette	12/22/2016	0.65	BA
2190-01-DW-020	Room 107 - kindergarten	12/22/2016	5.3	BA
2190-01-DW-022	Outside Room 107	12/22/2016	3.9	BA
2190-01-DW-027	Outside Girl's Room	12/22/2016	2.5	BA
2190-02-DW-034	Outside Girl's Room	12/22/2016	2.1	BA
2190-02-DW-039	Outside Room 207	12/22/2016	2.6	BA
2190-02-BF-040	Nurse's Office bathroom	12/22/2016	3.5	BA
2190-03-DW-042	Outside Room 302	12/22/2016	2.6	BA
2190-01-DW-046	Room 100 - kindergarten	12/22/2016	2.1	BA
2190-00-DW-058	Outside Girl's Room - Left	12/22/2016	0.70	BA
2190-00-DW-059	Outside Girl's Room - Right	12/22/2016	1.1	BA
2190-00-DW-060	Outside Boy's Room - Left	12/22/2016	0.36	BA
2190-00-DW-061	Outside Boy's Room - Right	12/22/2016	0.68	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb\*

**SPREADSHEET LEGEND**

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

\*EPA ACTION LEVEL FOR LEAD IS 20 ppb