

School Name: Edmonds Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
6210-00-HS-003	Outside boiler room - left	12/16/2016	0.054	BA
6210-00-DW-016	Inside Cafeteria - on column - close to kitchen	12/16/2016	3.2	BA
6210-01-DW-018	Outside Room 115A - left	12/16/2016	2.0	BA
6210-01-CF-027	Nurse's Office	12/16/2016	3.0	BA
6210-01-HS-037	Outside Men's Room - left	12/16/2016	0.054	BA
6210-01-DW-054	Across from Room 103 - left	12/16/2016	2.5	BA
6210-01-DW-055	Across from Room 103 - right	12/16/2016	0.93	BA
6210-02-DW-072	Section B; in hallway, outside bathrooms and Room 205 - left	12/16/2016	1.4	BA
6210-02-DW-073	Section B; in hallway, outside bathrooms and Room 205 - right	12/16/2016	0.54	BA
6210-02-HS-087	Outside Room 212 - left	12/16/2016	0.054	BA
6210-02-DW-098	Outside Room 217A	12/16/2016	6.9	BA
<u>Annex Building</u>				
6210-00-WC-108N	Outside Room 126 - left	12/16/2016	0.054	BA

DISTRICT ACTION LEVEL FOR LEAD IS 10 ppb*

SPREADSHEET LEGEND

BA - Below District Action Level of 10 ppb

AA - Above District Action Level of 10 ppb

*EPA ACTION LEVEL FOR LEAD IS 20 ppb