

School Name: Blankenburg Elementary School

Outlet ID #	Outlet Location	Sample Collection Date	Test Result (ppb)	Test Results
1490-00-DW-002	Outside Building Engineer's office - Left	8/11/2016	0.89	BA
1490-00-DW-003	Outside Building Engineer's office - Center	8/11/2016	2.4	BA
1490-00-DW-004	Outside Building Engineer's office - Right	8/11/2016	3.0	BA
1490-00-DW-007	Across from Gym - Left - near Room 027	8/11/2016	5.8	BA
1490-00-DW-009	Across From Gym - Right - near Room 027	8/11/2016	3.6	BA
1490-00-DW-010	Across from Gym - Left - Near Room 030	8/11/2016	2.2	BA
1490-00-DW-012	Across from Gym - Right - Near Room 030	8/11/2016	2.1	BA
1490-00-DW-013	Across from IMC Room 003B - left	8/11/2016	9.5	BA
1490-00-DW-015	Across from IMC Room 003B - right	8/11/2016	3.6	BA
1490-01-WC-016	Outside Room 003	8/11/2016	0.59	BA
1490-01-DW-024	In Room 004 (K-4)	8/11/2016	1.3	BA
1490-01-WC-028	Outside Room 005	8/11/2016	6.2	BA
1490-02-DW-032	Outside Room 014	8/11/2016	3.5	BA
1490-02-DW-038	Outside Room 010	8/11/2016	0.95	BA
1490-03-DW-047	Outside Room 018	8/11/2016	3.0	BA
1490-02-DW-051	Outside Room 026	8/11/2016	2.9	BA
1490-00-DW-078N	Day Care Room 027	8/11/2016	0.81	BA
1490-00-DW-079N	Day Care Room 029	8/11/2016	3.3	BA

DISTRICT ACTION LEVEL FOR LEAD IS 15 ppb\*

SPREADSHEET LEGEND

BA - Below EPA Action Level of 15 ppb

AA - Above EPA Action Level